

MSO/CEPO(GT)

F. No. J-11011/413/2008- IA II (I)
Government of India
Ministry of Environment and Forests
(I.A. Division)

Paryavaran Bhawan
CGO Complex, Lodhi Road
New Delhi – 110 003

E-mail : aditya.narayan@nic.in
Telefax : 011: 2436 549
Dated 20th September, 2012

To,

Shri A. Buragohain,
General Manager (PROD-Oil) I/C
M/s Oil India Limited, P.O. Duliajan
Dibrugarh-786 602, Assam

Email : lahiri_joydev@yahoo.co.in ; safety@oilindia.in; ecpldelhi@rediffmail.com;
Fax No.: 0374-2804888

Subject: Setting up of Four Development Projects viz. (1) Oil Collecting Station (OCS) at Bhogpara; (2) Augmentation of Capacity of Intermediate Tank Farm (ITF) at Tengakhat; (3) New Browser Unloading Station (BUS) at Makum & (4) Hapjan-Savitri Crude Oil Pipeline in Tengakhat-Naharkatia-Jorajan (TNS) area District Dibrugarh and Tinsukhia, Assam by M/s Oil India Limited (OIL) – Amendment reg.

Ref. : (i) Ministry's letter of even no. dated 24th January, 2011.
(ii) Your letter no. OIL/CORP/EC-ITF/MOEF/030 dated 13th December, 2011.

Sir,

This has reference to your letter dated 13th December, 2011 regarding change in environmental condition in respect of total storage capacity of the oil tank and further attention is invited to Ministry's letter no J-11011/413/2008- IA II (I) dated 24th January, 2011. Following amendment may be made in the Ministry's letter no. J-11011/413/2008- IA II (I) dated 24th January, 2011:

Para 6.0; A SPECIFIC CONDITIONS, S.N. Viii:

For:

"Total storage capacity of the oil tanks shall not exceed 40,000 KL after expansion. Capacity of the each of the storage tank shall not exceed 5,000 KL. Instead of fixed roof tanks, floating roof tanks shall be provided."

Read:

"Total storage capacity of the oil tanks shall not exceed 40,000 KL after expansion. Capacity of the each of the storage tank shall not exceed 20,000 KL. Instead of fixed roof tanks, floating roof tanks shall be provided."

2.0 All other conditions will remain unchanged.

A-1

3.0 You are also requested to keep this letter with the environmental clearance accorded vide letter no. J-11011/413/2008- IA II (I) dated 24th January, 2011.

4.0 This has been issued with the prior approval of Competent Authority.

Asi

(A N Singh)
Dy. Director

1. Chairman, Assam Pollution Control Board, Bahunimatram, Assam, Guwahati.
2. Chairman, Central Pollution Control Board, Parivesh Bhavan, CBD-cum-Office Complex, East Arjun Nagar, Delhi - 110032.
3. The Conservator of Forests (Central), Ministry of Environment & Forests, Regional Office (Northeast Eastern Regional Office, Uplands Road, Laitumkhrach, Shillong – 793003, Meghalaya.
4. Joint Secretary (IA-II), Ministry of Environment and Forests, Paryavaran Bhawan, CGO Complex, New Delhi.
5. Monitoring Cell, Ministry of Environment and Forests, Paryavaran Bhawan, CGO Complex, New Delhi.
6. Guard File.
7. Monitoring File.
8. Record File.

(A N Singh)
Dy. Director