

OIL INDIA LIMITED

(A Govt. Of India Enterprise) Tel :033 2230 1657, 1658
 4, India Exchange Place, Fax :91 33 2230 2596
 Kolkata-700001 E-mail :oilcalmn@cal2.vsnl.net.in

Tender No. & Date : KID4787L12/04 27.01.2012

Bid Security Amount : INR 0.00 OR USD 0.00
 (or equivalent Amount in any currency)

Bidding Type : Single Bid (Composite Bid)

Bid Closing On : 28.02.2012 at 14:00 hrs. (IST)
 Bid Opening On : 28.02.2012 at 14:00 hrs. (IST)

Performance Guarantee : Not Applicable

OIL INDIA LIMITED invites Limited tenders for items detailed below:

Item No./ Mat. Code	Material Description	Quantity	UOM
10 99003059	<p>Required for Maintenance/Extension of Existing Fire Fighting System in all establishments/installtions (Including Drilling & Workover) of Duliajan, Moran & Manabhum.</p> <p>SINGLE HEADED FIRE HYDRANT VALVE The Single Headed Fire Hydrants Valve (Landing Valves) assembly of "Type A" shall be consisting of Valve, Instantaneous female outlet and blank cap. The valve body, bonnet, stop valve, check nut, spindle, instantaneous female outlet and blank cap shall be made of Stainless Steel grade 1 & 4 of IS-3444. Hand wheel shall be made of mild steel conforming to IS: 1030-1989. Washers, Seat washer shall be made of rubber conforming to IS:937-1981. The spring shall be of phosphorous wire conforming to IS:7608-1987. The tooth of the lug shall be forged from brass material conforming to grade FLB of IS:6912-1985. The valve shall have 75mm flat faced drilled flanged inlet and flange outer diameter 200 mm with suitable PCD & number of holes as per relevant standard. The valve shall be tested to 14 Kg/cm² for valve seat and 21 Kg/cm² for body. All parts shall be of good finish, clear of burrs and sharp edges. All casting shall be clean and sound and shall be free from plugging, welding or repair of any defects. An additional matching flange should be supplied along with each valve. One pair of additional (spare) matching lugs should be provided with each valve. MARKING: Each assembled valve shall be clearly and permanently marked on the valve body, as follows: a) Manufacturer's Name or Trade Mark b) Code letter indication the type of valve c) Year of Manufacture d) ISI Certification Mark. The complete assembled valve shall be conforming to IS:5290-1993 and shall have the ISI Mark.</p>	50	NO

Tender No. & Date : KID4787L12/04 27.01.2012

Item No./ Mat. Code	Material Description	Quantity	UOM
20 99071391	<p>The Double Headed Fire Hydrants Valve (Landing Valves) assembly of #Type B# shall be consisting of Valve, Instantaneous female outlet and blank cap. The valve body, bonnet, stop valve, check nut, spindle, instantaneous female outlet and blank cap shall be made of Stainless Steel grade 1 & 4 of IS-3444. Hand wheel shall be made of mild steel conforming to IS: 1030-1989. Washers, Seat washer shall be made of rubber conforming to IS:937-1981.</p> <p>The spring shall be of phosphorous wire conforming to IS:7608-1987. The tooth of the lug shall be forged from brass material conforming to grade FLB of IS:6912-1985.</p> <p>The valve shall have 100mm flat faced drilled flanged inlet and flange outer diameter 220 mm with suitable PCD & number of holes as per relevant standard.</p> <p>The valve shall be tested to 14 Kg/cm² for valve seat and 21 Kg/cm² for body. All parts shall be of good finish, clear of burrs and sharp edges. All casting shall be clean and sound and shall be free from plugging, welding or repair of any defects. An additional matching flange should be supplied along with each valve.</p> <p>One pair of additional (spare) matching lugs should be provided with each valve.</p> <p>MARKING:</p> <p>Each assembled valve shall be clearly and permanently marked on the valve body, as follows:</p> <p>a) Manufacturer's Name or Trade Mark b) Code letter indication the type of valve c) Year of Manufacture d) ISI Certification Mark.</p> <p>The complete assembled valve shall be conforming to IS:5290-1993 and shall have the ISI Mark.</p>	50	NO

- Special Notes** :
1. The bidder must submit BIS Certificate alongwith the offer, failing which offer may be liable for rejection.
 2. Inspection will be carried out at Supplier's Works before despatch by our Company Representative.
 3. Validity of offer: 75 days from the date of tender opening. Offer with validity less than 75 days will be rejected.
 4. The bidder must submit technical literature / catalogue of the offered product in duplicate along with the offer, failing which offer may be liable for rejection.
 5. Guarantee / Warranty certificate for one year will be required along with the supply.

Tender No. : KID4787L12/04
Tender Date : 27.01.2012
Bid Closing On : 28.02.2012 at 14:00 hrs.(IST)
Bid Opening On : 28.02.2012 at 14:00 hrs.(IST)

Tender issued to following parties only:

Slno	V_Code	Vendor Name	City/Country
1	200390	KOOVERJI DEVSHI & CO. PVT.LTD.	NAVI MUMBAI
2	201113	GUNNEBO INDIA LTD.	KOLKATA
3	201214	ZENITH FIRE SERVICES (INDIA) PVT.LT	MUMBAI
4	203287	NITIN FIRE PROTECTION INDUSTRIES LT	MUMBAI
5	203528	VIMAL FIRE CONTROLS PVT. LTD.	MUMBAI
6	204218	VIJAY FIRE VEHICLES AND PUMPS LTD	MUMBAI
7	204534	HD FIRE PROTECT PVT LTD.	THANE
8	204756	DEVRAJ ENGINEERS	GANDHINAGAR
9	205123	NEWAGE INDUSTRIES	SURENDRANAGAR