



ऑयल इंडिया लिमिटेड
OIL INDIA LIMITED
Materials Department
P.O. Duliajan, Dist. Dibrugarh
Assam, PIN –786 602, India,
Tel: (+91) 374 2808724
E-mail: panchali@oilindia.in

AMENDMENT NO. 02 DATED 04.08.2026 TO TENDER GEM/2026/B/7698630

This amendment is issued for the following:

1. Amendment to technical Specification has been shown as below.
2. BC date has been revised upto 19.08.2026.

All other terms and conditions of the tender remain unchanged.

Sd/-

(Panchali Thakuria)
DGM-FP 06
For CGM Materials HoD
For Resident Chief Executive

Amendment no. 2 to tender

Clause No	Existing	Amendment	Justification
Clause B	Accessories for above (For each unit): b) 1.1/4 inch ID x 75 feet (31.75 mm X 22.86 meters) return hose, 1000 PSI (70.31 kg/sq cm) WP with self sealing coupling (aero equip type) and dust cap / plug.	Accessories for above (For each unit): b) 1.1/4 inch ID x 75 feet (31.75 mm X 22.86 meters) return hose, 1000 PSI (70.31 kg/sq cm) WP with self sealing coupling (aero equip type) and dust cap / plug- 04 Numbers	Typographical error
Clause D	Electrical Spares The following identical Electrical Spares to be supplied with the offer (for 02 unit)	Electrical Spares The following identical Electrical Spares to be supplied with the offer (for 03 units)	Typographical error



ऑयल इंडिया लिमिटेड
OIL INDIA LIMITED
Materials Department
P.O. Duliajan, Dist. Dibrugarh
Assam, PIN –786 602, India,
Tel: (+91) 374 2808724
E-mail: panchali@oilindia.in

AMENDMENT NO. 01 DATED 18.07.2026 TO TENDER GEM/2026/B/7698630

This amendment is issued for the following:

1. Amendment to technical Specification has been shown as below.
2. BC date has been revised upto 05.08.2026.

All other terms and conditions of the tender remain unchanged.

Sd/-

(Panchali Thakuria)
DGM-FP 06
For CGM Materials HoD
For Resident Chief Executive

Amendment no. 1 to tender

Clause No	Existing	Amendment	Justification
A, (a)	Frame size E225 as per IS 1231	To be deleted	It is not a functional specification and hence can be deleted
A, (b), 2	The Motor Starter shall have Hand/OFF/Auto (HOA) mode selector switch to allow user to run the motor manually, as well as with all interlocks in place ("Auto" mode).	The Motor Starter shall have OFF/ON selector switch	An ON/OFF switch is adequate for safe local operation, simplifies the control circuit