

**BID CORRIGENDUM**

**AMENDMENT NO. 01 DATED 24.04.2024 To GEM BID NO.  
GEM/2024/B/4833791**

- 1.0 This addendum/corrigendum is issued to upload reply to pre-bid queries raised by the prospective bidders as under:

<b>Bidder's Query</b>	<b>OIL's reply</b>
Please confirm the type of panel is FIXED type or DRAWOUT MODULE type.	DRAWOUT MODULE type
As mentioned in the Technical Specification section of the Bid Document, Page number 3/7, " 2 modules in each vertical panel of the capacity of 37KW, The panels shall be exactly similar to the existing L&T make Type-SYNF633 panel of PCC-406 in all respect, As per SLD", but there is no SLD or Drawings attached in tender documents.	As already mentioned in the NIT, Bidders are advised to refer to Annexure IA for detailed technical specifications and bid accordingly.  Please ignore the clause mentioning " 2 modules in each vertical panel of the capacity of 37KW, The panels shall be exactly similar to the existing L&T make Type-SYNF633 panel of PCC-406 in all respect, As per SLD" as this is taken from GeM just for reference only.
As mentioned in ANNEXURE-IA, Technical Specifications, the buyer is requesting for 3.15 mm thick CRCA sheet and IEC-61439 standard, which has 2 mm sheet.	Kindly submit your offer with adherence to the IEC standard.

- 2.0 This reply to pre-bid queries shall be part of the NIT and all the bidders must submit their offer accordingly.  
3.0 This Bid End Date/Time and Bid Opening Date/Time shall also be amended as under in lieu of existing:

<b>Bid End Date/Time:</b>	<b>01-05-2024 14:00:00</b>
<b>Bid Opening Date/Time</b>	<b>01-05-2024 14:30:00</b>

- 4.0 All the Terms & Conditions of the Bid Document remain unaltered.

sd/-  
A. D. SINGH  
Manager (C&P)  
For General Manager (C&P)  
For Executive Director (RF)