

OIL INDIA LIMITED
(A Government of India Enterprise)
CONTRACTS DEPARTMENT
P.O.: Duliajan- 786602, Assam

CORRIGENDUM-3 DATED: 06.04.2024 TO TENDER NO. : CDI5748P24

This Corrigendum is issued to all concerned bidders of the aforesaid tenders to notify the following:

- i) Detailed specification mentioned under **Annexure-II to SCC** for **Item No. 300** (F & A Department Block Panel) under INTERNAL ELECTRIFICATION WORKS, Page No.144 of the Tender Document has been amended. The Revised specification for **Item No. 300** (F & A Department Block Panel) has been attached herewith.
- ii) Approved Make List of Electrical Items (as **Annexure-III to SCC**).

All others terms and conditions of the Bid Document remain unchanged. Details can be viewed at www.oil-india.com.


OFFICER-CONTRACTS (C)

Item No.	Item Name	Description
300	F & A Department Block Panel	<p>Block Panel :</p> <p>Incomer - I & II</p> <p>400A 4Pole 50kA MCCB with Microprocessor base LSIG Protection, Spreader, Extended Rotary Handle, Aux & Trip Contact 2 sets.</p> <p>Multifunction Meter 2Nos. , CT - 2Sets, Indicating Lamp, Control MCB</p> <p>50kA TPN SPD , Type1+2 - 2Nos. With protection MCB</p> <p>Incomer - III</p> <p>80A 4Pole 50kA MCCB with Microprocessor base LSIG Protection, Spreader, Extended Rotary Handle, Aux & Trip Contact 1 set.</p> <p>Multifunction Meter 1No. , CT - 1Set, Indicating Lamp, Control MCB</p> <p>50kA TPN SPD , Type1+2 - 1No. With protection MCB</p> <p>Outgoing Feeder :</p> <p>Each MCCB Feeder consist of On, Off, Trip Lamp, Spreader, Extended Rotary Handle, Aux. & Trip Contact Control MCB</p> <p>i) 250A FP 25kA Thermal based O/C & S/C MCCB - 2 Nos.</p> <p>ii) 160A FP 25kA Thermal based O/C & S/C MCCB - 4 Nos.</p> <p>iii) 100A FP 25kA Thermal based O/C & S/C MCCB - 3 Nos.</p> <p>iv) 63A FP 25kA Thermal based O/C & S/C MCCB - 8 Nos.</p> <p>v) 40A FP 10kA MCB - 5 Nos.</p> <p>vi) 25A FP 10kA MCB - 4 Nos.</p>

APPROVED MAKE OF ELECTRICAL ITEMS

Sl. No.:	Description of item	Approved Makes	
1	Single core BIS marked, copper, FRLSH PVC insulated multistranded 1100V grade cable/wire	FINOLEX/HAVELLS/POLYCAB/RR KABEL/KEI	
2	Multi core PVC Aluminium cable	FINOLEX/HAVELLS/POLYCAB/RR KABEL/KEI	
3	Earth wire	FINOLEX/HAVELLS/POLYCAB/RR KABEL/KEI	
4	Copper Lugs	DOWELL/3D-BILLET/JAINEX/SCHNEIDER	
5	PVC Casing Capping	PRESTO PLAST/AKG/PLAZA/RICHA/PRESTO TEAK	
6	PVC Casing Box	ANCHOR/LEGRAND/RICHA/PRESTOPLAST	
7	PVC Conduit	RICHA/ ANCHOR /PLAZA/AKG/ PRESTOPLAST	
8	PVC modular Board	PRESTO PLAST/AKG/PLAZA/RICHA/PRESTO TEAK	
9	20 A Metal Clad Switch-socket unit	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T	
10	Ceiling Fan, 1400 mm sweep, white in colour	HAVELLS/BAJAJ/ORIENT/USHA/CROMPTON GREAVES	
11	LIGHT FITTINGS (including Driver)	LED Batten, 2 feet & 4 ft	PHILIPS/CROMPTON/BAJAJ/HAVELLS/WIPRO
		LED downlighter	PHILIPS/CROMPTON/BAJAJ/HAVELLS/WIPRO
		LED 1x4 suspended	PHILIPS/CROMPTON/BAJAJ/HAVELLS/WIPRO
		Led 2x2 fittings	PHILIPS/CROMPTON/BAJAJ/HAVELLS/WIPRO
12	MCCB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T	
13	MCB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T	
14	RCBO	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T Note: RCBO, MCBs and box shall be of same make	
15	MCB DB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/ L&T Note: MCB DB and MCBs/RCBO fitted therein have to be of same make	
16	VTPN DB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T Note: VTPN DB and all components fitted therein have to be of same make	
17	TPN DB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T Note: TPN DB and all components fitted therein have to be of same make	

Annexure-III to SCC

18	7 segment DB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T Note:DB and all components fitted therein have to be of same make
19	Modular switches/sockets/Box	LEGRAND/SCHNEIDER/CRABTREE/INDOASIAN/ELVIRA/HAVELLS
20	Modular Fan Regulator 100W	LEGRAND/SCHNEIDER/CRABTREE/INDOASIAN/ELVIRA/HAVELLS
21	GI Box	LEGRAND/SCHNEIDER/CRABTREE/INDOASIAN/ELVIRA
22	AC system	Daikin/Carrier/Mitsubishi/Lloyd/Bluestar/Voltas/LG
23	Metal Enclosure for MCB/MCCB	LEGRAND/SCHNEIDER/SIEMENS/HAVELLS/ABB/L&T

Note 1: Contractor should strictly adhere to the approved make list. In case of urgency, operational exigencies, difficulty in procuring or obsolescence, other equivalent makes may be approved. Such equivalents however, may be used only with the prior approval of concerned engineer of P-CI section of Electrical Engineering Dept.

Note 2: Certain items shall be installed as one integral unit, as per specification in SOQ (like MCB, RCBO and MCB DB; or MCB and metal box, or VTPN). In such cases, the make shall be the same for all items within that integral unit.