

OIL INDIA LIMITED
(A Government of India Enterprise)
P.O. Duliajan, Pin – 786602
Dist-Dibrugarh, Assam

CORRIGENDUM NO. 1

Corrigendum No. 1 dated 05.09.2024 to **IFB No. CDI7354P25** for “**Implementation of Isolated Lightning Protection System for Floating Roof Crude Oil Storage Tanks at CTF-Moran of Oil India Limited**”.

This Corrigendum is issued to notify the following modification in Clause 5.6 of **SCOPE AND TECHNICAL SPECIFICATION**:

Clause No.	Existing Clause	Revised Clause
5.6 of <u>SCOPE AND TECHNICAL SPECIFICATION</u>	All the steel structural, including foundation bolts, nuts, bolts etc. shall be hot dipped galvanized as per IS: 4759 or fabricated from Stainless steel. Minimum galvanization thickness shall be 150 microns.	All the steel structural, including foundation bolts, nuts, bolts etc. shall be hot dipped galvanized as per IS: 4759 or fabricated from Stainless steel. Minimum galvanization thickness shall be 120 microns.

All other terms and conditions of the Bid Document remain unchanged. Details can be viewed at <https://etender.srm.oilindia.in/irj/portal> and www.oil-india.com.

Chief Manager-Contracts (S)