

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	03-06-2026 13:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	03-06-2026 13:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Petroleum And Natural Gas
विभाग का नाम/Department Name	Oil India Limited
संगठन का नाम/Organisation Name	Oil India Limited
कार्यालय का नाम/Office Name	Oil India Limited
कुल मात्रा/Total Quantity	49000
वस्तु श्रेणी /Item Category	PVC Insulated Copper Cable Single Core and Multi Core Circular Sheathed with Rigid Conductor (V2) ISI Marked To IS 694 (Q2)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension	1

बिड विवरण/Bid Details	
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Single Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	PVC Insulated Copper Cable Single Core and Multi Core Circular Sheathed with Rigid Conductor (V2) ISI Marked To IS 694
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	5 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Payment Timelines	Payments shall be made to the Seller within 21 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	ICICI
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	16

(a).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

SMM

CGM-Materials(HoD), Materials Department, Oil India Limited, Duliajan, District - Dibrugarh, Assam - 786602. The vendor shall submit to OIL the copy of the SFMS message as sent by the issuing bank branch along with the original bank guarantee. E-mail id of Buyer: "sukanya_buragohain@oilindia.in" (Sukanya Buragohain)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमआईआई के लिए सक्षम प्राधिकारी का विवरण:/Details of the Competent Authority for MII

सक्षम प्राधिकारी का नाम/Name of Competent Authority	S.Dhar
सक्षम प्राधिकारी का पदनाम/Designation of Competent Authority	US to GoI
सक्षम प्राधिकारी का कार्यालय/विभाग/प्रभाग/Office / Department / Division of Competent Authority	MoPNG (Flagship Programme Cell)
सीए अनुमोदन संख्या/CA Approval Number	FP-20013/3-2017-FP-PNG-Part (4) (E 41432)
सक्षम प्राधिकारी अनुमोदन तिथि/Competent Authority Approval Date	26-04-2022
सक्षम प्राधिकारी द्वारा प्रदान की गई स्वीकृति का संक्षिप्त विवरण/Brief Description of the Approval Granted by Competent Authority	Limit for exemption of small purchase under para 4 of the PPP-MII Order, 2017 shall be Rs. 1 crore.

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	100

ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are

validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	1.5
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST1

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 1.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications (I)	1. Size: 1Cx 1.5 sq mm 2. Voltage Grade: 1100V 3. Colour: Red 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 1.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications (II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 1.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications (III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 1.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications (IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	1.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST1

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 1.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1C x 1.5 sq mm 2. Voltage Grade: 1100V 3. Colour: Black 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 1.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 1.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 1.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid

Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	1.5
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST1

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 1.5 sq mm, Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 1.5 sq mm 2. Voltage Grade: 1100V 3. Colour: Green 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 1.5 sq mm, Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 1.5 sq mm, Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 1.5 sq mm, Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.

Specification Parameter Name	Bid Requirement (Allowed Values)
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	2.5
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 2.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 2.5 sq mm 2. Voltage Grade: 1100V 3. Colour: Red 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 2.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 2.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 2.5 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	2.5
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx2.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 2.5 sq mm 2. Voltage Grade: 1100V 3. Colour: Black 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx2.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx2.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx2.5 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	2.5
	Type of Insulation	Type A
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx2.5 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 2.5 sq mm 2. Voltage Grade: 1100V 3. Colour: GREEN 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx2.5 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx2.5 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx2.5 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	4000	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1C x 4 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1C x 4 sq mm. 2. Voltage Grade: 1100V. 3. Colour: Red. 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1C x 4 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side. 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%.
Cable, 1C x 4 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any). 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1C x 4 sq mm, Copper, Red, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 4 sq mm, Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx4 sq mm 2. Voltage Grade: 1100V 3. Colour: Yellow 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 4 sq mm, Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 4 sq mm, Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 4 sq mm, Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 4mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 4mm ² 2. Voltage Grade: 1100V 3. Colour: Blue 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 4mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 4mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 4mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx4 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 4 sq mm 2. Voltage Grade: 1100V 3. Colour: Black 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx4 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx4 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx4 sq mm, Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	4.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx4 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 4 sq mm 2. Voltage Grade: 1100V 3. Colour: GREEN 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx4 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx4 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx4 sq mm, Copper, GREEN, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 10mm ² , Copper, RED, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 10mm ² 2. Voltage Grade: 1100V 3. Colour: RED 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 10mm ² , Copper, RED, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 10mm ² , Copper, RED, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 10mm ² , Copper, RED, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx 10mm ² , Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 10mm ² 2. Voltage Grade: 1100V 3. Colour: Yellow 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx 10mm ² , Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx 10mm ² , Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx 10mm ² , Copper, Yellow, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx10mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx10mm ² 2. Voltage Grade: 1100V 3. Colour: Blue 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx10mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx10mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx10mm ² , Copper, Blue, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx10 mm ² , Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1Cx 10mm ² 2. Voltage Grade: 1100V 3. Colour: Black 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx10 mm ² , Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx10 mm ² , Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx10 mm ² , Copper, Black, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR-LSH
	Conductor Material	Annealed Bare copper
	Form of Conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation	Type C (HR)
	Number of Core	1 Core
	Sheath Type	Type ST2 (HR)

Additional Specification Parameters - PVC Insulated Copper Cable Single Core And Multi Core Circular Sheathed With Rigid Conductor (V2) ISI Marked To IS 694 (2500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cable, 1Cx10mm ² , Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(I)	1. Size: 1CX10mm ² 2. Voltage Grade: 1100V 3. Colour: Green 4. Material: Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Cable, 1Cx10mm ² , Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(II)	5. Shape: Complete round on outer side 6. Insulation: PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature. The insulation shall be of FR-LSH grade PVC compound. 7. Length per coil: Min 100mtr±10% in single length, Max 200m ± 10%
Cable, 1Cx10mm ² , Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(III)	8. Applicable standards: IS: 694- 1990, IS: 5831-1984, IS: 8130-1984 (with latest amendments if any) 9. Marking on the cable: Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Cable, 1Cx10mm ² , Copper, Green, Flame Retardant Low Smoke & Halogen as per following specifications(IV)	10. The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner. 11. Make: Any brand with valid BIS manufacturing license & type test certificates.
12. Submittals:	i. With offer- Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee. ii. With the supply: Original Routine test certificate, warranty certificate.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	2500	60

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original

delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

3. **Generic**

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

4. **Generic**

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

5. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

6. **Warranty**

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

7. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

Special Terms and Conditions:

1. Bidder should be a manufacturer or an authorised dealer. In case of authorised dealer ,valid authorisation/dealership certificate to be submitted along with the offer. In case of manufacturer, manufacturing licence/registration certificate/any other document which substantiate that the bidder is a manufacturer to be submitted along with the offer.

2. The bidder to mention the make of the offered items and to submit Technical Data Sheet and catalogue along with the offer for all the items of the tender.

3. Bidder to quote for all the items of the tender.

4. Bidder to submit type test certificate from NABL accredited lab for all the items along with the bid.

5. Please note that the Bid Evaluation Criteria and General notes to bidders and all annexures and proformas are attached as Buyer uploaded ATC Document. Bidders are requested to refer the same while submitting their offer.

6. Bidders are also requested to provide their compliance against the Technical Specifications and Special Terms and conditions of the Tender in their offer.

7. Queries Submission Timeline clause-

All prospective bidders are hereby instructed to submit any queries or requests for clarification related to this tender within the timeline defined in GeM. Any queries received after the stipulated deadline will not be entertained or responded to by OIL. Queries must be submitted in writing via email to sukanya_buragohain@oilindia.in. Please ensure that the subject line of your email clearly states 'Tender Query - [Tender No. &

Name]'.
.

8. Avoidance of Extension for Bid Submission clause-

Bidders are earnestly advised to ensure that their bid submissions are prepared and submitted in accordance with the deadlines specified in this tender document. OIL has taken all necessary steps to establish reasonable timelines for the submission of bids to allow ample time for thorough preparation. As a matter of policy, OIL will only consider granting an extension of the bid submission due date as a onetime exception in situations deemed unavoidable. Such extensions will be granted solely at the discretion of OIL and only in response to a written request from the bidder (mail to sukanya_buragohain@oilindia.in), submitted in accordance with the procedures outlined in this tender document. It is hereby emphasized that OIL will not entertain or consider any requests for an extension of the bid submission due date, except in cases where OIL deems such extension unavoidable and the bidder submits a formal written request, detailing the compelling circumstances necessitating the extension. Bidders are therefore strongly advised to refrain from seeking an extension of the bid submission due date unless absolutely necessary due to unforeseen and unavoidable circumstances. By participating in this tender process, all bidders acknowledge and accept the terms and conditions outlined in this Avoidance of Bid Submission Due Date Extensions clause.

9. Bidders are requested to submit sealed and signed Undertakings attached as Buyer uploaded ATC Document in the Tender along with their offer.

8. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1

bidders through a Random Algorithm executed by GeM system.

14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---