

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	16-07-2025 13:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	16-07-2025 13:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Petroleum And Natural Gas
विभाग का नाम/Department Name	Oil India Limited
संगठन का नाम/Organisation Name	Oil India Limited
कार्यालय का नाम/Office Name	Oil India Limited
कुल मात्रा/Total Quantity	11000
वस्तु श्रेणी /Item Category	PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694 (Q2)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694

बिड विवरण/Bid Details

तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	5 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Payment Timelines	Payments shall be made to the Seller within 21 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Item wise evaluation/
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

विभाजन/Splitting

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमआईआई के लिए सक्षम प्राधिकारी का विवरण:/Details of the Competent Authority for MII

सक्षम प्राधिकारी का नाम/Name of Competent Authority	S.Dhar
सक्षम प्राधिकारी का पदनाम/Designation of Competent Authority	US to GoI
सक्षम प्राधिकारी का कार्यालय/विभाग/प्रभाग/Office / Department / Division of Competent Authority	MoPNG (Flagship Programme Cell)
सीए अनुमोदन संख्या/CA Approval Number	FP-20013/3-2017-FP-PNG-Part (4) (E 41432) Competent Authority

सक्षम प्राधिकारी अनुमोदन तिथि/Competent Authority Approval Date	26-04-2022
सक्षम प्राधिकारी द्वारा प्रदान की गई स्वीकृति का संक्षिप्त विवरण/Brief Description of the Approval Granted by Competent Authority	Limit for exemption of small purchase under para 4 of the PPP-MII Order, 2017 shall be Rs. 1 crore

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / Evaluation Schedules	वस्तु/श्रेणी / Item/Category	मात्रा / Quantity
Schedule 1	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 2	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 3	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 4	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000

Schedule 5	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 6	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 7	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 8	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 9	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 10	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000
Schedule 11	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	1000

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	1.5
	Number of core (in Nos.)	1
	Colour of core	Red
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.

Specification Parameter Name	Bid Requirement (Allowed Values)
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	1.5
	Number of core (in Nos.)	1
	Colour of core	Black
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	1.5
	Number of core (in Nos.)	1
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Colour of Core:	GREEN

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Conductor material	Class 5 as per IS:8130 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	2.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Number of core (in Nos.)	1
	Colour of core	Red
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Conductor material	Class 5 as per IS:8130 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	2.5
	Number of core (in Nos.)	1
	Colour of core	Black
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	2.5
	Number of core (in Nos.)	1
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Colour of core:	GREEN

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
	Number of core (in Nos.)	1
	Colour of core	Red
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
	Number of core (in Nos.)	1
	Colour of core	Yellow
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.

Specification Parameter Name	Bid Requirement (Allowed Values)
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
	Number of core (in Nos.)	1
	Colour of core	Blue
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH' shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
	Number of core (in Nos.)	1
	Colour of core	Black
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Governing technical specification of the product	as per IS:694:2010 latest
	Insulation material	as per IS:5831 latest
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
	Number of core (in Nos.)	1

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Material of conductor	Plain copper
	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Voltage Grade & Material.:	1100V, Multi stranded, flexible, flame retardant, low smoke cable with Class 2 Copper Conductor. Conductors shall be drawn from minimum 99.97% bright electrolytic grade copper strands and annealed.
Insulation:	PVC, Unsheathed, improved fire performance Category C2. Cable shall have high insulation resistance and dielectric strength with high oxygen and temperature index for restricting the spread of fire and smoke even at very high temperature.
Length per coil & Applicable standards:	Min 100mtr±10% in single length, Max 200m ± 10%, IS: 694- 1990, IS: 5831-1984, IS: 8130-1984(with latest amendments if any)
Marking on the cable:	Manufacture's name, voltage grade, length (in metres), size of cable, year of manufacture and the letters 'FR-LSH'shall be printed, indented or embossed on the insulation of the cable throughout the length. The distance between any two consecutive printings, indentations or embossings shall be not more than 1 m.
Colour of core:	GREEN

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bandana Borah	786602,Oil India Limited, Duliajan, Assam	1000	90

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original

delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

3. **Warranty**

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

4. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1.0 Special Notes:

- a) Items should be procured from the manufacturer or authorised dealer only. In case of dealer, copy of valid authorisation certificate should be submitted along with the offer for evaluation.
- b) Bidder shall clearly mention the make of the offered item along with the offer.
- c) Technical Catalogue/Datasheet for the offered item shall be submitted along with the offer for evaluation.
- d) Along with the bid, bidder shall submit valid BIS certificate & type test certificate for same or larger size cable from NABL accredited test laboratory.
- e) Along with the supply, supplier shall submit Routine test certificate of the items.
- f) Packing should be adequate to avoid transit damage and water ingress.
- g) Supplied materials must have a warranty period of 1 year from the date of acceptance. Warranty certificate should be supplied along with the materials.
- h) The cable shall be supplied in packed coils. Packing shall be marked with manufacture's name, voltage grade, size of cable, year of manufacturing, length of cable, ISI mark in permanent manner.
- i) Make: Any brand with valid BIS manufacturing license & type test certificates.
- j) Submittals:

With offer- Technical catalogue, Copies of Valid authorisation/dealership certificate (in case of bidders other than OEM), valid BIS certificate, Type test certificate from NABL accredited laboratory, Approval from Fire Insurance Authority & Approval from Tariff Advisory Committee.

With the supply: Original Routine test certificate & warranty certificate.

2..0 Queries Submission Timeline clause-

All prospective bidders are hereby instructed to submit any queries or requests for clarification related to this tender within the timeline defined in GeM. Any queries received after the stipulated deadline will not be entertained or responded to by OIL. Queries must be submitted in writing via email to sukanya_buragohain@oilindia.in. Please ensure that the subject line of your email clearly states 'Tender Query - [Tender No. & Name]'.

3.0 Avoidance of Extension for Bid Submission clause-

Bidders are earnestly advised to ensure that their bid submissions are prepared and submitted in accordance with the deadlines specified in this tender document. OIL has taken all necessary steps to establish reasonable timelines for the submission of bids to allow ample time for thorough preparation. As a matter of policy, OIL will only consider granting an extension of the bid submission due date as a onetime exception in situations deemed unavoidable. Such extensions will be granted solely at the discretion of OIL and only in response to a written request from the bidder (mail to sukanya_buragohain@oilindia.in), submitted in accordance with the procedures outlined in this tender document. It is hereby emphasized that OIL will not entertain or consider any requests for an extension of the bid submission due date, except in cases where OIL deems such extension unavoidable and the bidder submits a formal written request, detailing the compelling circumstances necessitating the extension. Bidders are therefore strongly advised to refrain from seeking an extension of the bid submission due date unless absolutely necessary due to unforeseen and unavoidable circumstances. By participating in this tender process, all bidders acknowledge and accept the terms and conditions outlined in this Avoidance of Bid Submission Due Date Extensions clause.

4.0 Bidders are requested to submit signed and sealed Undertakings (Exhibit I, II, III, Annexure K, P, Q, R & O) attached as Buyer Specification Document in the Tender along with their offer.

5. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.

16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---