

Bid Document

Bid Details	
Bid End Date/Time	27-05-2021 14:00:00
Bid Opening Date/Time	27-05-2021 14:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	70 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Oil India Limited
Organisation Name	Oil India Limited
Office Name	Oil India Limited
Total Quantity	6
Item Category	Fire Breathing Apparatus (SCBA-EN 137)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Time allowed for Technical Clarifications during technical evaluation	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method	Total value wise evaluation

EMD Detail

Required	No
----------	----

ePBG Detail

Advisory Bank	HDFC Bank
ePBG Percentage(%)	3.00
Duration of ePBG required (Months).	14

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

MANAGER MATERIALS-IP
Oil India Limited, Ministry of Petroleum and Natural Gas
(Mingku Nazari)

Splitting

Bid splitting not applied.

MII Purchase Preference

MII Purchase Preference	Yes
-------------------------	-----

1. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate. In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

Fire Breathing Apparatus (SCBA-EN 137) (6 pieces)

(Minimum 50% Local content required for MII compliance)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
Material and Components	Types of Pressure Gauge	Bourdon pressure gauge with luminescent dial analog type
	Air Cylinder material (Non Corrosive)	Carbon composites with Aluminium alloy liner
	PESO approval Type for cylinder	Type 2
	Cylinder Valve	The cylinder valve should be both hand operated, perpendicular to cylinder but should not protrude beyond cylinder width, having safety device to prevent accidentally closure of valve., Excess flow cylinder valve should be both hand operated, perpendicular to cylinder but should not protrude beyond cylinder width, having safety device to prevent accidentally closure of valve.
	Indication in case of Digital Pressure Gauge, Digital cum Mechanical Pressure Gauge	NA for Bourdon pressure gauge with luminescent dial analog type)
	Back Plate design	Universal (Fixed Back plate)
PERFORMANCE	Water Capacity of Breathing Apparatus Cylinder	6.8
	Charging Pressure	251 to 300 Bars
CERTIFICATION	Warranty / Guaranty	3.0, 1.0

Additional Specification Parameters - Fire Breathing Apparatus (SCBA-EN 137) (6 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Cylinder and Valve assembly:	A filled additional (spare) cylinder of same characteristics and capacity shall be supplied along with each SCBA set and bidder to offer their price accordingly.
DOCUMENTS TO BE SUBMITTED ALONGWITH THE OFFER	i. EN137:2006 Type II approval certificate of SCBA set ii. EN 136 Class 3 approval certificate iii. Copy of PESO, Nagpur approval for Cylinder and cylinder valve iv. Manufacturers catalog and complete technical details of SCBA set v. Authorization certificate from the manufacturer to the bidder, if the bidder is a dealer. vi. List of technical deviations to the tender specifications.
DOCUMENTS TO BE SUBMITTED AT THE TIME OF SUPPLY OF MATERIAL	a) Original Hydro test Certificate of cylinder & valve b) "Permission for filling" by PESO. c) Test certificates as per EN 137 d) Quality Certificate of Breathable air filled in the cylinder as per Annexure A of IS : 9623 (latest revision) f) O&M manual / CD for SCBA set in English - 3 sets. g) Complete technical details of SCBA set h) Calibration certificate of pressure gauge i) Test certificate of First Stage Reducer
MARKING	The apparatus shall be marked as per EN137:2006 Type II (latest revision) and face mask as per EN 136 Class 3 (latest revision). The full face mask shall be marked with "cl 3+". The pressure reducer shall be durably marked with a serial number. The number and year of EN-12245, weight of empty & filled cylinder shall be marked on cylinder. Marking as per EN: 144-2 on valve.
Training regarding operation & maintenance of BA Set:	After supply of the units, the Supplier shall provide One Day's training on operation & maintenance of BA Set at Fire Service, Oil India Limited, Duliajan and charges for the same shall be borne by the supplier.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	DIPANKAR PATHAK	786602,Oil India Limited, Duliajan, Assam	6	90

Buyer Added Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 2.The buyer organization is an institution eligible for concessional rates of GST as notified by the Government of India. The goods for which bids have been invited fall under classification of GST concession and the conditions for eligibility of concession are met by the institution. A certificate to this effect will be issued by Buyer to the Seller after award of the Contract. Sellers are requested to submit their bids after accounting for the Concessional rate of GST.
Applicable Concessional rate of GST : 5%
Notification No.and date : 3/2017 dated 28/06/2017
- 3.Whereever Essentiality Certificate is applicable (PEL/ML), successful bidder should provide Proforma Invoice for processeing for EC application and material should be dispatche after receiving of EC rom DGH. In view of the same, an ATC may be incorporated in GeM, viz, "BIDDER/OEM must provide Proforma Invoice for processeing for EC application within 15 days from date of issue of GeM Contract and material should be dispatche after receiving of EC rom DGH."

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against

these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---