



OIL INDIA LIMITED

(A Government of India Enterprise)
P.O. Duliajan - 786602, Assam, India
FAX: 0374-2800533; Ph: 0374-2808719;

E-mail: ranjan_barman@oilindia.in; erp_mm@oilindia.in

CORRIGENDUM

Ref: HM/IP/RB/DID1538L20/03

Dated: 04.07.2019

Sub: Amendment No. 3 dated 04.07.2019 to Annexure-IA of Tender No. DID1538L20/L3

Dear Sirs,

This **Amendment No. 3** to the **Annexure-IA** of the subject Tender has been issued to **amend** the following specifications of **item no. 10** as under in place of existing:

Sl. No.	Existing clause (with clause no./page number)	Amended Clause
1	Annexure-IA /Page- 11 of 14, F. Spares: Point c. All other outgoing feeder/starter panel MCCBs-06(six) nos. of each rating (400/250/100A)	Annexure-IA /Page- 11 of 14, F. Spares: Point c. All other outgoing feeder/starter panel MCCBs- 02(two) nos. of each rating (400/250/100A)
2	Annexure-IA /Page- 11 of 14, F. Spares: Point d. Soft starter-02(two) no of each rating/capacity.	Annexure-IA /Page- 11 of 14, F. Spares: Point d. Soft starter- 01(one) no of each rating/capacity.
3	Annexure-IA /Page- 11 of 14, F. Spares: Point f. Contactors-8(eight) nos. of each rating/size(for 100HP soft starters, 40/20HP SDS & 15/5 HP DOL Starters)	Annexure-IA /Page- 11 of 14, F. Spares: Point f. Contactors- 4(four) nos. of each rating/size(for 100HP soft starters, 40/20HP SDS & 15/5 HP DOL Starters)
4	Annexure-IA /Page- 11 of 14, F. Spares: Pointg. Overload relays-12(twelve) nos. of each rating/size (-do-)	Annexure-IA /Page- 11 of 14, F. Spares: Pointg. Overload relays- 6(six) nos. of each rating/size (-do-)
5	Annexure-IA /Page- 11 of 14, F. Spares:	Annexure-IA /Page- 11 of 14, F. Spares:

	Pointh. CBCT-06(six) nos. of each rating/size/type	Pointh. CBCT- 03(three) nos. of each rating/size/type
6	Annexure-IA /Page- 11 of 14, F. Spares: Pointi. ELR(in conjunction with CBCT)-12(twelve) nos. of each rating/size/type	Annexure-IA /Page- 11 of 14, F. Spares: Pointi. ELR(in conjunction with CBCT)- 06(six) nos. of each rating/size/type

Bidders are requested to note all amendments & original NIT while quoting.

All other terms and conditions of the Tender remain unchanged.

Yours faithfully,
OIL INDIA LIMITED,



(RANJAN BARMAN)
DGM (IP)
For GM-Materials (HOD)

Comparison showing discrepancy in quantity of Spares in Annexure-I and Annexure-IA

Tender No. DID1538L20/L3 :: List of minimum indicative spares (total nos., to be supplied with the panels as per OIL approved Bill of Materials)

ANNEXURE-I :: Page : 4 / 7 (Special Notes)		ANNEXURE – IA :: Point : F. Spares :: Page 11/14
a.	Main panel Incomer ACB (1000 A)- 01 nos. (01 nos. of operating handles will be provided with ACB)	Main panel Incomer ACB (1000 A)- 02 nos. (02 nos. of operating handles will be provided with each ACB)
b.	Main panel Incomer MCCB (630 A)# 2 (two) nos.	Main panel Incomer MCCB (630 A)– 02 (two) nos.
c.	All other outgoing feeder/starter panel MCCBs- 02 (two) nos. of each rating (400/250/100 A)	All other outgoing feeder/starter panel MCCBs- 06 (six) nos. of each rating (400/250/100 A)
d.	Soft starters- 01 (one) no.	Soft starters- 02 (two) no. of each rating/capacity
e.	Contactors- 4 (Four) nos. of each rating/size (for 40/20 HP SDS & 10/5 HP DOL starters)	Contactors- 8 (eight) nos. of each rating/size (for 100 HP soft starters, 40/20 HP SDS & 15/5 HP DOL starters)
f.	Overload relays-6 (Six) nos. of each rating/size (- do -)	Overload relays- 12 (twelve) nos. of each rating/size (- do -)
g.	CBCT- 03 (three) nos. of each rating/size/type	CBCT- 06 (six) nos. of each rating/size/type
h.	ELR (in conjunction with CBCT) -6 (Six) nos. of each rating/size/type	ELR (in conjunction with CBCT) - 12 (twelve) nos. of each rating/size/type
i.	Ammeters and CTs- 03 (three) nos. of each rating and size	Ammeters and CTs- 03 (three) nos. of each rating and size
j.	Remote local selector switch and local start/stop switch- 03 (three) nos. of each rating/size/type	Remote local selector switch and local start/stop switch- 03 (three) nos. of each rating/size/type
k.	ON/OFF/OVERLOAD/Other types LED indication lamps with low voltage glow protection- 12 (twelve) nos. each colour/type	ON/OFF/OVERLOAD/Other types LED indication lamps with low voltage glow protection- 12 (twelve) nos. each colour/type
l.	One set of operating tools required to operate/maintain all the items installed in the panel like box wrench set, screw driver set etc. Standard electrician's tool kits from reputed firms like RS-Components, Stanley, Mekster etc. are to be supplied.	One set of operating tools required to operate/maintain all the items installed in the panel like box wrench set, screw driver set etc. Standard electrician's tool kits from reputed firms like RS-Components, Stanley etc. are to be supplied.
	If felt necessary, bidder may include further items in the above spares list.	If felt necessary, bidder may include further items in the above spares list and quote the prices for these accordingly.