

OIL INDIA LIMITED  
(A Govt. of India Enterprise)  
Udyan Vihar, Narengi, Guwahati,  
Assam

Fax-91 0361 2643686  
Email-oilmatpl@oilindia.in

**ANNEXURE-I**

**Tender No. : GOD3653L15/3H**  
**Tender Date : 24.05.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
<b>10</b> 0C000351	<p><b>DIGITAL EARTH TESTER</b></p> <p>Digital Earth Tester with following features: The digital tester is required for the measurement of earth resistance under following various conditions; a) measurement of earth resistance in difficult conditions, where noise present in the earth, b) Measurement of earth resistance for large complex earthing systems c) Attached rod technique d) 2,3 &amp; 4 point testing etc. The other constructional details and technical specifications are as per ANNEXURE-1 attached along with the Tender..</p> <p>MAKE: MEGGER/FLUKE PROGRAMMA/ DOUBLE or equivalent to Megger make Model No. DET4TCR2.</p>	1	NO
<b>20</b> 0C000351	SAME AS ITEM 10	1	NO
<b>30</b> 0C000351	SAME AS ITEM 10	1	NO
<b>40</b> 0C000351	SAME AS ITEM 10	1	NO
<b>50</b> 0C000384	<p><b>DIGITAL MULTIMETER</b></p> <p>Display- 4.5 digit DCV- Max. Voltage 1000V Accuracy +/- (0.025%+5) Max. Resolution 0.001 mV ACV- Max. Voltage 1000V Accuracy +/- (0.4%+40) Max. Resolution 0.001 mV DC Current- Max.Amps 10A Accuracy +/- (0.15%+2) Max. Resolution 0.01 micro A AC Current- Max.Amps 10A Accuracy +/- (0.75%+5) Max. Resolution 0.01 micro A</p> <p>Min/Max to record : 250 micro S peak Min/Max recording for the min, max &amp; average capturing transients. reading over time</p> <p>Resistance--- 500 M Ohm Accuracy +/- (0.05%+2) Max. Resolution 0.01 Ohm</p> <p>Accessories Leads Manual Battery</p>	1	NO

**ANNEXURE-I****Tender No. : GOD3653L15/3H****Tender Date : 24.05.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	Calibration Certificate  Make- Megger/Fluke/AVO Model- Equivalent to. Fluke Model 287		
<b>60</b> 0C000384	SAME AS ITEM 50	1	NO
<b>70</b> 0C000384	SAME AS ITEM 50	1	NO
<b>80</b> 0C000384	SAME AS ITEM 50	1	NO
<b>90</b> 0C000384	<p><b>DIGITAL CLAMP METER</b> 3 1/2 digit LCD display digital clamp on meter suitable for current measurement upto 2000A with additional provisions for AC/DC voltage measurement, resistance measurement, diode test &amp; continuity check. The meter should have following features:</p> <ol style="list-style-type: none"> <li>1) Measuring method : Dual integration mode</li> <li>2) Display : 3 1/2 digit LCD display upto 1999 counts</li> <li>3) Jaw opening capability : 50 mm dia.</li> <li>4) Auto power off : The meter should set to auto power off mode approx 10 minutes after power switch on.</li> <li>5) Sampling : 2 times/sec.</li> <li>6) Range : Auto/ Manual</li> <li>7) AC Amp Range (Manual) : 20A/ 200A/ 2000A</li> <li>8) Accuracy : +/- 1.2 %</li> <li>9) AC/DC Voltage Range (Auto range): 2V/20V/200V/600V</li> <li>10) Accuracy : +/- 1.2 %</li> <li>11) Resistance range (Auto): 200 ohm/2 Kohm/20 kohm/200 kohm/20 Mohm</li> <li>12) Accuracy : +/- 1.2 %</li> <li>13) Continuity check : Continuity beeper</li> <li>14) Diode test</li> </ol> <p>Accessories:  <ol style="list-style-type: none"> <li>1) Carrying case : 1 No.</li> <li>2) Test lead : 1 set</li> <li>3) Battery : 2 Nos.</li> <li>4) Instruction manual: ! No.</li> </ol> </p> <p>Model:Equivalent to Motowane make Type: DCM40A  Make: AVO/ FLUKE/MOTWANE OR EQUIVALENT</p>	1	NO
<b>100</b> 0C000384	<p><b>DIGITAL CLAMP METER</b> 3 1/2 digit LCD display digital clamp on meter suitable for current measurement upto 2000A with additional provisions for AC/DC voltage measurement, resistance measurement, diode test &amp; continuity check. The meter should have following features:</p> <ol style="list-style-type: none"> <li>1) Measuring method : Dual integration mode</li> <li>2) Display : 3 1/2 digit LCD display upto 1999 counts</li> <li>3) Jaw opening capability : 50 mm dia.</li> <li>4) Auto power off : The meter should set to auto power off mode approx 10 minutes after power switch on.</li> <li>5) Sampling : 2 times/sec.</li> </ol>	1	NO

**ANNEXURE-I****Tender No. : GOD3653L15/3H****Tender Date : 24.05.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	6) Range : Auto/ Manual 7) AC Amp Range (Manual) : 20A/ 200A/ 2000A 8) Accuracy : +/- 1.2 % 9) AC/DC Voltage Range (Auto range): 2V/20V/200V/600V 10) Accuracy : +/- 1.2 % 11) Resistance range (Auto): 200 ohm/2 Kohm/20 kohm/200 kohm/20 Mohm 12) Accuracy : +/- 1.2 % 13) Continuity check : Continuity beeper 14 Diode test Accessories: 1) Carrying case : 1 No. 2) Test lead : 1 set 3) Battery : 2 Nos. 4) Instruction manual: ! No.  Model:Equivalent to Motowane make Type: DCM40A  Make: AVO/ FLUKE/MOTWANE OR EQUIVALENT		

**Standard Notes:** 1. Material should be guaranteed for a minimum period of one year from the date of acceptance.

2. Packing should be adequate to avoid any transit damage.

3. Release of payment only after certified by user deptt. to be in perfect working condition.

**Special Notes :** 1. Bidder shall submit catalogue / brochure / leaflet providing technical details of the materials offered along with their quotation.

2. Bidders other than OEM must submit valid authorized dealership/authorization certificate from OEM along with their offer.

3. To evaluate the inter-se ranking of the offers, Assam Entry Tax on purchase value will be loaded as per prevailing government of Assam Guidelines as applicable on bid closing date. Bidders may check this With the appropriate authority, while submitting their bids.

4. Bidder should quote transportation charges on actual separately if not included in basic price. Transportation charges have to be quoted for transportation by mode as below:-

i) For consignments weighing around 50 Kgs, Actual transportation charge to be quoted for transportation by courier service (Air/Road).

ii) For consignment weighing more than the weight mentioned in Sl.No.(i), actual transportation cost shall be quoted for transportation by Road transport.

5. Any sum of money due and payable to the contractor (including Security Deposit refundable to them) under this or any other contract may be appropriated by Oil India Limited and set off against any claim of Oil India Limited (or such other person or person

**ANNEXURE-I**

**Tender No. : GOD3653L15/3H**

**Tender Date : 24.05.2014**

contracting through Oil India Limited) for payment of a sum of money arising out of this contract or under any other contract made by the contractor with Oil India Limited (or such other person or persons contracting through Oil India Limited).

6. Any statutory variation (increase / decrease )in the rate of excise duty / sales tax/Customs Duty or any statutory levy after the closing date of tenders / revised priced bid, as the case may be, but within the contractual delivery /completion period will be to the account of OIL subject to documentary evidence. However, any increase in excise duty /sales tax / Customs Duty or any statutory levy after the expiry of the scheduled date of delivery shall be to the supplier's account.

7. Please confirm acceptance of NIT payment terms.

8. Terms and conditions applicable to this tender is enclosed vide Annexure II to VI

Tender No. : GOD3653L15/3H  
Tender Date : 24.05.2014  
Bid Closing On : 03.07.2014 at 13:00 hrs.(IST)  
Bid Opening On : 03.07.2014 at 13:00 hrs.(IST)

**Tender issued to following parties only:**

Slno	V_Code	Vendor Name	City/Country
1	200129	RAJESH HARDWARE STORES	TINSUKIA
2	200211	STEEL & INDUSTRIAL STORES	TINSUKIA
3	200832	INDUSTRIAL EQUIPMENTS	GUWAHATI
4	201151	TOSHNIWAL ENTERPRISES	KOLKATA
5	201681	LARSEN & TOUBRO LIMITED.	GUWAHATI
6	202157	ENERGY COMPONENTS	GUWAHATI
7	202289	U.K. ENTERPRISE	GUWAHATI
8	203577	ARADHANA AGENCY	GUWAHATI
9	203799	CROMPTON GREAVES LTD	GUWAHATI
10	206055	ELECTROMECH ENGINEERING ENTERPRIS	GUWAHATI
11	206940	OZONE ENGINEERS	KOLKATA
12	208240	MEGGER INDIA	MUMBAI
13	209799	ATP THERMOTECH (P) LTD.	NEW DELHI