

**OIL INDIA LIMITED**

(A Govt. Of India Enterprise) Tel :033 2230 1657, 1658  
 4, India Exchange Place, Fax :91 33 2230 2596  
 Kolkata-700001 E-mail :oilcalmn@oilindia.in

**ANNEXURE-I**

**Tender No. : KID3884L15/04**  
**Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
<b>10</b> 99076812	<p><b><u>Fire Extinguishers for various installations at Duliajan, Moran &amp; Manabhum as well as New Projects</u></b></p> <p>Specification / Data Sheet for 25 Kg. Capacity Trolley Mounted DCP (Potassium Base) Fire Extinguisher</p> <p>Sr. No. Item Requirement</p> <p>1. General</p> <p>1.1. Standard Code Conforming to IS 10658:2004 (latest revisions as on bid due date).</p> <p>1.2. Necessary copy of IS certificate shall be submit along with the offer.</p> <p>1.3. Marking IS : 10658</p> <p>1.4. Type: Trolley Mounted</p> <p>1.5. Capacity : 25 Kg Capacity</p> <p>2. Construction - Body :</p> <p>2.1. Materials for Construction (MOC) of body : Mild steel sheets as per IS-2062.</p> <p>2.2. The construction of the body : Welded conforming to the requirements given in IS-9595.</p> <p>2.3. The shape of the body : Cylindrical.</p> <p>2.4. Dome &amp; dish : Convex without reverse curvature.</p> <p>2.5. Diameter : Not more than 75 cm</p> <p>2.6. Minimum thickness of the exinguisher body : 4 mm</p> <p>2.7. Provision shall be made for an internal pressure test on the body.For this purpose, the union to which the discharge hose is connected shall be screwed with threads.</p> <p>2.8. A cylindrical skirt having minimum 25 mm height shall be welded to the bottom dish.</p> <p>3. Neck Ring:</p> <p>3.1. Materials for Construction (MOC) of neck ring: Seamless mild steel tube as per IS-1239 (Part 1)</p> <p>3.2. Clear opening : Not less than 75 mm</p> <p>3.3. Parallel screw threads for effective length: Not less than 22 mm.</p> <p>4. Nozzle:</p> <p>4.1. Materials for Construction (MOC) of Nozzle : Aluminium alloy:Grade-4450 of IS-617</p> <p>5. Cap:</p> <p>5.1. Materials for Construction (MOC) of Cap: Leaded tin bronze, Grade LTB2 of IS-318 / Brass IS-319</p> <p>5.2. At least 3 holes of not less than 3 mm diameter each shall be drilled through the threads of the cap to form vents for release of any pressure remaining in the body during withdrawal of the cap.</p> <p>5.3. The extinguisher shall be fitted with safety valve which shall release at a pressure of not more than 17 kgf/cm<sup>2</sup></p> <p>5.4. Cap Joint Washer: The cap joint rubber washer provided in the recess in the cap.</p>	120	NO

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>6. Syphon tube: Materials for Construction (MOC) of Syphon tube - Mild steel tube as per IS-1239.</p> <p>7. Expansion Space: A space shall be provided above dry powder level in the body of the extinguisher. It shall be of sufficient volume to ensure that when discharge nozzle is temporarily closed and the extinguisher is operated at a temperature of <math>27 \pm 5^{\circ}\text{C}</math>, the internal pressure shall not exceed 15 kgf/cm<sup>2</sup> and the body shall not show any sign of leakage.</p> <p>8. Discharge Hose:  8.1. Material for Construction (MOC) of Discharge Hose : SAE 100R3 Markwel brand / SAE 100R3 with min. 300 mm spring Markwel brand.  8.2. Nominal bore : 19 mm diameter  8.3. Length of the discharge Hose : Not less than 3 meter.  8.4. Bursting pressure of Discharge hose: Not less than 50 kgf/cm<sup>2</sup>.</p> <p>9. Carbon Di Oxide (CO<sub>2</sub>)Cylinder:  9.1. CO<sub>2</sub> gas cylinder: Conform to IS 7285 &amp; PESO (CCOE) approved  9.2. Capacity : 1 Kg CO<sub>2</sub>  9.3. CO<sub>2</sub> cylinder valve : Conforming to IS-3224  9.4. CO<sub>2</sub> cylinder shall have wheel valve with safety pin &amp; seal.</p> <p>10. High Pressure Copper Tubing with standing 275 kg/cm<sup>2</sup> pressure &amp; it should not break while bending with minimum thickness 1.6mm.</p> <p>11. Wheeled Carriage (Trolley):  11.1. Axel of M.S. tube/ rod, fitted in standard lubricated bearing shall be fitted along with the Wheel with Solid Rubber tyre having min dia. 200 x 50 mm. Trolley shall be robust in construction.  11.2. Lowest part of the body remains not less than 10 cm.</p> <p>12. Anti-Corrosive Treatment:  12.1. Phosphating by hot dipping process to thickness not less than 0.012 mm both internally &amp; externally.  12.2. Epoxy polyester powder coating of minimum 50 micron thickness to all metallic external parts.</p> <p>13. Painting:  13.1. Extinguisher shall be painted with fire red colour conforming to shade No. 536 of IS 5.</p> <p>14. Marking :  14.1. Each extinguisher shall be clearly and permanently marked with the following information :  14.1.1. Manufacturer's name or trade-mark, serial number and year of manufacture shall be embossed at the bottom ring.  14.1.2. Words 'Dry Powder Extinguisher';  14.1.3. Capacity of the extinguisher in kg;  14.1.4. Letters indicating the various classes of fires for which the extinguisher is suitable;  14.1.5. Coloured Oil India Limited Logo along with the name of the company shall be painted on the extinguisher body.</p>		

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>14.1.6 All other markings on the extinguisher body shall be as per IS :10658.</p> <p>15. Extinguishing Media ( Dry Chemical Powder ):</p> <p>15.1. Dry Chemical Powder Potassium- bi-carbonate (min 90% of total composition of the chemicals) based ISI marked Dry Chemical Powder confirming to IS: 4308 2008(or latest revision).</p> <p>15.2. The Dry Chemical Powder shall be supplied in separate intact packets bearing ISI-mark (IS: 4308 of 2008) along with the supply of extinguishers.</p> <p>15.3. The test certificate of 90% base material (i.e. Potassium Bi-Carbonate) to be shown at the time of inspection &amp; to be submitted along with supply.</p> <p>15.4. DCP shall be compatible with all types of foams.</p> <p>15.5. All containers of Dry Chemical Powder refills shall clearly and permanently mark with the following information.</p> <p>15.5.1. Name of the manufacturer or his trade mark;</p> <p>15.5.2. Quantity of the powder in Kg;</p> <p>15.5.3. Date of manufacture/Batch No;</p> <p>15.5.4. Shelf life (5 years) of the Powder;</p> <p>15.5.5. ISI Certification mark</p> <p>16. Additional accessories/ Spares (Similar specification):</p> <p>16.1. Wheel Set : 01 Pair of wheel (with each extinguisher)</p> <p>16.2. CO2 Cylinder : 01 No (with each extinguisher)</p> <p>16.3. Discharge Hose with Nozzle : 01 No. (with each extinguisher)</p> <p>16.4. High Pressure Copper Tubing : 01 No. (with each extinguisher)</p> <p>16.5. Cap Joint Washer : 05 Nos. (with each extinguisher)</p> <p>16.6. Safety Pin : 01 Nos. (with each extinguisher)</p> <p>16.7. Cap : 5% of the total ordered quantity (If the calculated quantity is in decimals then next round figure will be considered for total number of quantity).</p> <p>17. Weather Proof Fire Extinguisher Cover shall be provided along with each extinguisher.</p> <p>18. Drawing &amp; Quality Assurance Plan (QAP): Vendor shall submit detailed drawing &amp; QAP along with material of construction &amp; obtain approval from OIL before start of fabrication.</p> <p>19. Test Requirements :The following test report to be submitted along with the supply of extinguisher :</p> <p>19.1.1. Dye Penetration Test 100% of weld joints.</p> <p>19.1.2. Radiography Report (to be reviewed at the time of inspection #if applicable).</p> <p>19.1.3. Performance Test one number per order lot.</p> <p>19.1.4. Hydraulic Test of 10% of Ordered Quantity as per IS- 10658.</p> <p>19.1.5 Performance test &amp; hydraulic test to be carried out at the time of inspection as per IS: 10658.</p>		
<p><b>20</b> 99076813</p>	<p>Specification / Data Sheet for 50 Kg. Capacity Trolley Mounted DCP (Potassium Base) Fire Extinguisher</p> <p>Sr. No. Item Requirement</p> <p>1. General:</p>	10	NO

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>1.1. Standard Code Conforming to IS 10658:2004 (latest revisions as on bid due date)</p> <p>1.2. Necessary copy of IS certificate shall be submit along with the offer.</p> <p>1.3. Marking IS : 10658</p> <p>1.4. Type: Trolley Mounted Type</p> <p>1.5. Capacity : 50 Kg Capacity</p> <p>2. Construction Body:</p> <p>2.1. Materials for Construction (MOC) of body : Mild steel sheets as per IS-2062.</p> <p>2.2. The construction of the body : Welded conforming to the requirements given in IS-9595.</p> <p>2.3. The shape of the body : Cylindrical</p> <p>2.4. Dome &amp; dish : Convex without reverse curvature.</p> <p>2.5. Diameter : Not more than 75 cm</p> <p>2.6. Minimum thickness of the body: 6 mm</p> <p>2.7. Provision shall be made for an internal pressure test on the body. For this purpose, the union to which the discharge hose is connected shall be screwed with threads.</p> <p>2.8. A cylindrical skirt having minimum 25 mm height shall be welded to the bottom dish.</p> <p>3. Neck Ring:</p> <p>3.1. Materials for Construction (MOC) of neck ring: Seamless mild steel tube as per IS-1239 (Part 1)</p> <p>3.2. Clear opening : Not less than 75 mm</p> <p>3.3. Parallel screw threads for effective length: Not less than 22 mm.</p> <p>4. Nozzle:</p> <p>4.1. Materials for Construction (MOC) of Nozzle : Aluminium alloy: Grade-4450 of IS-617</p> <p>5. Cap:</p> <p>5.1. Materials for Construction (MOC) of Cap: Leaded tin bronze, Grade LTB2 of IS-318 / Brass IS-319</p> <p>5.2. At least 3 holes of not less than 3 mm diameter each shall be drilled through the threads of the cap to form vents for release of any pressure remaining in the body during withdrawal of the cap.</p> <p>5.3. The extinguisher shall be fitted with safety valve which shall release at a pressure of not more than 17 kgf/cm<sup>2</sup></p> <p>5.4. Cap Joint Washer: The cap joint rubber washer provided in the recess in the cap.</p> <p>6. Syphon tube: Materials for Construction (MOC) of Syphon tube - Mild steel tube as per IS-1239.</p> <p>7. Expansion Space: A space shall be provided above dry powder level in the body of the extinguisher. It shall be of sufficient volume to ensure that when discharge nozzle is temporarily closed and the extinguisher is operated at a temperature of 27 ± 5°C, the internal pressure shall not exceed 15 kgf/cm<sup>2</sup> and the body shall not show any sign of leakage.</p> <p>8. Discharge Hose:</p>		

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>8.1. Material for Construction (MOC) of Discharge Hose : SAE 100R3 Markwel brand / SAE 100R3 with min. 300 mm spring Markwel brand.</p> <p>8.2. Nominal bore: 19 mm diameter</p> <p>8.3. Length of the discharge Hose: not less than 5 meter.</p> <p>8.4. Bursting pressure of Discharge hose: Not less than 50 kgf/cm<sup>2</sup>.</p> <p>9. Carbon Di Oxide (CO<sub>2</sub>)Cylinder:</p> <p>9.1. CO<sub>2</sub> gas cylinder: Conform to IS 7285 &amp; PESO (CCOE) approved</p> <p>9.2. Capacity: 2 Kg CO<sub>2</sub></p> <p>9.3. CO<sub>2</sub> cylinder valve : Conforming to IS 3224</p> <p>9.4. CO<sub>2</sub> cylinder shall have wheel valve with safety pin &amp; seal.</p> <p>10. High Pressure Copper Tubing with standing 275 kg/cm<sup>2</sup> pressure &amp; it should not break while bending with minimum thickness 1.6mm.</p> <p>11. Drain Plug:</p> <p>11.1. Materials for Construction (MOC) of Drain Plug- Leaded tin bronze, Grade LTB2 of IS-318 / Brass: Type I of IS-319.</p> <p>11.2. Diameter of Drain Plug: Not less than 25 mm.</p> <p>12. Wheeled Carriage (Trolley):</p> <p>12.1. Axel of M.S. tube/ rod, fitted in in standard lubricated bearing shall be fitted along with the Wheel with Solid Rubber tyre having Dia. 200 x 50 mm. Trolley shall be robust in construction.</p> <p>12.2. Lowest part of the body remains not less than 20 cm.</p> <p>13. Anti-Corrosive Treatment:</p> <p>13.1. Phosphating by hot dipping process to thickness not less than 0.012 mm both Internally &amp; externally.</p> <p>13.2. Epoxy polyester powder coating of minimum 50 micron thickness to all metallic external parts.</p> <p>14. Painting:</p> <p>14.1. Extinguisher shall be painted with fire red colour conforming to shade No. 536 of IS 5.</p> <p>15. Marking :</p> <p>15.1. Each extinguisher shall be clearly and permanently marked with the following information :</p> <p>15.1.1. Manufacturer's name or trade-mark, serial number and year of manufacture shall be embossed at the bottom ring.</p> <p>15.1.2. Words 'Dry Powder Extinguisher';</p> <p>15.1.3. Capacity of the extinguisher in kg;</p> <p>15.1.4. Letters indicating the various classes of fires for which the extinguisher is suitable;</p> <p>15.1.5. Coloured Oil India Limited Logo along with the name of the company shall be painted on the extinguisher body.</p> <p>15.1.6 All other markings on the extinguisher body shall be as per IS :10658.</p> <p>16. Extinguishing Media ( Dry Chemical Powder ):</p> <p>16.1. Dry Chemical Powder Potassium- bi-carbonate (min 90% of total composition of the chemicals) based ISI marked Dry Chemical Powder confirming to IS: 4308 2008(or latest revision).</p>		

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>16.2. The Dry Chemical Powder shall be supplied in separate intact packets bearing ISI-mark (IS: 4308 of 2008) along with the supply of extinguishers.</p> <p>16.3. The test certificate of 90% base material (i.e. Potassium Bi-Carbonate) to be shown at the time of inspection &amp; to be submitted along with supply.</p> <p>16.4. DCP shall be compatible with all types of foams.</p> <p>16.5. All containers of Dry Chemical Powder refills shall clearly and permanently mark with the following information.</p> <p>16.5.1. Name of the manufacturer or his trade mark;</p> <p>16.5.2. Quantity of the powder in Kg;</p> <p>16.5.3. Date of manufacture/Batch No;</p> <p>16.5.4. Shelf life (5 years) of the Powder;</p> <p>16.5.5. ISI Certification mark</p> <p>17. Additional accessories/ Spares (Similar specification):</p> <p>17.1. Wheel Set : 01 Pair of wheel (with each extinguisher)</p> <p>17.2. CO2 Cylinder : 01 No (with each extinguisher)</p> <p>17.3. Discharge Hose with Nozzle : 01 No.(with each extinguisher)</p> <p>17.4. High Pressure Copper Tubing : 01 No.(with each extinguisher)</p> <p>17.5. Cap Joint Washer : 05 Nos.(with each extinguisher)</p> <p>17.6. Safety Pin : 01 Nos. (with each extinguisher)</p> <p>17.7. Cap : 5% of the total ordered quantity (If the calculated quantity is in decimals then next round figure will be considered for total number of quantity).</p> <p>18. Weather Proof Fire Extinguisher Cover shall be provided along with each extinguisher.</p> <p>19. Drawing &amp; Quality Assurance Plan (QAP): Vendor shall submit detailed drawing &amp; QAP along with material of construction &amp; obtain approval from OIL before start of fabrication.</p> <p>20. Test Requirements :The following test report to be submitted along with the supply of extinguisher :</p> <p>20.1.1. Dye Penetration Test 100% of weld joints.</p> <p>20.1.2. Radiography Report (to be reviewed at the time of inspection # if applicable).</p> <p>20.1.3. Performance Test one number per order lot.</p> <p>20.1.4. Hydraulic Test of 10% of Ordered Quantity as per IS- 10658.</p> <p>20.1.5 Performance test &amp; hydraulic test to be carried out at the time of inspection as per IS: 10658.</p>		
<p><b>30</b> 99064194</p>	<p>Specification / Data Sheet for 75 Kg. Capacity Trolley Mounted DCP (Potassium Base) Fire Extinguisher</p> <p>Sr. No. Item Requirement</p> <p>1. General:</p> <p>1.1. Standard Code Conforming to IS 10658:2004 (latest revisions as on bid due date)</p> <p>1.2. Necessary copy of IS certificate shall be submit along with the offer.</p> <p>1.3. Marking IS : 10658</p> <p>1.4. Type: Trolley Mounted Type</p> <p>1.5. Capacity : 75 Kg Capacity</p>	5	NO

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>2. Construction Body:</p> <p>2.1. Materials for Construction (MOC) of body : Mild steel sheets as per IS 2062.</p> <p>2.2. The construction of the body : Welded conforming to the requirements given in IS 9595.</p> <p>2.3. The shape of the body : Cylindrical</p> <p>2.4. Dome &amp; dish : Convex without reverse curvature.</p> <p>2.5. Diameter : Not more than 75 cm</p> <p>2.6. Minimum thickness of the body: 6 mm</p> <p>2.7. Provision shall be made for an internal pressure test on the body. For this purpose, the union to which the discharge hose is connected shall be screwed with threads.</p> <p>2.8. A cylindrical skirt having minimum 25 mm height shall be welded to the bottom dish.</p> <p>3. Neck Ring:</p> <p>3.1. Materials for Construction (MOC) of neck ring: Seamless mild steel tube as per IS 1239 (Part 1)</p> <p>3.2. Clear opening : Not less than 75 mm</p> <p>3.3. Parallel screw threads for effective length: Not less than 22 mm.</p> <p>4. Nozzle: Materials for Construction (MOC) of Nozzle : Aluminium alloy: Grade 4450 of IS 617</p> <p>5. Cap:</p> <p>5.1. Materials for Construction (MOC) of Cap: Leaded tin bronze, Grade LTB2 of IS-318 / Brass IS-319</p> <p>5.2. At least 3 holes of not less than 3 mm diameter each shall be drilled through the threads of the cap to form vents for release of any pressure remaining in the body during withdrawal of the cap.</p> <p>5.3. The extinguisher shall be fitted with safety valve which shall release at a pressure of not more than 17 kgf/cm<sup>2</sup></p> <p>5.4. Cap Joint Washer: The cap joint rubber washer provided in the recess in the cap.</p> <p>6. Syphon tube: Materials for Construction (MOC) of Syphon tube - Mild steel tube as per IS-1239.</p> <p>7. Expansion Space: A space shall be provided above dry powder level in the body of the extinguisher. It shall be of sufficient volume to ensure that when discharge nozzle is temporarily closed and the extinguisher is operated at a temperature of 27 ± 5°C, the internal pressure shall not exceed 15 kgf/cm<sup>2</sup> and the body shall not show any sign of leakage.</p> <p>8. Discharge Hose:</p> <p>8.1. Material for Construction (MOC) of Discharge Hose : SAE 100R3 Markwel brand / SAE 100R3 with min. 300 mm spring Markwel brand.</p> <p>8.2. Nominal bore: 19 mm diameter</p> <p>8.3. Length of the discharge Hose: not less than 5 meter.</p> <p>8.4. Bursting pressure of Discharge hose: Not less than 50 kgf/cm<sup>2</sup>.</p> <p>9. Carbon Di Oxide (CO<sub>2</sub>)Cylinder:</p>		

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>9.1. CO2 gas cylinder: Conform to IS 7285 &amp; PESO (CCOE) approved            9.2. Capacity: 2 Kg CO2            9.3. CO2 cylinder valve : Conforming to IS 3224            9.4. CO2 cylinder shall have wheel valve with safety pin &amp; seal.</p> <p>10. High Pressure Copper Tubing with standing 275 kg/cm2 pressure &amp; it should not break while bending with minimum thickness 1.6mm.</p> <p>11. Drain Plug:            11.1. Materials for Construction (MOC) of Drain Plug: Leaded tin bronze, Grade LTB2 of IS 318 / Brass: Type I of IS 319            11.2. Diameter of Drain Plug: not less than 25 mm</p> <p>12. Wheeled Carriage (Trolley):            12.1. Axel of M.S. tube/ rod, fitted in in standard lubricated bearing shall be fitted along with the Wheel with Solid Rubber tyre having Dia. 300 x 75 mm. Trolley shall be robust in construction.            12.2. Lowest part of the body remains not less than 20 cm.</p> <p>13. Anti-Corrosive Treatment:            13.1. Phosphating by hot dipping process to thickness not less than 0.012 mm both Internally &amp; externally.            13.2. Epoxy polyester powder coating of minimum 50 micron thickness to all metallic external parts.</p> <p>14. Painting:            14.1. Extinguisher shall be painted with fire red colour conforming to shade No. 536 of IS 5.</p> <p>15. Marking :            15.1. Each extinguisher shall be clearly and permanently marked with the following information :            15.1.1. Manufacturer's name or trade-mark, serial number and year of manufacture shall be embossed at the bottom ring.            15.1.2. Words 'Dry Powder Extinguisher';            15.1.3. Capacity of the extinguisher in kg;            15.1.4. Letters indicating the various classes of fires for which the extinguisher is suitable;            15.1.5. Coloured Oil India Limited Logo along with the name of the company shall be painted on the extinguisher body.            15.1.6 All other markings on the extinguisher body shall be as per IS :10658.</p> <p>16. Extinguishing Media ( Dry Chemical Powder ):            16.1. Dry Chemical Powder Potassium- bi-carbonate (min 90% of total composition of the chemicals) based ISI marked Dry Chemical Powder confirming to IS: 4308 2008(or latest revision).            16.2. The Dry Chemical Powder shall be supplied in separate intact packets bearing ISI-mark (IS: 4308 of 2008) along with the supply of extinguishers.            16.3. The test certificate of 90% base material (i.e. Potassium Bi-Carbonate) to be shown at the time of inspection &amp; to be submitted along with supply.            16.4. DCP shall be compatible with all types of foams.            16.5. All containers of Dry Chemical Powder refills shall clearly and permanently mark with the following information.</p>		

**ANNEXURE-I****Tender No. : KID3884L15/04****Tender Date : 12.06.2014**

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>16.5.1. Name of the manufacturer or his trade mark;  16.5.2. Quantity of the powder in Kg;  16.5.3. Date of manufacture/Batch No;  16.5.4. Shelf life (5 years) of the Powder;  16.5.5. ISI Certification mark</p> <p>17. Additional accessories/ Spares (Similar specification):  17.1. Wheel Set : 01 Pair of wheel (with each extinguisher)  17.2. CO2 Cylinder : 01 No (with each extinguisher)  17.3. Discharge Hose with Nozzle : 01 No.(with each extinguisher)  17.4. High Pressure Copper Tubing : 01 No.(with each extinguisher)  17.5. Cap Joint Washer : 05 Nos.(with each extinguisher)  17.6. Safety Pin : 01 Nos. (with each extinguisher)  17.7 Cap : 5% of the total ordered quantity (If the calculated quantity is in decimals then next round figure will be considered for total number of quantity).</p> <p>18. Weather Proof Fire Extinguisher Cover shall be provided along with each extinguisher.</p> <p>19. Drawing &amp; Quality Assurance Plan (QAP): Vendor shall submit detailed drawing &amp; QAP along with material of construction &amp; obtain approval from OIL before start of fabrication.</p> <p>20. Test Requirements :The following test report to be submitted along with the supply of extinguisher :</p> <p>20.1.1. Dye Penetration Test 100% of weld joints.  20.1.2. Radiography Report (to be reviewed at the time of inspection # if applicable).  20.1.3. Performance Test one number per order lot.  20.1.4. Hydraulic Test of 10% of Ordered Quantity as per IS- 10658.  20.1.5 Performance test &amp; hydraulic test to be carried out at the time of inspection as per IS: 10658.</p>		

**Special Notes** : 1. The Bidder shall be an Original Equipment Manufacturer (OEM)/ authorized dealer/distributor of "Original Equipment Manufacturer (OEM).

1.1 In case the Bidder is an Original Equipment Manufacturer (OEM), the following criteria shall be met by the Bidder:-

1.1.1 The copy of "Certificate of Incorporation/ NSIC Certificate" of the firm shall be furnished along with the bid.

1.1.2 The Bidder shall be in the business of manufacturing of Fire Extinguishers continuously for last 3 (Three) years preceding to the Bid Closing date of this Tender. Necessary document {i.e. Copy of Audited Balance sheet for last 3 (Three) years} should be submitted along with bid.

1.2 In case the Bidder is an authorized dealer/distributor of "Original Equipment Manufacturer

**ANNEXURE-I**

**Tender No. : KID3884L15/04**

**Tender Date : 12.06.2014**

(OEM):-

1.2.1 Bidder shall submit a Certificate in original in support of authorization of dealership/distributorship with back up Warranty & Guarantee from the "Original Equipment Manufacturer (OEM)" to quote for this tender.

1.2.2 The Bidder shall confirm experience criteria as stipulated under clauses 1.1.2 above from Original equipment manufacturer (OEM). Necessary documents as mentioned above shall be submitted along with bid.

2. The Bidder shall submit a copy of valid BIS certificate of Fire Extinguishers having 25,50 & 75 Kg capacity .

3. Inspection will be carried out at supplier's work by our company representative before dispatch of the material.

4. WARRANTY: The bidders shall provide warranty for minimum 12 Months from the Date of Commissioning or 18 Months from the Date of Supply.

3. Validity of offer: 75 days from the date of tender opening. Offer with validity less than 75 days will be rejected.

Tender No. : KID3884L15/04  
Tender Date : 12.06.2014  
Bid Closing On : 15.07.2014 at 14:00 hrs.(IST)  
Bid Opening On : 15.07.2014 at 14:00 hrs.(IST)

**Tender issued to following parties only:**

Slno	V_Code	Vendor Name	City/Country
1	200390	KOOVERJI DEVSHI & CO. PVT.LTD.	NAVI MUMBAI
2	201113	GUNNEBO INDIA PVT. LTD.	KOLKATA
3	201214	ZENITH FIRE SERVICES (INDIA) PVT.LT	MUMBAI
4	203287	NITIN FIRE PROTECTION INDUSTRIES LT	MUMBAI
5	203423	VIJAY INDUSTRIES AND PROJECTS LIMIT	KOLKATA
6	203424	PETER AUTEKITS PVT. LTD.	MUMBAI
7	204603	VIJAY INDUSTRIES & PROJECTS LTD.	MUMBAI
8	209670	SUPREMEX EQUIPMENT	MUMBAI
9	210120	UNICARE FIRE SAFETY (I) PVT. LTD.	NOIDA
10	210121	KANADIA FYR FYTER PVT.LTD.	MUMBAI
11	210122	HINDUSTAN FIRE PROTECTION	MUMBAI
12	210242	MODI INTERNATIONAL	NEW DELHI
13	210243	VINTEX FIRE PROTECTION PVT. LTD.	MUMBAI
14	210731	SAFEX FIRE SERVICES LTD.	MUMBAI
15	211025	NAAZ ENGINEERING WORKS	MUMBAI
16	211026	CEASEFIRE INDUSTRIES LIMITED	NOIDA