

OIL INDIA LIMITED

(A Govt. Of India Enterprise) Tel :033 2230 1657, 1658
 4, India Exchange Place, Fax :91 33 2230 2596
 Kolkata-700001 E-mail :oilcalmn@oilindia.in

Tender No. & Date : KID4830L15/04 09.09.2014

Bid Security Amount : INR 0.00 OR USD 0.00
 (or equivalent Amount in any currency)

Bidding Type : Single Bid (Composite Bid)

Bid Closing On : 14.10.2014 at 14:00 hrs. (IST)
 Bid Opening On : 14.10.2014 at 14:00 hrs. (IST)

Performance Guarantee : Not Applicable

OIL INDIA LIMITED invites Limited tenders for items detailed below:

Item No./ Mat. Code	Material Description	Quantity	UOM
10 99030901	<p>FIRE EXTINGUISHER,CART.TYPE,9KG CAP DCP</p> <p>Specification / Data Sheet for 9.0 Kg. Capacity Portable DCP Fire Extinguisher (Cartridge Type)</p> <p>Sr. No. ITEM REQUIREMENT</p> <p>1.00 General</p> <p>1.01 Standard Code Conforming to IS 15683 : 2006 (latest revisions as on bid due date)</p> <p>1.02 Marking IS : 15683</p> <p>1.03 Type Cartridge Type</p> <p>1.04 Fire Rating 9.0 Kgs Capacity : 34B</p> <p>1.05 Classification Class B & Class C</p> <p>2.00 Material of Construction</p> <p>2.01</p> <p>(a) Body Carbon Steel as per - IS: 513 (latest revision), with minimum 1.8 mm thickness of the extinguisher shell including dished ends. EDD grade with no vertical weld joint on the body.</p> <p>(b)Extinguisher shall be fabricated out of sheet of minimum 2mm thickness.</p> <p>2.02 Neck Ring Seamless Mild Steel Tube conforming to IS: 1239 (Part 1)- Latest Revision.</p> <p>2.03 Valve Assembly SS-316 or Forged Brass as per IS:6912 grade FLB(Latest Revision)</p>	600	NO

Tender No. & Date : KID4830L15/04 09.09.2014

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>2.04 Siphon Tubes (Inlet & Outlet) SS-316 or Brass as per IS:407 or Aluminium.</p> <p>2.05 Discharge Nozzle SS-316 or Forged Brass as per IS: 6912 grade FLB (Latest Revision) or PVC with metal insert</p> <p>2.06 Discharge Hose EPDM Rubber (length 500 mm).</p> <p>2.07 Wall Mounting Bracket Mild Steel (Powder coated)</p> <p>2.08 Safety Pin SS-316</p> <p>3.00 Extinguishing Media</p> <p>3.01 Dry Chemical Powder Potassium bi-carbonate (min 90% of total composition of the chemicals) based ISI marked Dry Chemical Powder confirming to IS: 4308 (latest revision).</p> <p>4.00 Gas Cartridge</p> <p>4.01 Co2 Gas cartridge ISI marked as per IS: 4947(latest revision) Nominal Capacity for 9 KG. DCP Extinguisher: 180/200 gms. Each Cartridge shall be individually wrapped in wax paper or put in a shroud of tray- orphan and packed in strong carton made out of corrugated board.</p> <p>5.00 Dimensions</p> <p>5.01 Diameter of body 9 Kg : 175 ± 10 mm</p> <p>5.02 Overall Height 9 Kg : Less than 650 mm</p> <p>6.00 General Operating</p> <p>6.01 Operating Temperature 0 deg C to +55 deg C</p> <p>7.00 Painting/Marking</p> <p>7.01 Anticorrosive Treatment Phosphating by hot dipping process to thickness not less than 0.012 mm both Internally & externally.</p> <p>7.02 Painting Epoxy polyester powder coating of minimum 50 micron thickness to all metallic external parts.</p> <p>7.03 A small band of blue colour of 5 percent of surface area shall be painted on the extinguisher</p> <p>7.04 Marking Coloured Oil India Limited Logo along-with Name of the Company (Minimum 40 mm size) shall be printed on the extinguisher body.All other markings as per IS:15683</p> <p>7.05 Finish Post Office red as per Shade 538 of IS:5</p>		

Tender No. & Date : KID4830L15/04 09.09.2014

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>8.00 Drawing & Quality Assurance Plan(QAP)</p> <p>8.01 Drawing Vendor shall submit detailed drawing along with material of construction & obtain approval of OIL before start of fabrication.</p> <p>8.02 QAP Vendor shall submit detailed Quality Assurance Plan & obtain approval of OIL before start of fabrication.</p> <p>8.03 Extinguisher shall be confirming to IS: 15683 latest revisions as on bid due date.</p> <p>8.04 Data Sheet contains only specific requirements for the items mentioned in data sheet.</p> <p>8.05 IS codes mentioned above shall be latest revision as on bid due date.</p> <p>8.06 Two (2) nos. extra (Spare) Co2 Gas Cartridge with ISI marked as per IS: 4947(latest revision), Nominal Capacity for 9 KG. DCP Extinguisher: 180/200 gms are to be supplied along with each extinguisher. These cartridges are in addition to the one no. Co2 gas cartridge supplied along with the extinguisher. Each Cartridge shall be individually wrapped in wax paper or put in a shroud of tray- orphan and packed in strong carton made out of corrugated board.</p> <p>8.07 Quantity of Spanner to be provided for Maintenance of Fire Extinguishers: Two (2) percent of the ordered quantity of Fire Extinguishers to be provided.</p> <p>9) IS codes mentioned above shall be latest revision as on bid due date.</p>		

Special Notes : 1. Each Fire extinguisher shall be provided with a PVC base cover.

2. The Dry Chemical Powder shall not be filled in the Fire extinguisher during supply. The DCP shall be supplied separately in 9kg bags along with the Fire extinguisher.

3. Bidder's response to all NIT stipulations should clearly be defined. Bidder shall furnish specific details/specifications of all major components.

4. Generalised response like - 'As per NIT Specifications/Technical Leaflet', 'Noted', and 'Accepted' or in any similar fashion is not acceptable.

5. WARRANTY : The bidders shall provide warranty for minimum 12 Months from the Date of Commissioning or 18 Months from the Date of Supply.

6. The Bidder shall be an Original Equipment Manufacturer (OEM) and shall be in the business of manufacturing of Fire Extinguishers continuously for the last 3 years as on Bid Closing Date of this tender. Documentary evidence to be provided.

7. The Bidder must have valid BIS approval certificate of tendered 9.0 Kg. Capacity Portable

DCP Fire Extinguisher (Cartridge Type). Credentials to this effect shall be submitted along with the bid for evaluation without which offer will be summarily rejected.

8. Inspection will be carried out by OIL at supplier's work in presence of third party before dispatch of the material.

9. Validity of offer : 75 days from the date of tender opening. Offer with validity less than 75 days will be rejected.

Tender No. : KID4830L15/04
Tender Date : 09.09.2014
Bid Closing On : 14.10.2014 at 14:00 hrs.(IST)
Bid Opening On : 14.10.2014 at 14:00 hrs.(IST)

Tender issued to following parties only:

Slno	V_Code	Vendor Name	City/Country
1	200390	KOOVERJI DEVSHI & CO. PVT.LTD.	NAVI MUMBAI
2	201113	GUNNEBO INDIA PVT. LTD.	KOLKATA
3	201214	ZENITH FIRE SERVICES (INDIA) PVT.LT	MUMBAI
4	203287	NITIN FIRE PROTECTION INDUSTRIES LT	MUMBAI
5	203423	VIJAY INDUSTRIES AND PROJECTS LIMIT	KOLKATA
6	203424	PETER AUTEKITS PVT. LTD.	MUMBAI
7	204603	VIJAY INDUSTRIES & PROJECTS LTD.	MUMBAI
8	209670	SUPREMEX EQUIPMENT	MUMBAI
9	210120	UNICARE FIRE SAFETY (I) PVT. LTD.	NOIDA
10	210121	KANADIA FYR FYTER PVT.LTD.	MUMBAI
11	210122	HINDUSTAN FIRE PROTECTION	MUMBAI
12	210242	MODI INTERNATIONAL	NEW DELHI
13	210243	VINTEX FIRE PROTECTION PVT. LTD.	MUMBAI
14	210731	SAFEX FIRE SERVICES LTD.	MUMBAI
15	211025	NAAZ ENGINEERING WORKS	MUMBAI
16	211026	CEASEFIRE INDUSTRIES LIMITED	NOIDA