

TENDER NO. DIS7064L16 DATED 29.04.2015

Other than the vendors to whom the enquiry has been issued, interested vendors who wish to participate in the tender may apply with proper credentials and other relevant details so as to reach Head-Materials, Oil India Limited, P.O. Duliajan, Dist. Dibrugarh, Assam – 786602 (e-mail : material@oilindia.in, Fax : 0374-2800533) within 10 days of publication of the tender on OIL's website.

The vendors must fulfill the following conditions:

- i) The party should have 03 (three) years' experience as on the Bid closing date for the same item.
- ii) The party should have received one order for at least 50% quantity in last 03 (three) years' (as on the Bid closing date) for the item from any reputed firm.
- iii) Annual turnover of the firm in any of the last 3 (three) financial years or current financial year should be more than Rs. 13.07 Lakhs.

NOTE:

- a. The applicant must meet the above qualifying criteria for which documentary evidence should be enclosed by the applicant with the application without which tender document shall not be issued.
- b. Relevant documents in support of experience, last order and annual turnover must be submitted along with the application.
- c. Application without complete supporting document will not be considered.

OIL INDIA LIMITED

(A Govt. of India Enterprise) Fax No. 91-0374-2800533
P.O. Duliajan-786602, Assam E-mail:material@oilindia.in

ANNEXURE-I**Tender No. : DIS7064L16/L4****Tender Date : 29.04.2015**

Item No./ Mat. Code	Material Description	Quantity	UOM
50 81062069	WIRING MATERIALS MILL LAMP MLL blended lamp as per following specifications : a) Wattage (W) : 160W b) Voltage Rating : 240 Volts A.C. c) Nominal Voltage : 190 Volts d) Cap : ES 27 e) Average life : Above 5000 Hrs. f) Luminous flux (Lumens) : 2900 MAKE : PHILLIPS/OSRAM/BAJAJ/OSAKA/CROMPTON/GE Lighting	1500	NO
90 81030584	DISTRIBUTION BOARDS Plug & socket mounted metallic Distribution Board complete with 20A, 240vAC, SP MCB & having following features. The DB should made from CRCA sheet steel which is given seven tank anti corrosion treatment & then powder coated (thickness of paint 50 micron) in white colour. One no. Plug/socket set 20amp, 240vAC rated (2P+E), scrapping earth pin & as per IS-8804 should be mounted in the DB. Plug and socket housing should be made of metallic alloy and painted in white colour. Plug to have suitably strong sleeve to prevent stress on cable end connections. Socket with protective cap to be mounted on metallic box. TB should be provided inside DB for termination of supply neutral wire. Single core, 1100v grade, PVC insulated, 4.0 sqmm stranded copper wires with tinned copper lugs are to be connected from MCB output and neutral TB to phase and neutral terminals of the socket. Wire loop (4.0 sqmm copper) should be connected for earthing of socket earth to DB enclosure. External & internal earth terminal, top & bottom cable entry knockouts & mounting holes on back are to be provided in the DB. MCB should be 'C' curve, 240vAC rated, 10kA rated breaking capacity, DMC based insulating material housing, suitable for class-II tropicalisation (as per IEC) & approved by ISI. MCB should have integrated label holder, biconnect upper & lower terminals & air channels for low temp. rise. Party to mention part no. of box, plug, socket and MCB in the offer. Make:Legrand/Schneider Electric/Siemens/Havells	150	NO
60 81062333	SPARES FOR HIGH PRESSURE SODIUM VAPOUR (HPSV) LIGHT FITTINGS Ballast for SON 400 Watt High Pressure Sodium Vapour (HPSV) Light Fittings, similar to Type C8 341L/11 and of Make : Philips having the overall dimension in length (L), breadth (B) and height (H). 185 mm (L), 95 mm (B), 80 mm (H) Make : PHILIPS/BAJAJ/CROMPTON GREAVES/GEC ALSTHOM.	200	NO
70 81062344	Spares for High Pressure Sodium Vapour (HPSV) Light Fittings, Type SNF-14 1 X 400 W. Electronic Ignitor similar to type SN-58 Make : Philips/Crompton	400	NO

ANNEXURE-I

Tender No. : DIS7064L16/L4
Tender Date : 29.04.2015

Item No./ Mat. Code	Material Description	Quantity	UOM
80 81062381	Ballast for 400 Watt HPSV Light Fittings, similar to Type BJS/MH400 of Make : BAJAJ conforming to IEC 922 and IEC 923 having the overall dimension in length (L), breadth (B) and height (H). 140 mm (L) x 110 mm (B) x 100 mm (H) Make : Bajaj/Philips/GE/Crompton Greaves.	100	NO
20 81100051	SWITCH FUSES, I.C. SWITCH FUSES, PORCELAIN FUSES, PLUGS AND SOCKETS 32 amp. 240V AC, SPN Switch Fuse Unit, non-weatherproof type complete with one no. 32 amp porcelain fuse base and carrier and one no. removable neutral link. All contacts and connectors shall be made from hard silver coated electrolytic grade copper. Conduit entry : 19/20 mm at top and bottom with rubber grommet ring or knockout. Enclosure and cover shall be made from rust free MS sheet and powder coated in White/DA Grey colour. Enclosure cover shall have neoprene gasket. Operating handle shall be provided in the side of the unit. One no. external earth point shall be provided in the unit. Switch Fuse Unit shall be suitable for mounting on wall and shall confirm to IS-13947 (Part-3) with latest amendments. Make : BCH/Havell's/GE	100	NO
30 81100062	63 amp, 240V AC, Single Pole Switch Fuse Unit, non-weatherproof type complete with one no. 63 amp porcelain fuse base and carrier and one no. removable neutral link. All contacts and connectors shall be made from hard silver coated electrolytic grade copper. Conduit entry : 20/25 mm at top and bottom with rubber grommet ring or knockout. Enclosure and cover shall be made from rust free MS sheet and powder coated in White/DA Grey colour. Enclosure cover shall have neoprene rubber gasket. Metallic operating handle shall be provided in the side of the unit. One no. external earth point shall be provided in the unit. Switch Fuse Unit shall be suitable for mounting on wall and shall confirm to IS-13947 (Part-3) with latest amendments. Make : GE/Havells/BCH.	40	NO
40 81100118	Switch, Fuse Unit, 32 amp, 415V AC, TPN non weatherproof type complete with three nos. 30 amp moulded type fuse base and carrier fitted with three nos. 32 amp HRC fuselinks and one neutral link. All contacts shall be made from hard silver coated electrolytic grade copper. Conduit entry. 19/20 mm at top and bottom with rubber grommet ring or knockouts. Enclosure and cover should be made from rust free MS sheet and powder coated in White/DA Grey colour. Enclosure cover should have neoprene rubber gasket and shall have operating handle on side. Two nos. external earth points shall be provided in the unit. Switch Fuse Unit shall be suitable for mounting on wall and shall confirm to IS-13947 (Part-3) with latest amendments.	35	NO

ANNEXURE-I

Tender No. : DIS7064L16/L4
Tender Date : 29.04.2015

Item No./ Mat. Code	Material Description	Quantity	UOM
	Make : BCH/Havell's/GEPC		
10 81094160	SPARES FOR DCPCR OF S-3 & S-4 AC SCR RIGS TWIN AVIATION LIGHT FITTING, LED BASED LED based low intensity twin aviation obstruction warning light with all accessories with the following specifications: Colour of the LEDs: Red (fixed), Supply voltage: 230 VAC, Intensity: 10 Candelas in any direction, Protection: IP 65, Weight: Not more than 4.0 Kgs; fitting should be vibration and shock resistant against severe vibration. The complete unit shall be mounted on a sturdy frame with fixing arrangement. Make: Baliga/ Crompton Greaves/ Microtech/ Ama/ Bajaj	10	NO

Note description for item no./nos. : 10

NOTES :

- 1) Items shall be procured from manufacturers or their authorized dealers/agents only. Offers without valid dealership certificates shall not be considered for evaluation.
- 2) Technical catalogues/drawings/manuals etc. shall be submitted along with the offer.

Note description for item no./nos. : 80

NOTE :

Make : BAJAJ, PHILIPS, CROMPTON GREAVES, GELIGHTING.

Note description for item no./nos. : 20, 40

Note :

Electrical fitting item(s) must bear IS Monogram

Standard Notes: (1) **VALIDITY :** Your offer must be valid for 75 days from the date of bid opening. Offer with inadequate validity will be rejected.

(2) The offer should be submitted in Duplicate.

(3) Any sum of money due and payable to the contractor (including Security Deposit refundable to them) under this or any other contract may be appropriated by Oil India Limited and set-off against any claim of Oil India Limited (or such other person or persons contracting through Oil India Limited) for payment of a sum of money arising out of this contract or under any other contract made by the contractor with Oil India Limited (or such other person or persons contracting through Oil India Limited).

(4) In the event you authorize your dealer/stockist/channel partner to quote on your behalf, the dealer/stockist/channel partner while submitting bid should mention on the body of the envelope that they are submitting bid on your behalf.

In the event the dealer/stockist/channel partner do not mention the name of their OEM/principal on the body of the envelope, the offer shall be treated as unsolicited offer and will not be considered for opening.

The dealer/stockist/channel partner should take note of above while submitting bid on behalf of

ANNEXURE-I

Tender No. : DIS7064L16/L4
Tender Date : 29.04.2015

their OEM/principal.

(5) For order with F.O.R. Destination term, 100% payment against despatch documents will not be entertained. In this regards please refer payment terms in ANNEXURE-MM/TENDER/LP/01/06.

(6) To evaluate the inter-se ranking of the offers, Assam Entry Tax on purchase value will be loaded as per prevailing Government of Assam Guidelines as applicable on bid closing date. Bidders may check this with the appropriate authority while submitting their bids.

(7) Bidder must mention page no./nos. in every pages of their offer.

(8) Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.

(9) Bidder should clearly mention their name and address on the outside of the envelope containing their offer.

(10) In the event of receipt of only a single offer against the tender within B.C.date, OIL reserves the right to extend the B.C. date as deemed fit by the company. During the extended period, the bidders who have already submitted the bids on or before the original B.C date, shall not be permitted to revise their quotation.

Special Notes : 1) Please submit valid dealership certificate of the offered items from OEM.
2) Please submit technical literature/catalogue to the offered products.
3) Please confirm make of the offered items.

NOTE : Your offer may not be evaluated in the absence of above documents.

Tender No. : DIS7064L16/L4
Tender Date : 29.04.2015
Bid Closing On : 04.06.2015 at 13:00 hrs.(IST)
Bid Opening On : 04.06.2015 at 13:00 hrs.(IST)

Tender issued to following parties only:

S/no	V_Code	Vendor Name	City/Country
1	200211	STEEL & INDUSTRIAL STORES	ASSAM
2	200310	ASSAM ELECTRICALS	TINSUKIA
3	200384	PHILIPS ELECTRONICS INDIA LIMITED	KOLKATA
4	200832	INDUSTRIAL EQUIPMENTS	GUWAHATI
5	201832	BAJAJ ELECTRICALS LIMITED	GUWAHATI
6	202000	BENGAL ELECTRICAL INDUSTRIES	KOLKATA
7	202289	U.K. ENTERPRISE	GUWAHATI
8	203062	GLOCON	TINSUKIA
9	203118	OSRAM INDIA LTD	KOLKATA - 700 020
10	203202	HAVELL'S INDIA LIMITED	GUWAHATI
11	203453	ELMECH TRADERS	TINSUKIA
12	203577	ARADHANA AGENCY	GUWAHATI
13	203799	CROMPTON GREAVES LTD	GUWAHATI
14	204724	KIRAN ELECTRONICS	GUWAHATI
15	204799	NATIONAL ELECTRIC CORPN (CAL)	KOLKATA
16	205062	POWER GRID ASSOCIATES	DULIAJAN
17	205108	GE INDIA INDUSTRIAL PVT. LTD.	KOLKATA
18	205574	NATIONAL MARKETING ENTERPRISES	TINSUKIA
19	208329	GARG HARDWARE & ELECTRICALS	JORHAT
20	208781	SHIV ENTERPRISE	TINSUKIA
21	208845	BALAJI ELECTRICALS	TINSUKIA
22	210398	TIRUPATI ELECTRICAL	DULIAJAN
23	401861	R K CHETIA	DULIAJAN