

TENDER NO. DIS9304L16 DATED 23.11.2015

Other than the vendors to whom the enquiry has been issued, interested vendors who wish to participate in the tender may apply with proper credentials and other relevant details so as to reach Head-Materials, Oil India Limited, P.O. Duliajan, Dist. Dibrugarh, Assam – 786602 (e-mail : material@oilindia.in, Fax : 0374-2800533) within 10 days of publication of the tender on OIL's website.

The vendors must fulfill the following conditions:

- i) The party should have 03 (three) years' experience as on the Bid closing date for the same item.
- ii) The party should have received one order for at least 50% quantity in last 03 (three) years' (as on the Bid closing date) for the item from any reputed firm.
- iii) Annual turnover of the firm in any of the last 3 (three) financial years or current financial year should be more than Rs. 08.61 Lakhs.

NOTE:

- a. The applicant must meet the above qualifying criteria for which documentary evidence should be enclosed by the applicant with the application without which tender document shall not be issued.
- b. Relevant documents in support of experience, last order and annual turnover must be submitted along with the application.
- c. Application without complete supporting document will not be considered.

OIL INDIA LIMITED

(A Govt. of India Enterprise) Fax No. 91-0374-2800533
P.O. Duliajan-786602, Assam E-mail:material@oilindia.in

ANNEXURE-I**Tender No. : DIS9304L16/L4****Tender Date : 23.11.2015**

Item No./ Mat. Code	Material Description	Quantity	UOM
20 81090567	LIGHTING FITTING AND SHADES INDUSTRIAL Lamp holder for FLP flood loght, porcelain G.E.S. type suitable for 500 watts lamp and suitable for Baliger Cat. No. FLP - 3690 or similar.	400	NO
10 81090487	<p>FLP FLOOD LIGHT FITTINGS FOR ILLUMINATION OF DERRICKS IN DRILLING RIGS.</p> <p>A. LIGHT FITTINGS : Flameproof and Weatherproof non-integral type flood light fittings similar to type LF 31400 of CEAG FCG make suitable for 400W HPMV lamps 230 +/- 5%, 1 phase, 50 HZ supply with 250W HPMV bulbs fitted and matching control gear box for use in hazardous zone 1 & 2 and hazardous gas group IIA & IIB with the following specifications :</p> <p>(a) "Flameproof" and "Weatherproof" bear the definitions as described in IS:5572/1994 and IS:2148/1981. (b) Type of protection : EX-d (c) Degree of protection : IP65 as per IS:13947 (Part-I)/1993 (d) Suitable for use in gas groups IIA & IIB as per IS:2148/1981 (e) Must be light in weight - maximum permissible weight : 22 kgs. (f) Enclosure material : Die cast Aluminium alloy (LM-6 or similar) (g) Transparent part : Heat and Impact resistant toughened type 'A' glass, preferable "T3" type as per IS:2206 (Part-I) (h) Lamp holder Porcelain, Type ES-40 (i) Internal reflector : Aluminium anodized (j) Gasket : Endless moulded neoprene (k) Hardware : Stainless Steel (l) Cable entry details : 1 x 3/4" ET, sealed with FLP stopping plug (one no. FLP cable gland suitable for 4 core 1.5 mm 2 EPR cable should be separately packed). (m) Earthing points : 02 Nos. outside of the fitting and 01 No. inside of the fitting to be provided. (Total 3 points) (n) Finish : Anti-corrosive powder coated epoxy gray. (o) CMRI certification and DGMS approval No. : Bidder to specify them and supporting documents shall be enclosed. Also, a separate tag plate shall be embossed on the fitting stating the CMRI certificate and DGMS approval No. with date.</p> <p>(B) FLP CONTROL GEAR BOX FOR THE ABOVE FITTINGS : Flameproof and Weatherproof Control Gear Box for item A above, similar to Cat.No. LC-31400 of CEAG FCG make complete with ballast, ignitor, capacitor and control fuse suitable for 250W HPMV lamps upto 250V, 1 phase, 50HZ for use in hazardous zone 1 & 2 and hazardous area gas group IIA & IIB with following specifications :</p> <p>(a) "Flameproof" and "Weatherproof" bear the definitions as described in IS:5572/1994 and IS:2148/1981 (b) Type of protection : Ex-d (c) Degree of protection : IP65 as per IS:13947 (Part-I) 1993 (d) Suitable for use in gas groups IIA & IIB as per IS:248/1981 (e) Enclosure material : Die cast Aluminium alloy (LM-6 or similar) with</p>	40	NO

ANNEXURE-I

Tender No. : DIS9304L16/L4
Tender Date : 23.11.2015

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>neoprene gasket.</p> <p>(f) <u>Components</u> : Suitable for 250W HPMV lamps</p> <p>i) Copper wound ballast</p> <p>ii) Capacitor</p> <p>iii) HRC fuse</p> <p>iv) Ignitor</p> <p>v) Terminal block</p> <p>g) Cable entries : 3 x 3/4" ET sealed with FLP stopping plug (3 Nos. FLP cable glands suitable for 4 core 1.5 mm.sqr. EPR cable should be separately packed).</p> <p>(h) Earthing points : 02 Nos. outside of the fitting and 01 No. inside of the fitting to be provided (Total 3 points).</p> <p>(i) Finish : Anti-corrosive powder coated epoxy gray</p> <p>(j) CMRI certificate and DGMS approval No. : Bidder to specify them and supporting documents shall be enclosed. Also, a separate tag plate shall be embossed on the fitting stating the CMRI certificate and DGMS approval No. with date.</p> <p><u>Accessories</u> :</p> <p>Reputed make tool kit one set containing Allen keys of all sizes used in the fitting :</p> <p>1 set for every 4 Nos. of fittings.</p> <p>Galvanized nuts, bolts and washers suitable for fixing the flood light fittings : 1 set per fittings.</p> <p>Galvanized nuts, bolts and washer suitable for fixing the control gear boxes : 1 set per box.</p>		
<p>30 81270013</p>	<p>SPARES FOR DC - P.C.R. OF S-5 & S-6 AC-SCR BHEL E-1400 RIGS.</p> <p>GROUP : RIG LIGHTING</p> <p>Flame proof and weather proof START/STOP push Button</p> <p>Station as per the following specifications :</p> <p>a) Ratings : 10 Amps, 415 Volts AC, 50 Hz.</p> <p>b) Components :- i) 1 N.O. + 1 N.C. contactelement for START/STOP operation.</p> <p>ii) Colour of Actuator - RED for STOP and GREEN for START with mechanical interlock on STOP Button.</p> <p>c) Materials of construction-Die-cast Aluminium Alloy LM6</p> <p>d) Enclosure - Flame proof Exd as per IS-2148.</p> <p>e) Protection - IP-55 as per IS-2147</p> <p>f) Hazardous Area classification - Zone - 1 & Zone - 2.</p> <p>g) Gas Group : IIA & IIB as per IS-2148.</p> <p>h) Cable entry : 2 Nos. at bottom with 3/4" ET thread. One entry should be provided with FLP double compression gland suitable for 19 mm. O.D. Cable and the other entry should be provided with suitable size FLP stop plug.</p> <p>i) Rain hood/canopy : Suitable size canopy to be provided with the PBS for rain water protection.</p> <p>j) Mounting : On wall/structure by 10 mm diameter 4 holes.</p> <p>k) Finish : Anti-corrosive Epoxy light Grey shade 631 including canopy.</p> <p>l) Weight : 2.25 Kg. (approx.)</p>	30	NO

ANNEXURE-I

Tender No. : DIS9304L16/L4
Tender Date : 23.11.2015

Item No./ Mat. Code	Material Description	Quantity	UOM
	m) C.M.R.S. Certificate Ref. No. n) D.G.M.S. Approval No. o) Catalogue No. 30202 p) Identification Mark : A plate bearing the C.M.R.S. Ref.No. and D.G.M.S. Approval No. shall be rivetted on the face of the PBS unit. q) Earthing : Provision should be made for one no. earthing stud inside and two nos. earthing studs outside of the PBS unit. r) Make : CEAG Flame Proof Control Gears Pvt. Limited, Mumbai or equivalent. Part No. BP405C543010		

Note description for item no./nos. : 10

NOTES :

- 1) Quotations should be supported by catalogue, copies of CMRS certificate, DGMS approval letters with complete technical details and sent to Chief Engineer(Electrical) for technical scrutiny.
- 2) Item A & B should be of same make
- 3) Special care should be taken in packing of the material to avoid transit damage. Transporter should be advised to take proper care during loading and unloading and transportation of material.
- 4) Offers incomplete and not supported by CMRS certificate and DGMS approval will be liable for rejection.
- 5) Items are to be procured from manufacturers or their authorized dealers only
- 6) This item falls under Spl. item list Srl. No. 65

Note description for item no./nos. : 30

- 1) Above items shall be suitable for use in hazardous area Zone-1 and Zone-2 and Gas Group-IIA & IIB of the Oil and Gas field. The item must be certified by C.M.R.S. and approved by D.G.M.S. The copies of CMRS certificate and DGMS approval must be enclosed for our scrutiny.
- 2) The bidders should also submit detailed technical catalogue including dimensional drawings of the item for our scrutiny.
- 3) The suppliers shall have to provide guarantee for a minimum period of 18 months from the date of receipt for any faulty materials and workmanship of the item.
- 4) Packing should be adequate to avoid any transit damage and moisture ingress.
- 5) Item shall be procured from the manufacturer or their authorised dealers only

Standard Notes: (1) Other than the vendors to whom the enquiry has been issued, interested vendors who wish to participate in the tender may apply with proper credentials and other relevant details so as to reach Head-Materials, Oil India Limited, P.O. Duliajan, Dist. Dibrugarh, Assam - 786602 (e-mail : material@oilindia.in, Fax : 0374-2800533) within 10 days of publication of the tender on OIL's website.

(2) **VALIDITY :** Your offer must be valid for 75 days from the date of bid opening. Offer with inadequate validity will be rejected.

(3) The offer should be submitted in Duplicate.

(4) Any sum of money due and payable to the contractor (including Security Deposit refundable to them) under this or any other contract may be appropriated by Oil India Limited and set-off against any claim of Oil India Limited (or such other person or persons contracting

ANNEXURE-I

Tender No. : DIS9304L16/L4
Tender Date : 23.11.2015

through Oil India Limited) for payment of a sum of money arising out of this contract or under any other contract made by the contractor with Oil India Limited (or such other person or persons contracting through Oil India Limited).

(5) In the event you authorize your dealer/stockist/channel partner to quote on your behalf, the dealer/stockist/channel partner while submitting bid should mention on the body of the envelope that they are submitting bid on your behalf.

In the event the dealer/stockist/channel partner do not mention the name of their OEM/principal on the body of the envelope, the offer shall be treated as unsolicited offer and will not be considered for opening.

The dealer/stockist/channel partner should take note of above while submitting bid on behalf of their OEM/principal.

(6) For order with F.O.R. Destination term, 100% payment against despatch documents will not be entertained. In this regards please refer payment terms in ANNEXURE-MM/TENDER/LP/01/06.

(7) To evaluate the inter-se ranking of the offers, Assam Entry Tax on purchase value will be loaded as per prevailing Government of Assam Guidelines as applicable on bid closing date. Bidders may check this with the appropriate authority while submitting their bids.

(8) Bidder must mention page no./nos. in every pages of their offer.

(9) Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.

(10) Bidder should clearly mention their name and address on the outside of the envelope containing their offer.

(11) In the event of receipt of only a single offer against the tender within B.C.date, OIL reserves the right to extend the B.C. date as deemed fit by the company. During the extended period, the bidders who have already submitted the bids on or before the original B.C date, shall not be permitted to revise their quotation.

Special Notes : 1) Bid Rejection Criteria : The vendors should submit/mention following alongwith their quotation : (a) Valid dealership certificate, (b) Technical catalogue / Literature of their offered Make, (c) Make of the offered product. The offer of the vendor shall be rejected straightway in case if above are not submitted / mentioned by them in their quotation.

2) Bidder other than OEM must forward their valid dealership/authorization certificate against tender along with their offer.

Tender No. : DIS9304L16/L4
Tender Date : 23.11.2015
Bid Closing On : 24.12.2015 at 13:00 hrs.(IST)
Bid Opening On : 24.12.2015 at 13:00 hrs.(IST)

Tender issued to following parties only:

Slno	V_Code	Vendor Name	City/Country
1	200313	FCG FLAMEPROOF CONTROL GEARS PVT.LT	MUMBAI
2	200573	BALIGA LIGHTING EQUIPMENT PVT. LTD.	CHENNAI
3	201116	SUNIL & CO.	KOLKATA
4	202594	ANDREW YULE & CO. LIMITED	KOLKATA
5	204856	PRATIK ENGINEERING SERVICES	TINSUKIA
6	205663	FCG POWER INDUSTRIES PVT.LTD	MUMBAI
7	207641	HIMALAYA ENGINEERS	VODODARA
8	209658	SABITRI SALES CORPORATION	DIBRUGARH
9	209659	INDUSTRIAL PRODUCTS EQUIPMENT	MUMBAI