

OIL INDIA LIMITED

(A Govt. Of India Enterprise) Tel :033 2230 1657, 1658
 4, India Exchange Place, Fax :91 33 2230 2596
 Kolkata-700001 E-mail :oilcalmn@oilindia.in

Tender No. & Date : KID1985L17/04 03.08.2016

Bid Security Amount : INR 0.00 OR USD 0.00
 (or equivalent Amount in any currency)

Bidding Type : Single Bid (Composite Bid)

Bid Closing On : 13.09.2016 at 14:00 hrs. (IST)

Bid Opening On : 13.09.2016 at 14:00 hrs. (IST)

Performance Guarantee : Applicable

OIL INDIA LIMITED invites Limited tenders for items detailed below:

Item No./ Mat. Code	Material Description	Quantity	UOM
10 99000775	Fire Extinguishers required for various installations at Duliajan, Moran & Manabhum. Specification / Data Sheet for 9.0 Kg. Capacity Portable DCP Fire Extinguisher (Stored Pressure Type) Sr. No. ITEM REQUIREMENT 1.00 General 1.01 Standard Code Conforming to IS 15683 : 2006 (latest revisions as on bid due date) 1.02 Marking IS : 15683 1.03 Type Portable Stored Pressure Type 1.04 Fire Rating 34B 1.05 Classification Class B & Class C 2.00 Material of Construction 2.01 Body Carbon Steel as per # IS:513 (latest revision), EDD grade with no vertical weld joint on the body. 2.02 Neck Ring Seamless Mild Steel Tube conforming to IS:1239 (Part 1)-Latest Revision. 2.03 Valve Assembly SS-316 or Forged Brass as per IS:6912 grade FLB(Latest Revision) 2.04 Siphon Tubes (Inlet & Outlet) SS-316 or Brass as per IS:407 2.05 Discharge Nozzle SS-316 or Forged Brass as per IS:6912 grade FLB (Latest Revision)	300	NO

Tender No. & Date : KID1985L17/04 03.08.2016

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>2.06 Discharge Hose EPDM Rubber (length 500 mm).</p> <p>2.07 Wall Mounting Bracket Mild Steel (Powder coated)</p> <p>2.08 Safety Pin SS-316</p> <p>2.09 Pressure Gauge / Indicator As per IS:15683(latest revision)</p> <p>3.00 Extinguishing Media</p> <p>3.01 Dry Chemical Powder Potassium bi-carbonate (min 90 % of total composition of the chemicals) based ISI marked Dry Chemical Powder confirming to IS: 4308 (latest revision).</p> <p>4.00 Propellants</p> <p>4.01 Expellant Gas Dry Nitrogen gas as per IS 15683(latest revision)</p> <p>5.00 Dimensions</p> <p>5.01 Diameter of body 175 ± 10 mm</p> <p>5.02 Overall Height Less than 650 mm</p> <p>6.00 General Operating</p> <p>6.01 Operating Temperature 0 deg C to +55 deg</p> <p>7.00 Painting/Marking</p> <p>7.01 Anticorrosive Treatment Phosphating by hot dipping process to thickness not less than 0.012 mm both Internally & externally.</p> <p>7.02 Painting Epoxy polyester powder coating of minimum 50 micron thickness to all metallic external parts.</p> <p>7.03 Fluorescent Tape Two bands of yellow coloured fluorescent adhesive tape of minimum 20 mm Width on the body.</p> <p>7.04 Marking Coloured Oil India Limited Logo along-with Name of the Company (Minimum 40 mm size) shall be printed on the extinguisher body. All other markings as per IS:15683</p> <p>7.05 Finish Post Office red as per Shade 538 of IS:5</p> <p>8.00 Drawing & Quality Assurance Plan(QAP)</p> <p>8.01 Drawing Vendor shall submit detailed drawing along with material of construction & obtain approval of OIL before start of fabrication.</p>		

Tender No. & Date : KID1985L17/04 03.08.2016

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>8.02 QAP Vendor shall submit detailed Quality Assurance Plan & obtain approval of OIL before start of fabrication.</p> <p>Note :</p> <p>1) Extinguisher shall be confirming to IS: 15683 latest revisions as on bid due date.</p> <p>2) Data Sheet contains only specific requirements for the items mentioned in data sheet.</p> <p>3) IS codes mentioned above shall be latest revision as on bid due date.</p>		

- Special Notes** :
- Following Spares shall be provided with supply of 300 Nos. Fire Extinguishers:-
 - Matching Pressure Gauge - 50 Nos.
 - Discharge Tube - 100 Nos.
 - Syphon Tube - 100 Nos.
 - PVC base cover - 100 Nos.
 - Complete Plunger Assembly - 50 Nos.
 - Refilling kit for refilling of Fire Extinguishers. - 02 Nos.
 - Operating Instruction Sticker - 100 Nos.
 - Following spares shall be provided with Each Fire extinguisher:-
 - O Ring -02 Nos.
 - Safety Pin - 01 No.
 - Fire extinguisher shell including dished ends shall have minimum 1.8 mm thickness.
 - Fire Extinguisher shall be fabricated out of sheet of minimum 2mm thickness.
 - Bidder's response to all NIT stipulations should clearly be defined. Bidder shall furnish specific details/specifications of all major components.
 - The Bidder must have valid BIS approval certificate of tendered 9.0 Kg. Capacity Portable DCP Fire Extinguisher (stored Pressure Type). Credentials to this effect shall be submitted along with the bid for evaluation.
 - Inspection will be carried out by OIL Engineer at supplier's work in presence of third party before dispatch of the material.
 - After complete supply of the Fire Extinguishers, the Successful Bidder shall provide two days training on operation, maintenance & Re-filling of Fire Extinguishers at M/s Oil India Ltd., Duliajan Assam without any additional charges. However, Dry Chemical Powder & Nitrogen Gas will be provided as free charge.
 - WARRANTY** : The bidders shall provide warranty for minimum 12 Months from the Date of Commissioning or 18 Months from the Date of Supply.
 - Guarantee / Warranty certificate for one year will be required along with the supply.
 - Validity of offer: 75 days from the date of tender opening. Offer with validity less than 75

days will be rejected.

12. PERFORMANCE GUARANTEE:

Performance Guarantee is applicable against this tender. 10% of the ordered value shall be given as performance guarantee in the form of bank guarantee and shall be valid for 90 days beyond applicable warranty / guarantee / defect liability period (if any). Bidders should undertake in their bid to submit Performance Security as stated above.

Tender No. : KID1985L17/04
Tender Date : 03.08.2016
Bid Closing On : 13.09.2016 at 14:00 hrs.(IST)
Bid Opening On : 13.09.2016 at 14:00 hrs.(IST)

Tender issued to following parties only:

S/no	V _Code	Vendor Name	City/Country
1	200390	KOOVERJI DEVSHI & CO. PVT.LTD.	NAVI MUMBAI
2	201113	GUNNEBO INDIA PVT. LTD.	KOLKATA
3	201214	ZENITH FIRE SERVICES (INDIA) PVT.LT	MUMBAI
4	203287	NITIN FIRE PROTECTION INDUSTRIES LT	MUMBAI
5	203423	VIJAY INDUSTRIES AND PROJECTS LIMIT	KOLKATA
6	203424	PETER AUTEKITS PVT. LTD.	MUMBAI
7	204603	VIJAY INDUSTRIES & PROJECTS LTD.	MUMBAI
8	209670	SUPREMEX EQUIPMENTS	MUMBAI
9	210120	UNICARE FIRE SAFETY (I) PVT. LTD.	NOIDA
10	210121	KANADIA FYR FYTER PVT.LTD.	MUMBAI
11	210122	HINDUSTAN FIRE PROTECTION	MUMBAI
12	210242	MODI INTERNATIONAL	NEW DELHI
13	210243	VINTEX FIRE PROTECTION PRIVATE LIM	MUMBAI
14	210322	SRI TRIVENI CRAFTS	GURGAON
15	210731	SAFEX FIRE SERVICES LTD.	MUMBAI
16	211025	NAAZ ENGINEERING WORKS	MUMBAI
17	211026	CEASEFIRE INDUSTRIES LIMITED	NOIDA