

OIL INDIA LIMITED

(A Govt. Of India Enterprise) Tel :033 2230 1657, 1658
 4, India Exchange Place, Fax :91 33 2230 2596
 Kolkata-700001 E-mail :oilcalmn@oilindia.in

Tender No. & Date : KID8908L16/07 14.10.2015

Bid Security Amount : INR 0.00 OR USD 0.00
 (or equivalent Amount in any currency)

Bidding Type : Single Bid (Composite Bid)

Bid Closing On : 08.12.2015 at 14:00 hrs. (IST)
 Bid Opening On : 08.12.2015 at 14:00 hrs. (IST)

Performance Guarantee : Not Applicable

OIL INDIA LIMITED invites Limited tenders for items detailed below:

Item No./ Mat. Code	Material Description	Quantity	UOM
10 0C000180	<p><u>FLP WALL MOUNTED FAN</u></p> <p>Working voltage: Single phase, 230 V AC, 50 Hz Motor HP # 0.5 HP (Indicative) Fan should be certified to Ex-d, Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148) by CIMFR / other authorised testing laboratory Protection: IP 55 Earthing : One internal and two external points for body earthing. Sweep : 18" Material of construction: Cast Aluminum Alloy LM-6 or equivalent Terminals: Suitable terminals for hazardous area application. Cable glands: Should be fitted with required no of FLP Cable gland size 3/4": (for 4 core, 1.5 sq mm EPR cable) Weight: Max weight (21kg) (Indicative). Bidder should mention the gross weight of the fan with technical bid. Finish: Epoxy gray Mounting: Wall mounting with pivoted horizontal and vertical adjustment.</p> <p>Switch: Fan should be supplied with suitably rated individual FLP ON-OFF cum FAN REGULATOR switch. Should have facility to fix on wall separately. Ex-d Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148) Protection: IP 55 Earthing : One internal and two numbers for body earthing. Switch should be with FLP cable glands. *****</p>	12	NO
20 0C000406	<p><u>FLP PEDESTAL FAN</u></p> <p>Working voltage: Single phase, 230 V AC, 50 Hz Motor HP # 0.5 HP (Indicative) Fan should be certified to Ex-d Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148), by CIMFR / other authorised testing laboratory Protection: IP 55 Earthing : One internal and two external points for body earthing. Sweep : 18"</p>	8	NO

Tender No. & Date : KID8908L16/07 14.10.2015

Item No./ Mat. Code	Material Description	Quantity	UOM
	<p>Material of construction: Cast Aluminum Alloy LM-6 or equivalent Terminals: Suitable terminals for hazardous area application. Cable glands: Should be fitted with required no of FLP Cable gland size 3/4": (for 4 core, 1.5 sq mm EPR cable) Weight: Max weight (35kg) Bidder should mention the gross weight of the fan with technical bid. Finish: Epoxy gray Mounting: Pedestal with suitable height adjustment.</p> <p>Switch: Fan should be supplied with suitably rated individual FLP ON-OFF cum FAN REGULATOR switch. Switch should have facility to fix on pedestal separately. The switch/regulator should be certified to Ex-d Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148) Protection: IP 55 Earthing : One internal and two external points for body earthing. Switch should be with FLP cable glands. *****</p>		
30 OC000180	<p><u>FLP WALL MOUNTED FAN</u></p> <p>Working voltage: Single phase, 230 V AC, 50 Hz Motor HP # 0.5 HP (Indicative) Fan should be certified to Ex-d, Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148) by CIMFR / other authorised testing laboratory Protection: IP 55 Earthing : One internal and two external points for body earthing. Sweep : 18" Material of construction: Cast Aluminum Alloy LM-6 or equivalent Terminals: Suitable terminals for hazardous area application. Cable glands: Should be fitted with required no of FLP Cable gland size 3/4": (for 4 core, 1.5 sq mm EPR cable) Weight: Max weight (21kg) (Indicative). Bidder should mention the gross weight of the fan with technical bid. Finish: Epoxy gray Mounting: Wall mounting with pivoted horizontal and vertical adjustment.</p> <p>Switch: Fan should be supplied with suitably rated individual FLP ON-OFF cum FAN REGULATOR switch. Should have facility to fix on wall separately. Ex-d Gas Group IIA & IIB as per IS/IEC 60079-1 (Old IS 2148) Protection: IP 55 Earthing : One internal and two numbers for body earthing. Switch should be with FLP cable glands. ****</p>	18	NO

Special Notes : 1. Guarantee / Warranty certificate for one year will be required along with the supply.

2. Validity of offer: 75 days from the date of tender opening. Offer with validity less than 75 days will be rejected.

Note :

1. Detailed technical catalogue to be submitted along with the bid mentioning the MAKE & MODEL OFFERED for our technical scrutiny. Offer received without detailed technical catalogue/ literature will be liable for rejection.
2. FLP Pedestal fan and FLP Wall mounted fan should be supplied with individual FLP ON-OFF switch cum Fan Regulator.
3. The FLP equipments/items (Fan & Switch cum Regulator) must be CIMFR (or equivalent, authorised testing laboratory) certified. Copy of certificate must be enclosed along with the offer.
4. The equipments offered should be guaranteed for a minimum period of 6 months from the date of acceptance by the user department.
5. The items should be delivered at Materials Department, Oil India Ltd., Duliajan, Assam.
6. Items must be procured from Original Equipment Manufacturer (OEM) or from their authorized dealers only. In case OEM , the bidder should have established office in India in respect of supply and after Sales Service support from India.
7. In case bidder is not OEM of the offered product, a valid dealership certificate from OEM should be enclosed along with the offer. Offer without valid dealership certificate will not be considered for evaluation.
8. Items must be supplied with all required accessories.
9. Packing should be adequate to avoid any transit damage.
10. Wherever indicative is mentioned in the items specifications, 15% to 20 % allowance is acceptable.

Make & model:

For FLP Wall mounted Fan :

FCG Type no EF 1002, GA DRG No. GA A3 088B/11 REV.1(18.05.03) or equivalent

For FLP Switch cum Regulator: FCG Type no IJ61107, GA DRG No. G3 582/W/Q1640, REV.0(03.12.03) or equivalent

For FLP pedestal fan:

FCG Type no EF 1002, GA DRG No. GA A3 088C/11 REV.1(18.05.03) or equivalent

For FLP Switch cum Regulator: FCG Type no IJ61107, GA DRG No. G3 582/W/Q1640, REV.0(03.12.03) or equivalent

Tender No. : KID8908L16/07
Tender Date : 14.10.2015
Bid Closing On : 08.12.2015 at 14:00 hrs.(IST)
Bid Opening On : 08.12.2015 at 14:00 hrs.(IST)

Tender issued to following parties only:

Slno	V_Code	Vendor Name	City/Country
1	200313	FCG FLAMEPROOF CONTROL GEARS PVT.LT	MUMBAI
2	200573	BALIGA LIGHTING EQUIPMENT PVT. LTD.	CHENNAI
3	201116	SUNIL & CO.	KOLKATA
4	202938	FCG FLAMEPROOF CONTROL GEARS PVT.LT	KOLKATA
5	203062	GLOCON	TINSUKIA
6	203577	ARADHANA AGENCY	GUWAHATI
7	203655	SUDHIR SWITCHGEARS PVT. LTD.	MUMBAI
8	203718	SAFEX FLAMEPROOF CONTROLS PVT. LTD.	DHANBAD
9	204070	FLEXPRO ELECTRICALS PVT. LTD.	NAVSARI
10	206823	FLAMEPROOF EQUIPMENTS PVT.LTD.	MUMBAI
11	212267	TRIMITI ELECTRICALS	DOMVIVILI(E)

NOTICE

Tender No: KID8908L16/07 Dated: 14.10.2015

Other than the vendors to whom the enquiry has been issued, interested vendors who wish to participate in the tender may apply with proper credentials and other relevant details so as to reach Head-Calcutta Branch, Oil India Limited , ICC Building, 4th Floor, 4 India Exchange Place, Kolkata - 700001, West Bengal (E-mail: oilcalmn@oilindia.in , Fax : 033-22302596) **within 10 days of publication of the tender in OIL's website.**

The vendors must fulfill the following conditions:

- i) The party should have **three year's experience as on bid closing date** for the same item.
- ii) The party should have received **one order for at least 50% quantity in last three years (as on Bid Closing Date) for the item from any reputed firm.**
- iii) Annual turnover of the firm in any of the **last three financial years or current financial year** should be more than **Rs 9.06 lakhs.**

NOTE: i) Relevant documents in support of experience, last order and annual turnover must be submitted along with the application.

- ii) Application without complete supporting document will not be considered.
