

PO: Udayan Vihar

Guwahati – 781171, Assam (India) Phone: +91-361-2595682

Email: balen_bharali@oilindia.in erp_mm@oilindia.in



AMENDMENT NO. 1 DATED 16.03.2020 To Tender No. SGI4038P20

This Amendment no. 1 dated 16.03.2020 to tender no. SGI4038P20 issued to amend the technical specification of the item 10 as under:

"CPVC PIPE 75 mm or 3 Inch as per standard IS:15778 or ASTM D 2846 as per schedule 40 minimum wall thickness 5.5 mm maximum working pressure at 27 DEG 18 KG/CM2 and at 82 DEG 4 KG/CM2"

All other specification, terms and conditions of the tender remain unchanged.

Sd/-

(B Bharali)

CHIEF MANAGER MATERIALS (PL) FOR GENERAL MANAGER - MATERIALS (PL) FOR EXECUTIVE DIRECTOR (PLS)