

OIL INDIA LIMITED
(A Govt. of India Enterprise)
4 India Exchange Place, ICC Building, 4th Floor
Kolkata-700001
West Bengal
Phone (O) 033-22301657/58
FAX: 91-33-22302596
Email: oilcalmn@oilindia.in

AMENDMENT NO 01 DTD 02.12.2015

TENDER NO: SKI 9106P16 dtd 29.10.2015

DESCRIPTION: “SUPPLY, INSTALLATION AND COMMISSIONING OF SPARES OF 2 NOS. OF COOLING TOWER”

1.0 PLEASE READ CLAUSE NO. 2 OF NOTES ON NIT (in Doc 2 , Annexure IA, PAGE NO. 11) OF TENDER DOCUMENT NO. **SKI 9106P16 dtd 29.10.2015** AS MENTIONED BELOW IN PLACE OF THE EXISTING:-

***Clause no. 2.** Timber components has to be Douglas fir timber of grade 2 which should meet the strength as per IS:883 of the cooling tower.*

2.0 Also read “**FRP Casing & Louver - 100 %**” in place of existing “FRP Casing & Louver - 30 %” under Materials required for CT MODEL 457-202 Sl. 80-2-0211 (in Doc 2 , Annexure IA, PAGE NO page no. 10) .

3.0 However all other terms and conditions of the Tender remain same