

PO: Udayan Vihar

Guwahati – 781171, Assam (India) Phone: +91-361-2595682





## AMENDMENT NO. 2 DATED 28.10.2020 TO TENDER NO. SGI5407P21

This amendment is issued to incorporate the following additional clauses/specification in the technical Specification of **Annexure-AA** of the tender no. <u>SGI5407P21</u>:

- i. FRLS properties required for both the outer and inner sheath of the instrument and control cables. Valid Test certificates to be provided by the bidders along with supply of materials.
- ii. For instrument and control cables Word "FRLS" Shall be marked on outer sheath of cable. In addition, sequential length marking shall be printed on outer sheath of cable at every one-meter interval".
- iii. In case of following: -

2 pair instrument cable the overall diameter = (21±2.00) mm 6 pair instrument cable the overall diameter = (26±2.00) mm

- iv. Tolerance of upto 5% is acceptable for maximum overall diameter of instrument and control cables.
- v. Tolerance of upto 2 % is acceptable for maximum conductor resistance for control and instrument cables.
- vi. In case of any doubt, dispute, confusion, variance and overlapping of any technical specification, clauses and provisions of various codes including IS codes mentioned in the technical specification will prevail.
- vii. Any minor deviation of technical specs which may not affect the quality and performance of the cable along with no major violations of IS codes may be acceptable. However, the owner reserves the right to accept / reject the items as per technical specification of the tender.
- viii. All the standard test and compliance certificates to have traceability to NABL accredited laboratory. Documentary evidence to be provided by the bidders for the same
- ix. The above points are inclusive of the technical checklist and specification.
- 2. All others terms and conditions of the Bid Document remain unchanged.

Sd/-

(B Bharali)

CHIEF MANAGER MATERIALS (PL)
FOR GENERAL MANAGER - MATERIALS (PL)
FOR EXECUTIVE DIRECTOR (PLS)