

OIL INDIA LIMITED
(A Government of India Enterprise)
2-A, District Shopping Centre,
Saraswati Nagar, Basni
Jodhpur, Rajasthan

CORRIGENDUM

Addendum No. 3 Dated 28.07.2015

to

Tender No. SJI7546P16

AA. This Addendum No. 3 dated 28.07.2015 to **Tender No. SJI7546P16 for Fabrication and Supply of skid mounted 37.37 kls capacity rectangular crude oil storage tank**, is issued to amend Material Description (Technical Specification) under **Annexure -IA of the tender document to be read in place of existing** as under:

“37.37 kls capacity, 7500 mm x 2500 mm x 2150 mm rectangular crude oil storage tank out of 6 mm thick IS: 226 ms plates with roof suitably skid mounted with all welded on structure and complete with manholes, ladder and other accessories as per details shown in drawing no.OIL/2984/C. The tanks shall be ADDITIONALLY equipped with the followings:

1. The clean out door shall be fitted in an extended neck frame of minimum 2" height, using 50 x 50 x 6 mm ms angle plates welded to the tank wall, such that all bolts to the cover can be accessed from outside.

2. Both 4" inlet & 6" outlet of the tank shall be extended to 12" by suitably supported spacer spools from tank wall and the openings shall be of flanged end connection (as per ANSI B16.5).

3. A 4" NB coupling with plug shall be provided at the center of the middle cover (tank top) to facilitate riser attachment / flame arrestor.

4. A dip hatch of 3" dia with suitable opening / closing facility shall be provided at the center of the rectangular manhole cover (tank top), nearest to the 6" delivery connection of the tank. An additional ms plate of size 8" x 8" x 6 mm shall be welded to the tank bottom plate, where the dip bob will hit during dipping.

5. A 1 foot (approximately) x 6" size long bend shall be THREADED to the inside end of the suction flange (the end shall be positioned downward), so that the dead volume level can be lowered by another 4".

6. The tanks shall be complete with API 600 x 150 class gate valves with companion flanges and stud & bolts for inlet and outlet of the tanks. The valves shall be supplied from any one of the following make:
M/S AIL, M/S L&T, M/S L'ACIER industries & M/S KSB pumps ltd.

7. The bidder shall provide product catalogue, cross sectional drawing with material specifications of API 600 valve from the concerned manufacturer along with the offer.”

BB. All other terms and conditions of the tender remain unchanged.

Yours faithfully

OIL INDIA LIMITED

(Krishna Mohan Kumar)
Dy. Materials Manager
For Chief Manager (M&C)
For Head Services
FOR Executive Director (RP)
