

**OIL INDIA LIMITED**  
(A Government of India Enterprise)  
P.O. Duliajan, Pin – 786602  
Dist-Dibrugarh, Assam

**CORRIGENDUM No-2 dated 25.04.2016 to IFB No: CDI8533P16**

This Corrigendum no-1 dated 25.04.2016 to IFB No: CDI8533P16 for 'Replacement of electrical wiring with new surface type wiring , fixing of new MCCB, DB, electrical fixtures/fittings, lamps , fans in occupied Bungalows of Oil India Limited, at Duliajan and Moran, Assam' is issued to notify the following:

- i) Bid Closing Date & Time : Extended up to 10.05.2016 [11.00 Hrs(IST)]
- ii) Bid Opening Date & Time : Extended up to 10.05.2016 [14.00 Hrs (IST)]
- iii) Changes against the clauses as attached vide Annexure-AA

All other Terms and Conditions of the Bid Document remain unchanged. Details also can be viewed in the e-portal and [www.oil-india.com](http://www.oil-india.com).

**Sd/  
DGM-CONTRACTS  
FOR RESIDENT CHIEF EXECUTIVE**

**ANNEXURE-AA:**

<b>Sl. No</b>	<b>Clause in tender</b>	<b>Amended Clause</b>
1	<b>SCC - 6.2.9 Repairing and painting</b> of the portion of the wall damaged during dismantling and rewiring/refixing of electrical items.	<b>Repairing</b> of the portion of the wall damaged during dismantling and rewiring/refixing of electrical items.
2	<b>SCC 9.1:</b> All works shall be measured in metric system and payment shall be made based on actual work done.	All works shall be measured in metric system and payment shall be made <b>monthly based</b> on actual work done.
3	<b>SCC - 14.5.2</b> The contractor shall first start the wiring job in a particular B'low on a sample basis and complete the jobs as per the OIL's instructions. The contractor has to start the wiring jobs in the next similar type of B'low only after obtaining the design, layout and wiring jobs approved from OIL.	The contractor shall first start the wiring job in a particular <b>B'low of each type</b> , on a sample basis and complete the jobs as per the OIL's instructions. The contractor has to start the wiring jobs in the other similar type of B'low only after obtaining the design, layout and wiring jobs approved by OIL.
4	<b>Item No-180 of SOQ:</b> S/F 25 A RCBO Metal Plug Socket: Supply and fixing of Surface type 25A metallic plug/socket DB complete with 25A Plug and Socket and 25 A DP RCBO, 100mA sensitivity for AC. Make: Schneider/Legrand/Siemens/Indo Asian or approved by OIL	S/F 25 A RCBO with Metal Plug Socket: Supply and fixing of Surface type 20A metallic plug/socket DB complete with 20A Plug, Socket and 25 A DP, 100mA sensitivity RCBO for AC. Make: Schneider/Legrand/Siemens /Indo Asian or approved by OIL. RCBO model similar to Legrand cat no. <b>4113 32. Plug &amp; Socket DB model similar to Legrand cat no. 6078 60</b>
5	<b>Item No- 270 of SOQ</b> S/F of Junction Box for MCB DB: Supply and fixing PVC box of <b>250 mm X 300 mm X 60 mm deep</b> (nominal size) on surface. This PVC box will be used as a junction box for MCB DB. Make: Presto Plast/AKG /Richa or approved by OIL	S/F of Junction Box for MCB DB: Supply and fixing PVC box of <b>200 mm X 250 mm X 48 mm</b> deep (nominal size) on surface. This PVC box will be used as a junction box for MCB DB. Make: Presto Plast/AKG /Richa or <b>any ISI marked &amp; approved by OIL</b>
6	<b>GCC 20. Special Conditions</b> a) The amount of retention money shall be released after 6(six) months from the date of issue of completion certificate from concerned department.	<b>GCC 20. Special Conditions</b> (a) The amount of retention money shall be released after issue of completion certificate from concerned department on expiry of the 1(One) year warranty period of the Electrical items.