

OIL INDIA LIMITED
(A Government of India Enterprise)
P.O. Duliajan-786602, Assam, India
E-mail: material@oilindia.in

INVITATION FOR BID
LOCAL COMPETITIVE BID

OIL INDIA LIMITED invites Local Competitive Bid (LCB) through its e-procurement portal <https://etender.srm.oilindia.in/irj/portal> for the following items:

Tender No	Bid Closing/ Opening Date	Item & Qty
SSI7718P16 DT: 30.06.2015	20.08.2015	PRE-GELATINIZED STARCH-150MT
SSI7723P16 DT: 30.06.2015	20.08.2015	ETHYLENE GLYCOL MONOBUTYLE ETHER- 10 MT
SSI7739P16 DT. 01.07.2015	20.08.2015	PAINTS
SDI7741P16 DT. 01.07.2015	06.08.2015	OIL DIARY-2016
SDI7733P16 DT. 30.06.2015	06.08.2015	OIL CALENDER-2016
SDI7701P16 DT.30.06.2015	20.08.2015	SPLIT A/C
SDI7743P16 DT:01.07.2015	20.08.2015	06 NOS HIGH MAST
SDI7757P16 DT:03.07.2015	20.08.2015	SOLAR GENERATING SET – 07 NOS
SSI7738P16 DT:01.07.2015	20.08.2015	TELEPHONE CABLE
SDI7774P16 DT:04.07.2015	20.08.2015	TRUCKS FOR MOBILE STEAM GENERATOR – 03 NOS
SDI7742P16 DT:01.07.2015	20.08.2015	PACKAGED A/C – 15 NOS

Tender fee (Non-refundable): Rs 1,000.00; Bid Closing/Opening Time: (11 Hrs.) IST/(14 Hrs.) IST; Last date for submission of application for Issue of User ID and password- **one week prior to bid closing date**. The complete bid documents and details for purchasing bid documents, participation in E-tenders are available on OIL's e-procurement portal <https://etender.srm.oilindia.in/irj/portal> as well as OIL's website www.oil-india.com.

NOTE: All addenda, Corrigenda, time extension etc. to the tenders will be hosted on above website and e- portal only and no separate notification shall be issued in the press. Bidders should regularly visit above website and e-portal to keep themselves updated.



OIL INDIA LIMITED
(A Government of India Enterprises)
PO : Duliajan – 786602
Assam (India)

TELEPHONE NO: (91-374) 2808719

FAX NO: (91-374) 2800533

Email: ranjan_barman@oilindia.in ; erp_mm@oilindia.in

FORWARDING LETTER

Tender No. : SDI7743P16 DT: 01.07.2015

Tender Fee : Rs 1,000.00

Bid Security Amount : Rs 48,000.00

Bidding Type : SINGLE STAGE COMPOSITE BID SYSTEM

Bid Closing on : As mentioned in the e-portal

Bid Opening on : -do-

Performance Security : Applicable

Integrity Pact : Not Applicable

OIL invites Bids for **Supply, Installation and commissioning for 30M HIGH MAST – 06 NOS AT MORAN OIL** through its e-Procurement site under **SINGLE STAGE COMPOSITE BID SYSTEM**. The bidding documents and other terms and conditions are available at Booklet No. MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders. The prescribed Bid Forms for submission of bids are available in the Technical RFx -> External Area -> Tender Documents

The general details of tender can be viewed by opening the RFx [Tender] under RFx and Auctions.. The details of items tendered can be **found in the Item Data and details uploaded under Technical RFX**.

The tender will be governed by:

- a) “General Terms & Conditions” for e-Procurement as per Booklet No. MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders.
- b) Technical specifications and Quantity as per **Annexure – 1A**.
- c) The prescribed Bid Forms for submission of bids are available in the Technical RFx -> External Area -> Tender Documents.
- d) In the event of receipt of only a single offer against the tender within B.C. date, OIL reserves the right to extend the B.C. date as deemed fit by the Company. During the extended period, the bidders who have already submitted the bids on or before the original B.C. date, shall not be permitted to revise their quotation.
- e) All corrigenda, addenda, amendments, time extension, clarifications etc. To the tender will be hoisted on OIL’s website (www.oil-india.com) and in the e-portal (<https://etenders.srm.oilindia.in/irj/portal>) only and no separate notification shall be issued

in the press. Prospective bidders are requested to regularly visit the website and e-portal to keep themselves updated.

- f) Any sum of money due and payable to the contractor (including Security Deposit refundable to them) under this or any other contract may be appropriated by Oil India Limited and set-off against any claim of Oil India Limited (or such other person or persons contracting through Oil India Limited) for payment of sum of money arising out of this contract or under any other contract made by the contractor with Oil India Limited (or such other person or persons contracting through Oil India Limited).
- g) Bidder are advised to fill up the Technical bid check list (**Annexure EEE**) and Response sheet (**Annexure FFF**) given in MS excel format in Technical RFx -> External Area - > Tender Documents. The above filled up document to be uploaded in the **Technical RFX** Response.

Special Note:

1.0 General Qualification Criteria:

In addition to the general BRC/BEC, following criteria on Bidders' Experience and their financial capabilities shall be considered (**Documentary evidence to be provided along with the bid in Technical RFx -> External Area - > Tender Documents**) as on the Bid Closing Date:

Criteria	Complied / Not Complied. Documentary evidence submitted / not submitted
a) Bidder should have experience of successfully executing similar single order of Rs 14.40 Lakhs during last 3 years.	
b) Annual financial turnover of the firm in any of the last 3 financial years or current financial year should not be less than Rs 48.00 Lakhs.	

Note: Documentary evidence in respect of the above should be submitted in the form of copies of relevant Purchase Orders along with copies of any of the documents in respect of satisfactory execution of each of those Purchase Orders, such as – (i) Satisfactory Inspection Report (OR) (ii) Satisfactory Supply Completion / Installation Report (OR) (iii) Consignee Received Delivery Challans (OR) (iv) Central Excise Gate Pass / Tax , Invoices issued under relevant rules of Central Excise / VAT (OR) (v) any other documentary evidence that can substantiate the satisfactory execution of each of the purchase orders cited above. For Annual financial turnover enclose the audited Annual Reports or balance sheet certified by a chartered accountant.

2.0 Application showing full address/email address with Tender Fee (Non-refundable) of Rs. 1,000.00 in favour of M/s Oil India Limited and payable at Duliajan is to be sent to Head-Materials, Oil India Limited, P.O. Duliajan, Assam-786602. Application shall be accepted only upto one week prior to Bid Closing date (or as amended in e-portal). The envelope containing the application for participation should clearly indicate “REQUEST FOR ISSUE OF USER ID AND PASSWORD FOR E TENDER NO ...” for easy identification and timely issue of user ID and password. On receipt of requisite tender fee, USER_ID and initial PASSWORD will be communicated to the bidder (through e-mail) and will be allowed to participate in the tender through OIL’s e- Procurement portal. No physical tender documents will be provided. Details

of NIT can be viewed using “Guest Login” provided in the e-Procurement portal. The link to e-Procurement portal has been also provided through OIL’s web site www.oil-india.com.

NOTE:

a) Tender Fee may also be paid online upto one week prior to the bid closing date (or as amended in e-portal).

b) PSUs and SSI units are provided tender documents Free of Cost (as per govt guidelines), however they have to apply to OIL's designated office to issue the tender documents before the last date of sale of tender document mentioned in the tender.

3.0 Please note that all tender forms and supporting documents are to be submitted through OIL’s e-Procurement site only except following documents which are to be submitted manually in sealed envelope super scribed with **Tender no.** and **Due date** to **Head Materials, Materials Department, Oil India Limited, Duliajan - 786602, Assam** on or before the Bid Closing Date and Time mentioned in the Tender.

a) **Original Bid Security**

b) **Detailed Catalogue (if any)**

c) **Any other document required to be submitted in original as per tender requirement**

All documents submitted in physical form should be signed on all pages by the authorised signatory of the bidder and to be submitted in triplicate.

4.0 Benefits to Micro & Small Enterprises (MSEs) as per prevailing Govt guidelines as applicable on B.C date shall be given. MSEs who are interested in availing the benefits will upload with their offer proof of their being MSE registered for the item tendered. The MSE are also required to upload scanned copies of relevant documents indicating details of registration alongwith validity, name of the registering organization and details of the item, ownership etc., failing which, their offer may not be liable for consideration of benefits to MSEs.

5.0 Bidders are requested to examine all instructions, forms, terms and specifications in the bid. Failure to furnish all information required as per the NIT or submission of offers not substantially responsive to the bid in every respect will be at the bidders risk and may result in rejection of its offer without seeking any clarifications.

6.0 Bidders must ensure that their bid is uploaded in the system before the tender closing date and time. Also, they must ensure that above documents which are to be submitted in a sealed envelope are also submitted at the above mentioned address before the bid closing date and time failing which the offer shall be rejected.

7.0 Bid must be submitted electronically only through OIL’s e-procurement portal. Bid submitted in any other form will be rejected.

s

8.0 The tender shall be governed by the Bid Rejection & Bid Evaluation Criteria given in enclosed **Annexure-CCC. However, if any of the **Clauses of the Bid Rejection Criteria / Bid Evaluation Criteria (as per Annexure-CCC)** contradict the **Clauses of the tender and / or “General Terms & Conditions” as per Booklet No. MM/LOCAL/E-01/2005 for E-procurement (LCB Tenders) elsewhere, those in the BEC / BRC shall prevail.****

9.0 To ascertain the substantial responsiveness of the bid OIL reserves the right to ask the bidder for clarification in respect of clauses covered under BRC also and such clarifications

fulfilling the BRC clauses in toto must be received on or before the deadline given by the company, failing which the offer will be summarily rejected.

10.0 Please do refer the User Manual provided on the portal on the procedure How to create Response for submitting offer.

NOTE:

Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.

Yours Faithfully

Sd-

(R BARMAN)

**SR. MANAGER MATERIALS (IP)
FOR HEAD-MATERIALS**

Tender No & Date: SDI7743P16 DT:01.07.2015**BID REJECTION CRITERIA (BRC) / BID EVALUATION CRITERIA (BEC)**

The following BRC/BEC will govern the evaluation of the bids received against this tender. Bids that do not comply with stipulated BRC/BEC in full will be treated as non responsive and such bids shall prima-facie be rejected. Bid evaluation will be done only for those bids that pass through the “Bid Rejection Criteria” as stipulated in this document.

Other terms and conditions of the enquiry shall be as per General Terms and Conditions vide MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders. However, if any of the Clauses of the Bid Rejection Criteria / Bid Evaluation Criteria (BRC / BEC) contradict the Clauses of the tender or MM/LOCAL/E-01/2005 elsewhere, those in the BRC / BEC shall prevail.

<u>Criteria</u>	Complied / Not Complied. (Remarks if any)
<p>1.0 BID REJECTION CRITERIA (BRC):</p> <p>A) TECHNICAL:</p> <p>The bid shall conform generally to the terms and conditions given in this document. Notwithstanding the general conformity of the bids to the stipulated specifications, the following requirements will have to be particularly met by the Bidders without which the same will be considered as non-responsive and rejected.</p> <p>B) COMMERCIAL:</p> <p>i). Validity of the bid shall be minimum 120 days from the Bid Closing Date.</p> <p>ii). Bid security: The bid must be accompanied by Bid Security of Rs 48,000.00 in OIL's prescribed format as Bank Guarantee or a Bank Draft/Cashier cheque in favour of OIL. The Bid Security may be submitted manually in sealed envelope superscribed with Tender no. and Bid Closing date to Head Materials, Materials Department, Oil India Limited, Duliajan- 786602, Assam on or before the Bid Closing Date and Time mentioned in the Tender. The Bank Guarantee towards Bid Security shall be valid for 10 months from Bid closing date. (i.e. upto 20.06.2016).</p> <p>Bid Security may also be paid online on or before the Bid Closing Date and Time mentioned in the Tender.</p> <p><u>If bid security in ORIGINAL of above mentioned Amount and Validity is not received or paid online within bid closing date and time, the bid submitted through electronic form will be rejected</u></p>	

without any further consideration.

For exemption for submission of Bid Security, please refer Clause No. 8.8 of General Terms and Conditions vide MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders.

The format of Bank Guarantee towards Bid Security (Annexure – VII) has been amended to Annexure – VII (Revised) and bidders should submit Bank Guarantee towards Bid Security as per Annexure – VII (Revised) only.

In case of extension of Bid Closing date against the tender where a bidder has already submitted his bid with requisite bid security validity within the original B.C. Date, such bidders will extend validity of bid security covering the extended period of the bid closing date.

iii). Performance Security:

Successful bidder will be required to furnish a Performance Security @10% of the order value. For exemption for submission of Performance Security, please refer Clause No. 9.12 of General Terms and Conditions vide MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders. **The Performance Security must be valid for 12 months from the date of commissioning or 18 months from the date of despatch whichever concludes earlier. Bidder must confirm the same in their bid. Offers not complying with this clause will be rejected.**

The validity requirement of Performance Security is assuming despatch within stipulated delivery period and confirmation to all terms and conditions of order. In case of any delay in despatch or non-confirmation to all terms and conditions of order, validity of the Performance Security is to be extended suitably as advised by OIL.

For exemption for submission of Performance Security, please refer Clause No. 9.12 of General Terms and Conditions vide MM/LOCAL/E-01/2005 for E-Procurement LCB Tenders.

iv). *The Bank Guarantee should be allowed to be encashed at all branches within India.*

v). The prices offered will have to be firm through delivery and not subject to variation on any account. A bid submitted with an adjustable price will be treated as non-responsive and rejected.

vi). Bids received after the bid closing date and time will be rejected. Similarly, modifications to bids received after the bid closing date & time will not be considered.

vii). All the Bids must be Digitally Signed using “Class 3” digital certificate with Organisation’s name (*e-commerce application*) as per Indian IT Act

<p>obtained from the licensed Certifying Authorities operating under the Root Certifying Authority of India (RCAI), Controller of Certifying Authorities (CCA) of India. The bid signed using other than “Class 3 with Organisation’s Name” digital certificate, will be rejected.</p> <p>viii). Price should be maintained in the “online price schedule” only. The price submitted other than the “online price schedule” shall not be considered.</p> <p>2.0 <u>BID EVALUATION CRITERIA (BEC)</u></p> <p>The bids conforming to the terms and conditions stipulated in the tender and considered to be responsive after subjecting to the Bid Rejection Criteria as well as verification of original of any or all documents/ documentary evidences pertaining to BRC, will be considered for further evaluation as per the Bid Evaluation Criteria given below.</p> <p>A) TECHNICAL:</p> <p>1. The manufactured product should be strictly as per OIL’s tender specification.</p> <p>B) COMMERCIAL:</p> <p>i). To evaluate the inter-se-ranking of the offers, Assam Entry Tax on purchase value will be loaded as per prevailing Govt. of Assam guidelines as applicable on bid closing date. Bidders may check this with the appropriate authority while submitting their offer.</p> <p>ii). To ascertain the substantial responsiveness of the bid OIL reserves the right to ask the bidder for clarification in respect of clauses covered under BRC also and such clarifications fulfilling the BRC clauses in toto must be received on or before the deadline given by the company, failing which the offer will be summarily rejected.</p>	
--	--

NOTE:

Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.

-----XXXX-----

TECHNICAL SPECIFICATIONS WITH QUANTITY

Tender No & Date: SDI7743P16 DT:01.07.2015

	Complied / Not Complied. (Remarks if any)
<p><u>ITEM NO. 10</u></p> <p><u>Supply, erection, testing & commissioning of 30 Meters tall High mast Lighting system with 12nos. of 2x400 watt SON fittings with Non integral control gear box- QTY= 6 NOS.</u></p> <p><u>ALL THE ITEMS TO BE INSTALLED AT OIL MORAN</u></p> <p>Details of specifications are given below:</p> <p>TECHNICAL SPECIFICATIONS OF 30 MTRS HIGH MAST LIGHTING SYSTEM</p> <p>1.0 MAST:</p> <p>1.1 The high mast shall be continuously tapered, polygonal cross section and 30 meters high above base plate. The mast shall be fabricated from steel plate welded construction in suitable number of sections (not less than 3), telescopically jointed giving a continuous tapered profile and presenting good visual appearances.</p> <p>1.2 Mast sections material shall conform to IS 2062.</p> <p>1.3 The mast sections are hot dipped galvanized both inside and outside conforming to IS: 4759-1984, IS: 2629-1985, IS: 2633-1072. Galvanisation thickness shall be of minimum 80 micron.</p> <p>1.4 Mast structure shall be designed to withstand wind velocity of 180km/hr. with 3 sec. gust conforming IS: 875 part VIII - 1987 and should have wind load factor 1.25 and material factor 1.15.</p> <p>1.5 The base flange shall be provided with gusset and high tensile anchor bolts.</p> <p>1.6 The bottom most section shall accommodate winch electric drive, cable, plug/socket etc. with a proper door opening in order to permit clear access to the above components. The door shall be dust proof; vermin proof and weather protected (IP 55) and shall be provided with suitable locking arrangement.</p> <p>1.7 Mast shall be provided with lightning protection.</p> <p>1.8 Provisions for suitable Earthing shall be provided.</p> <p>1.9 The mast shaft shall be made with best steel in compliance with BS EN 10025 FE 510 having the guaranteed characteristics.</p>	

- a. Minimum yield strength = 335 N/Sq. mm for thickness < 30mm.
- b. Tensile strength ranging from 340 to 470 N/sq. mm.
- c. Minimum elongation for thickness between 3 mm and 30 mm.
- d. All holding bolts are hot dip galvanized to BS 729.

2.0 LANTERN CARRIAGE

2.1 The lantern carriage shall be of steel tubular ring type construction designed to accommodate 12 Nos. of HPSV flood light luminaries with necessary C.G. Box in and radically symmetrical fashion.

2.2. The complete lantern carriage assembly shall be hot dip galvanized after fabrication.

2.3 The carriage shall have proper arrangement to avoid swing and to prevent damage to mast surface or other installed parts during lowering/raising operation of carriage.

2.4. All hardware used shall have necessary corrosion protection.

2.5 Lantern Carriage/Accessories shall be made with best steel in compliance with BS EN 10025 FE 430 A having the following guaranteed characteristics.

- a. Minimum yield strength 225 to 250 N/Sq. mm for thickness < 30mm
- b. Tensile strength ranging from 340 to 470 N/Sq. mm.
- c. Minimum elongation 23 to 26%.

2.6 Galvanization as per IS 4759, minimum thickness of galvanization 80 micron.

3.0 WINCH ASSEMBLY:

3.1 Winch assembly, meant for hoisting of lantern carriage shall be fixed in the base of the mast and shall have provision to operate both manually and electrically. The double drum winch should be suitably designed to handle the total weight of lantern carriage assembly with all fittings and accessories with required factor of safety.

3.2 The winch shall be of self sustaining and self lubricating type with positive locking arrangement. The rope drum is fabricated as per IS-807 and the wire rope is wound/unwound on double drum winch during movement of lantern carriage.

3.3 Particular care shall be exercised in all aspects of design, manufacture, and testing and installation arrangement of the system to ensure optimum safety under all operating condition to give a minimum 25 years of operating life.

3.4 Test certificates shall be provided with each winch stating clearly the capacity, speed and recommended lubricant.

3.5 The material of construction for top pulley block shall be non corrosive and preferably made of die cast LM-6 aluminum /brass alloy with self lubricating bearing.

3.6 The design shall ensure that the operation of pulley is maintenance free Pulley should be provided with weather proof cover.

4.0 WIRE ROPE:

4.1. The wire ropes are flexible marine grade and non corrosive stainless steel.

4.2. A minimum 8 turn of wire ropes shall be on the drum when the lantern carriage is fully lowered.

4.3. The stainless steel wire is of minimum 6mm diameter, 7x19 constructions which shall have a factor of safety not less than 5 times the safe working load (SFL) of winch.

5.0 WINCH DRIVING POWER TOOL:

5.1 The winch drive unit shall be squirrel cage reversible induction motor with following characteristic:

415V, 3 phase, 50 HZ

Class F insulation and temperature class limited to class B

Weather resistant

IP 55 Protections, Make- Crompton Greaves/ Kirloskar Ltd/ Siemens/ Bharat Bijlee

5.2. The capacity of the electric motor used in power tool shall be compatible to handle the design load of lantern carriage (Min 2.0 HP).

5.3 The power tool shall be housed at the base of the mast.

5.4 For safety reasons and final precision docking of lantern carriage ring, the power tool must have provision to operate manually by using external crank device without removing the drive motor from the winch unit.

6.0 CONTROL PANEL (FEEDER PILLAR BOX)

6.1. Feeder pillar box made of 14 SWG CRCA sheet metal, self supporting, floor mounted, dust, vermin and weather proof for outdoor use shall be supplied for locally/automatically switching' ON/OFF of luminaries. The enclosure protection shall be IP 55. The control panel comprises the following.

6.2. 63 Amps, TPN SFU with 63 A fuse as incomer with silver plated contacts.

Make: GE/Siemens/Schneider.

6.3. 32 Amps TPN fuse switch unit as isolator for motor starter(Fuse as per motor HP) .

Make: GE/Siemens/Schneider.

6.4 Earth leakage Relay with separate core balance current transformer

Sensitivity: 30 mA to 3A, Time delay: 0 - 5 sec, current and time setting adjustable in steps.

Make: Merlin Gerlin/ MDS Legrand

6.5. Triple pole power contactor AC 3 rating min 40A rating for long life for light control.

Make: Siemens/Telemmchanique/GEPC

Triple pole power contactor AC 3 rating min 16A rating for motor hoisting and lowering, Make: Siemens/Telemmchanique/GEPC

6.6. Digital Voltmeter & Ammeter, size-96mm X 96mm,

Range 0-600V, Current transformer with CT ratio-50/5 Make- Konzerv / AEI Ltd/L&T

LED- 3 nos for R,Y,B phase indication.

LED-2 Nos for a)Raising b)Lowering of the mast

6.7. Start/Stop push button for locally switching ON/OFF the luminaries - 1 set.

6.8. NS 4 type fuses carrier and base for control circuit.

6.9. Automatic lighting Switch with digital time switch of DIN rail mounting suitable for astronomical calculations of sun rise and sun set during summer/winter by setting date, time and positions of longitude and latitude, model-Astro Rex-D21 of Legrand, astro-time -switch, 230V AC, 50HZ, Make- MDS legrand/ Merlin Gerin

6.10.All power and control wiring shall be done with 1 core, 1100 V grade PVC insulated, IS marked ,flexible copper cable. Power cable size shall be as per IS 8623,control cable 2.5 Sqmm.

6.11. Brought out terminals of tinned copper shall be provided at incomer for terminating 4x25

Sqmm PVCA cable. All outgoing connections from 63 A TPN Switch shall be tapped through suitable rectangular copper bars.

6.12. Detachable gland plate and copper brought out terminals for incoming and outgoing cable connection

6.13. Feeder Pillar box to be cleaned with 7 tank anti rust treatment and then power coated on all sides with DA Paint. (Min thickness of paint 50 micron)

6.14. Push button for raising and lowering the mobile part shall operate on "Dead man principal" i.e. action shall cease as soon as the button is released.

6.15. Feeder Pillar should be located min. 5meters radial distance from high mast.

6.16. A single line diagram for Feeder Pillar shall be submitted along with the offer.

6.17. The height of foundation for panel shall be min. 450 mm from the ground level.

7.0 LUMINARIES:

7.1. 12 nos. of non-integral type, 2x400 W HPSV flood light luminaries with IP-65 protection similar to RVP 501 of Phillips Make with HPSV tubular lamps complete with external control gear box with all accessories. Cast Aluminium alloy control gear box shall be complete with VPI Electro Magnetic ballast, ignitor PF correction capacitor and individual HRC fuse and shall be as per IP 65.

Make of Luminaries shall be restricted to: PHILLIPS/CROMPTON/BAJAJ/GE

2Nos. 4 core, 6sqmm, copper conductor, flexible screen cable, 1100V grade, Make- Nicco/ Incab / Polycab /Finolex shall be used from lantern carriage to terminal block. Terminal block shall be covered to protect it from the entry of insects and dust particles.

8.0. EARTHING:

8.1. The mast shall be provided with lightning protection system comprising of an Earthing system per following specification:

50mmdia, 3 meters Long G.I Pipe with bricks enclosures of size 600mm X 600mm and RCC cover - 4Nos.

30mm X 6mm G.I straps for interconnection of stud at mast

2 nos.each electrodes for lightening arrester and 2Nos. earth electrodes for earthing system of high mast lighting system shall be provided.

9.0 TOOL BOX:

9.1 A tool box of sheet steel containing a set of general and special purpose tools is to be supplied along with high mast for maintenance job.

10.0. AVIATION OBSTRUCTION LIGHTS & LIGHTENING ARRESTER

10.1 Medium intensity LED aviation obstruction light similar to neon spiral type fitted in a weather- proof box on body unit of Aluminium alloy shall be supplied. The cover of the light will be glass with rubber gasket (IP65 protection). High Luminosity flashing red light emitting diodes having life of 11 years. Power consumption 10 to 15 Watts, 230V AC, 50HZ, 90 candela. LED#s are mounted on fire retardant epoxy printed circuit board in five series-parallel circuits.-1Set

Make- Binay Opto Electronics Pvt. Ltd./Bajaj Electricals Ltd/ Philips.

10.1 Lightning protection shall be provided on the top of the high mast.

10.2 Lightening arrester shall be connected rigidly to the foot of the mast.

11.0. FOUNDATION:

11.1 Foundation of high mast shall be designed for Zone V considering the Earth Quake resistance measure. Party shall have to design and furnish the details of foundation of High mast along with the offer for zone V.

11.2 The bearing capacity of the soil is 10 T/m²

12. GENERAL CONDITIONS:

12.1 Supply, erection, testing and commissioning, including civil foundation jobs, of high mast to be done by the party. The civil jobs of the foundation of the high mast shall be done by the party after approval of foundation drawing by OIL. All the materials for foundation shall be supplied by the party including metallic items like site bolts, anchor plate, steel template etc. Curing time and treatment for foundation shall be as directed by OIL before start of foundation work.

12.2 All necessary arrangements for erection of mast are to be made by the party including supply of all safety appliances and tools to workman.

12.3 Transportation of men and materials to the site will be party's responsibility and M/S. Oil India Limited will not provide any transport or transferring of man and materials to the site.

12.4 The persons who are authorized to carry out electrical works should have valid electrical supervising license and work permit as per I.E. Rules. Copy of the license to be submitted along with the offer.

12.5 For installation, testing and commissioning of mast, party should have valid electrical license valid for Assam. Copy of the license to be submitted along with the offer.

12.6 The party should submit detailed schedule of program of work within 15 days from the award of order.

12.7 The whole work should be completed within 3 to 4 month from the date of issue of order to the entire satisfaction of Engineer-in-charge of OIL.

12.8 The party will be responsible for their tools, tackle and materials and personnel at site till the towers are finally handed over to OIL.

12.9 The party will take all safety measures during the execution of the work. OIL will not compensate to the party in any way for any loss of man and material.

12.10 If due to improper execution of the work or due to negligence on the part of the party's workmen, OIL's property is damaged, the parties will compensate for the loss.

12.11 The party will submit six set of operation and maintenance instruction manual with each high mast set and on site drawings of all the components of mast.

12.12 All the works shall be carried out as per relevant codes, practices rules and regulations. The workmanship will be of very high standard.

12.13 Party shall make its own arrangement for boarding and lodging of their working personnel.

12.14 The work shall be carried out under direct supervision of the party. The party shall submit monthly progress report of work to the Engineer-in-charge in writing.

12.15 If the job is not completed in the stipulated time, the contractor shall be penalized at the rate of 0.01% of the unfinished job per month.

12.16 Any deviation shall be clearly spelled out along with the offer.

12.17 Verticality and straightness measurement shall be carried out and these should be within the limits as specified by manufacturer for wind velocity, earthquake zone mentioned in Tender.

12.18 A separate test certificate of the winch shall be submitted.

12.19 Supplier's Test Certificate shall be submitted for each reel of rope.

12.20 Test certificate of chemical composition and mechanical properties of Sheets and Flange

Plates shall be submitted as per the relevant Standards.

12.21 Test certificate of Head Frame Assembly, Mast sections, Trailing cable and cable connector as per relevant standards shall be submitted.

12.22 Welding and Fabrication detail shall be submitted to OIL. These should be as per relevant standard Rules, Regulations and practices.

12.23 Principles and details of joints shall be shown on drawings which will be submitted immediately after placement of order.

12.24 The thickness of internal and external galvanization shall be as per B5729 and IS 4759 and a test certificate shall be submitted confirming the minimum thickness of galvanization 80 micron.

12.25 Detailed dimensional drawing of the complete Mast including the dimensional details of Base door opening, the distance from the Mast Flange plate to the bottom of the door etc. should be submitted after placement of purchase order.

12.26 A drawing with details of Head Frame Assembly complete with Pulley, Guides, Ropes, covering to stop access of birds or other objects/rains etc. and power wiring arrangement should also be submitted after placement of purchase order.

12.27 Heat resisting cable shall be used between lamp holders and circuit connection points. Manufacture's Test Certificate as per relevant standard shall be submitted after placement of order.

12.28 Type of light distribution diagram will be submitted immediately after placement of purchase order.

12.29 All components shall be designed to require the minimum of maintenance and skilled attention and also to allow routine maintenance to be carried out quickly and easily with a minimum use of tools.

12.30 Every reasonable precaution and provision shall be incorporated in the design of the equipment for the safety and security of the system and of those concerned with its operation and maintenance.

12.31 The electrical installation shall comply of all appropriate statutory requirements, rules, regulations, standards and practices.

12.32 All metal work including luminaries, control gear units and luminaries carriage shall be bonded to the earth core of the luminaries supply cable. The earth continuity from luminaries carriage shall be via a single core of the multi-core cable.

12.33 The Mast shall be ventilated. Details by means of which this is achieved shall be submitted after placement of order.

12.34 The average rate of raising and lowering shall be not less than 3 meters per minute. Initial supply of oil for winch shall be given by the party.

12.35 High mast and accessories with fitting will be inspected by OIL's, Engineer at the premises of supplier before dispatch.

12.36 Party should submit credential to establish that they have executed successfully supply, erection, testing and commissioning of similar type of high mast in at least two Govt, semi-govt or PSU organizations. The manufacturer of the make offered by the party must have the experience of manufacturing of atleast 100 Nos of similar type high mast in last 5 years from the date of enquiry. Party/Authorised dealer must have experience of erection and commissioning of at least 5 Nos of similar high mast lights in Zone V area. Performance certificate of satisfactory completion of jobs and trouble free operation of the high mast offered from those organizations shall be submitted. Offer without any of these documents will be liable for rejection

12.37 Test certificate of steel plate, anchor plate, wire rope, Drum winch, wind velocity test and galvanization thickness shall be furnished along with quotation.

12.38 Party should fill up the Data sheet as per Annexure-II failing which offer is liable for rejection.

12.39 High mast should be designed to have maintenance free life of 25years and should be guaranteed for a period of 25 years against any manufacturing / design defects.

12.40 The construction of high mast must be of suitable design such that it can withstand the abnormal climatic condition which is normally encountered in this part of the country. It may also be noted that the location comes under Seismic zone V i.e. Earth quake prone area.

12.41 Self supporting 4 legged FRP platform ladder of suitable height of 8.10 feet shall be supplied for maintenance of high mast fitting when mast is lowered. Ladder shall be supplied with locking facility with the mast.

Documents : The following documents are to be submitted along with the offer for technical scrutiny failing which offer shall be liable for rejection.

1. RCC foundation details (2 sets) suitable for Zone V
2. Design calculations of foundation of high mast(2 sets)
3. Design calculation of high mast
4. Complete Catalogue of high mast ,luminaries and aviation light
5. General Arrangement (GA) diagram and Circuit diagrams of Feeder Pillar.
6. Illumination level chart
7. Test certificate of steel plate, anchor plate, wire rope, Drum winch, wind velocity test and galvanization thickness
8. Quality Assurance Plan for High mast shaft and accessories.
9. Credentials/ Experience certificates indicated as per Para: 12.36
10. Filled in data sheet as per Annexure II

SPECIAL TERMS AND CONDITIONS

1. Materials should be procured from original Engineering manufacturer (OEM)/ authorized dealers only. In case of authorized dealers valid authorized dealership certificate should be submitted along with the offer.

2. The bidder should have experience of successfully executing similar order (i. e., supplying and commissioning) of at least 1 (one) no. of 30meter high mast to Central Govt./State Govt./ PSU/ Public Ltd company in the last 3 years as on bid closing date. Documentary evidence for the same in the form of P.O. along with invoice to be submitted along with offer.

3. High Mast Foundation design should as per zone-V Earthquake categorization, bidder has to certify the same in their offer.

4. Quotation with catalogue / leaflet/literature should be forwarded to Chief Electrical engineer Oil India Ltd. Moran.

5. Technical catalogue/ leaflet, Operation & maintenance manual of the panel should be submitted along with the offer otherwise offer will be rejected.

6. The quotations along with the following documents should be submitted to us for technical scrutiny:

- i) Details of RCC foundations, 2 sets suitable for Zone V
- ii) Design calculations of foundation of High Mast (2 sets)
- iii) Design calculations of High Mast,
- iv) Catalogue of high mast and luminaries.
- v) General arrangement (GA)diagram & circuit diagrams of Feeder Pillar.
- vi) Illumination level chart.
- vii) Test certificates of steel plate, anchor bolts/plates, wire rope,drum winch, wind velocity test & galvanisation thickness.
- viii) Quality Assurance Plan of manufacturer for high mast shaft and accessories .
- iX) Radiographic test of High Mast.

<p>7. High Mast & accessories with all fittings will be inspected by OIL's Engineers at the premises of the supplier/ manufacturer before dispatch. Radiographic test must be carried out in presence of OIL's representative at main workshop.</p> <p>8. Packing should be adequate to avoid transit damage and ingress of moisture.</p> <p>9. High Mast should be designed to have a maintenance free life of 25 years and should be guaranteed for a period of 25 years against any manufacturing / design defects.</p> <p>10. Make : Philips / Bajaj /Crompton Greaves/ GE.</p> <p>11. Materials are for OR Moran.</p> <p>12. The party should submit the documents related to back up services, guarantee & supply of spares from OEM or Original equipment supplier.</p> <p>13. In case of order, 2 (two) sets of maintenance & operating manuals should be supplied along with the materials.</p> <p>14. Necessary civil jobs for commissioning for commissioning of supplied panels will be carried out by supplier at their own cost.</p>	
<p><u>ITEM NO. 20</u></p> <p><u>Installation and commissioning jobs shall include:</u></p> <p>1. Delivery of all items at site by bidder.</p> <p>2. Installation, testing & commissioning of the complete light masts including feeder pillars.</p> <p>3. All cabling works from feeder pillar to mast/power tool/luminaires</p> <p>4. Making of earth pits as per IS: 3043, laying and connection of earth straps from mast and feeder pillar to earth pits.</p> <p>5. Accommodation may be provided on chargeable basis subject to availability of house.</p> <p>6. Crane service may be provided on chargeable basis subject to availability of crane.</p> <p>7. Transportation of man & materials up to site is the scope of bidder.</p> <p>8. Commissioning report to be provided after the completion of work for the release of payment.</p>	

NOTE:

Bidders should submit their bids (preferably in tabular form) explicitly mentioning compliance / non compliance to all the NIT terms and conditions of NIT.

Technical Bid Checklist**Annexure-EEE**

Tender No.			
Bidder's Name :			
		Compliance by Bidder	
SL. NO.	BEC / TENDER REQUIREMENTS	Indicate 'Confirmed' / 'Not Confirmed' / Not applicable	Indicate Corresponding page ref. of unpriced bid or Comments
1	Bidder to confirm that he has not taken any exception/deviations to the bid document .		
2	Confirm that the product offered strictly conform to the technical specifications.		
3	Confirm that the Offer has been made with Bid Bond / Bank Guarantee / Earnest Money along with the offer (Wherever Applicable) ?		
4	Confirm unconditional validity of the bid for 120 days from the date of opening of techno-commercial bid.		
5	Confirm that the prices offered are firm and / or without any qualifications?		
6	Confirm that all relevant fields in the on-line bidding format been filled in by the bidders for the items quoted by them.		
7	Confirm that the the price bid is in conformity with OIL's online bidding format ?		
8	Confirm that the Bid comply with all the terms & conditions ?		
9	Confirm that the offers and all attached documents are digitally signed using digital signatures issued by an acceptable Certifying Authority (CA) as per Indian IT Act 2000.		
10	CONFIRM THAT YOU HAVE SUBMITTED THE DULY SIGNED INTEGRITY PACT DOCUMENT (Wherever Applicable)		
11	CONFIRM THAT YOU HAVE SHALL SUBMIT PERFORMANCE BANK GUARANTEE AS PER NIT IN THE EVENT OF PLACEMENT OF ORDER ON YOU (Wherever Applicable)		
12	CONFIRM THAT YOU HAVE SUBMITTED DOCUMENTS AS PER GENERAL QUALIFICATION CRITERIA		
13	Confirm that you have submitted Name and Full Address of Issuing Bank including Telephone, Fax Nos and Email id of branch manager where Bid security has been submitted as Bank Guarantee.		

NOTE: Please fill up the greyed cells only.

Response Sheet**Annexure-FFF**

Tender No.	
Bidders Name	

Bidders Response Sheet

Sl No.	Description	Remarks
1	Name of Bidder	
2	Whether tender document purchased from OIL's offices.	
3	Place of Despatch	
4	Whether Freight charges have been included in your quoted prices	
5	Whether Insurance charges have been included in your quoted prices	
6	Make of quoted Product	
7	Offered Validity of Bid as per NIT	
8	Delivery Period in weeks from placement of order	
9	Complied to Standard Payment Terms of OIL or not.	
10	Bid Security Submitted (if applicable)	
11	Details of Bid Security Submitted to OIL (if applicable)	
	a) Bid Security Amount (In Rs):	
	b) Bid Security Valid upto:	
12	If Bid security submitted as Bank Guarantee, Name and Full Address of Issuing Bank including Telephone, Fax Nos and Email id of branch manager	
13	Bid Security if Not submitted reasons thereof	
14	Whether you shall submit Performance Security in the event of placement of order on you (if applicable)	
15	Integrity Pact Submitted (if applicable)	
16	Whether submitted documents in support of General Qualification criteria of NIT	
17	If bidder is Small scale unit whether you have quoted your own product	
18	If bidder is Small scale unit whether you are eligible for purchase preference (as per Govt guidelines)	
19	Whether filled up the bank details for online payment as per Annexure GGG	

NOTE: Please fill up the greyed cells only.

ANNEXURE - GGG

**(TO BE FILLED UP BY ALL THE VENDOR IN THEIR OWN LETTER HEAD)
(ALL FIELDS ARE MANDATORY)**

Tender No. :.....
Name of Beneficiary :M/s.....
Vendor Code :.....
Address :.....
.....
Phone No. (Land Line) :.....
Mobile No. :.....
E-mail address :.....
Bank Account No. (Minimum
Eleven Digit No.) :.....
Bank Name :.....
Branch :.....
Complete Address of your
Bank :.....
IFSC Code of your Bank
a) RTGS :.....
b) NEFT :.....
PAN :.....
VAT Registration No. :.....
CST Registration No. :.....
Service Tax Registration No. :.....
Provident Fund Registration :.....

I/We confirm and agree that all payments due to me/us from Oil India Limited can be remitted to our above mentioned account directly and we shall not hold Oil India Limited responsible if the amount due from Oil India Limited is remitted to wrong account due to incorrect details furnished by us.

Office Seal

.....
Signature of Vendor

**Counter Signed by Banker:
Seal of Bank:**

Enclosure: Self attested photocopies of the following documents-

- 1) PAN Card
- 2) VAT Registration Certificate
- 3) Service Tax Registration
- 4) CST Registration
- 5) Provident Registration Certificate
- 6) Cancelled cheque of the bank account mentioned above (in original).
- 7) Bank Statement not older than 15 days on the date of submission.