



ऑयल इंडिया लिमिटेड
(भारत सरकार का उद्यम)
Oil India Limited
(A Government of India Enterprise)

PO : Udayan Vihar
Guwahati – 781171, Assam (India)
Phone: +91-361-2594286
Fax: +91-361-264386
Email: bikramjit_singha@oilindia.in
erp_mm@oilindia.in



INVITATION TO e-BID UNDER COMPOSITE BID SYSTEM

Tender No. & Date	: SGI8632P19 dated 13.07.2018
Tender Fee	: INR 1,000.00 (Non-Refundable)
Last Date of Sale of Tender Document	: 09.08.2018 upto 15.30 Hrs.
Bid Security	: INR 33,640.00
Bidding Type	: SINGLE STAGE COMPOSITE BID SYSTEM
Bid Closing on	: 16.08.2018 at 11.00 Hrs.
Bid Opening on	: 16.08.2018 at 14.00 Hrs.
Bid Validity	: Bid should be valid for 90 days from bid closing date.
Bid Bond Validity	: Bid Bond should be valid upto 16.02.2019. (Bid bond format has been changed. Please submit bid bond as per revised format)
Performance Guarantee	: Applicable @ 10% of order value.
Integrity Pact	: Not Applicable

OIL INDIA LIMITED invites electronic bids from Indigenous bidders under **NATIONAL COMPETITIVE BIDDING (NCB)** on **SINGLE STAGE COMPOSITE BID SYSTEM** through its e-procurement site for the items detailed below –

Item No.	Item Description	Quantity	UoM
10	Feeder Pillar with Panel (Technical Details As per Annexure – AA)	1	NO
20	Installation & commissioning of Item 10	1	LSM

The general details of tender can be viewed by opening the eRFx [Tender] under RFx and Auctions in the e-portal through Guest Login. The details of tendered items can be found in the Item Data and details uploaded under Technical RFX. The bidding document is available in the Technical RFX -> External Area -> Tender Documents.

STANDARD NOTES:

- 1.0 The tender will be governed by “General Terms & Conditions for National Tender (National Competitive Bidding)” for e-Procurement as per Booklet No. MM/LOCAL/E-01/2005(For e-tenders).
- 2.0 This Bidding document consists of:
 - (i) Annexure AA : Technical Specification
 - (ii) Annexure BB : Bid Rejection Criteria / Bid Evaluation Criteria
 - (iii) Annexure CC : Commercial Check List
 - (iv) Annexure DD : Price Schedule
 - (v) Annexure EE : Annual Turn Over and Net Worth Certificate
 - (vi) Annexure FF : Addendum to Bid Security and Performance Security Clause

Booklet No. MM/LOCAL/E-01/2005(For e-tenders) have been uploaded separately in the Technical RFx -> External Area - > Tender Documents.

- 3.0 For obtaining User ID and Password for accessing the tender document and for submission of bids, interested bidders are requested to go for Online Registration. Please visit the url: <https://etender.srm.oilindia.in/irj/portal> and click on the link ‘Supplier Enlistment for E-Tender’ for online registration and generation of user id and password. Bidders are advised to apply for user ID and password at least 7(seven) days prior to the last date of tender fee payment for their own interests. User ID’s shall be processed within 4(four) days subject to submission of complete information by the bidder. Once the registration is completed user id and password will be assigned to the bidder. The same user id and password may be used for participating in OIL’s future tender also.

- 3.1 After completion of the Online Registration process and receipt of user id and password, bidder may submit the tender fee online (Non-refundable). **Tender fee must be paid online through OIL’s payment gateway only and no other instrument (Cash/DD/Cheques/Cashier Cheque, etc) will be acceptable.** Please refer the New Vendor Manual uploaded alongwith the tender and also available in the e-portal page for procedure for submission of tender fee and EMD online. *For bidders having existing user id and password issued by OIL, same may be used for submission of bid after payment of tender fee.* On receipt of requisite tender fee, bidder will be allowed to participate in the tender through OIL’s e- Procurement portal. No physical tender documents shall be submitted.

NOTE: PSUs and SSI units are provided tender documents Free of Cost (as per Govt. guidelines), however they have to apply to OIL's designated office to issue the tender documents before the last date of sale of tender document mentioned in the tender.

- 4.0 Bidder seeking benefits of MSME and Purchase Preference Policy (Linked with Local Content) shall clearly indicate the same in the tender with proper documents as stipulated in the tender.
- 5.0 Bidders to note that Govt. of India under Micro, Small and Medium Enterprises Development (MSMED) Act 2006, has proclaimed the Public Procurement Policy, 2012 with effect from 1st April, 2012 in respect of procurement of goods and services, produced and provided by micro and small enterprises, by its Ministries, Departments and Public Sector Undertakings for promotion and development of Micro and Small Enterprises. A new Clause on applicability of Public Procurement Policy for procurement of goods from Micro and Small Enterprises (MSE) in the tender is furnished vide Annexure – I, Amendment to General Terms & Conditions for National Tender (National Competitive Bidding)” for e-Procurement as per Booklet No. MM/LOCAL/E-01/2005(For e-tenders). Bidders are requested to take note of the same and to submit their offers accordingly. **Bidders who are allowed to participate against the tender as MSEs must quote their own products failing which their bids will be rejected.**
- 6.0 OIL INDIA LIMITED (OIL) has upgraded its E-tender Portal. As part of the new system, the intending bidder must have Encryption Certificate along with Digital Signature Certificate (DSC) of Class III [Organization]. **All the Bids must be Digitally Signed using “Class III” digital certificate (e-commerce application) with ‘Certificate Type: Organisation Certificate’ as per Indian IT Act obtained from the licensed Certifying Authorities operating under the Root Certifying Authority of India (RCAI), Controller of Certifying Authorities (CCA) of India. The bid signed using other than “Class 3 with Organisation’s Name” digital certificate, will be rejected.**

- 7.0 EMD must be paid either through online mode or submitted as Bank Guarantee/LC. No DD/Cheques/Cashier Cheque or any other mode will be acceptable.
- 8.0 Please note that all tender forms and supporting documents are to be submitted through OIL's e-Procurement site only except following documents which are to be submitted manually in sealed envelope super scribed with Tender no. and Due date to **The Deputy General Manager - Materials (PL), Oil India Limited (Pipeline Headquarter), P.O. Udayan Vihar, Guwahati -781171 before 14.00 Hrs. IST on the Bid Closing Date** mentioned in the Tender.
- a) Bid Security(EMD) submitted in the form of Bank Guarantee.
 - b) Detailed Catalogue (if any).
 - c) Any other document required to be submitted in original as per tender requirement.

All documents submitted in physical form should be signed on all pages by the authorised signatory of the bidder and to be submitted in triplicate.

- 8.1 OIL has made arrangement for online confirmation of Bank Guarantee through SFMS Platform with Axis Bank, Guwahati. Therefore, bidders submitting Bid Security in the form of Bank Guarantee must route the BG through SFMS platform as per following details –

- a. (i) **MT 760/MT 760 COV for issuance of bank guarantee**
- (ii) **MT 767/MT 767 COV for amendment of bank guarantee**

The above message/intimation shall be sent through SFMS by the BG issuing bank branch to Axis Bank, Guwahati Branch, IFS Code – UTIB0000140, Branch Address – Axis Bank Ltd., Guwahati Branch, Chibber House, G.S. Road, Dispur, Assam, Pin – 781005.

- b. ***The Bidder shall submit to OIL the copy of SFMS message as sent by the issuing bank branch along with the original bank guarantee.***

- 9.0 Bidders are requested to go through the **'New Vendor Manual', 'Guidelines to Bidders for participating in OIL e-tenders', 'New Instruction to bidders for submission of bid' and 'Vendor User Manual for e-tendering'** available in the e-portal home page before submitting offer in system.
- 10.0 The tender is invited under **SINGLE STAGE-COMPOSITE BID SYSTEM**. The bidder has to submit both the "TECHNO-COMMERCIAL UNPRICED BID" and "PRICED BID" through electronic form in the OIL's e-Tender portal within the Bid Closing Date and Time stipulated in the e-Tender. The "Techno-commercial Unpriced Bid" shall contain all technical and commercial details except the prices which shall be kept blank. Details of prices as per Price Schedule to be uploaded as attachment in the Attachment Tab "Notes and Attachments".

Any offer not complying with above submission procedure will be rejected as per Bid Rejection Criteria mentioned in the tender.

Notes and Attachments	➔ Only price details should be uploaded
Technical attachments	➔ All technical bid documents except price details

Bidders are requested to go through the 'New Vendor Manual', 'Guidelines to Bidders for participating in OIL e-tenders', 'New Instruction to bidders for submission of bid' and 'Vendor User Manual for e-tendering' available in the e-portal home page before submitting offer in system



Oil India Limited e-Procurement

User ID *

Password *

Logon Problems? [Get Support](#)

[Supplier Enlistment for E-Tender](#)

[Important Note for New Portal Users:](#)

[Click here to View Compatibility Settings](#)

[General Guidelines to bidders](#)

[Click for User Manuals](#)

Click here for the New Manual & Instruction

© 2012 Oil India Limited. All rights reserved.
[Click for Terms of use](#), [Privacy Policy](#), [Refund Policy Docs](#)

- 11.0 Bidders are requested to examine all instructions, forms, terms and specifications in the tender. Failure to furnish all information required as per the tender or submission of offers not substantially responsive to the bid in every respect will be at the bidder's risk and may result in rejection of its offer without seeking any clarifications.
- 12.0 Bidders must ensure that their bid is uploaded in the system before the tender closing date and time. Also, they must ensure that all documents which are to be submitted in a sealed envelope are also submitted at the address mentioned in note 8.0 above before **14:00 Hrs (IST)** on the bid closing date failing which the offer shall be rejected.
- 13.0 **Deemed export/Custom Duty benefits are not applicable against this tender and bidders should furnish prices without considering these benefits.**
- 14.0 Other terms and conditions of the tender shall be as per General Terms & Conditions for National Tender (National Competitive Bidding)" for e-Procurement as per Booklet No. MM/LOCAL/E-01/2005(For e-tenders). However, if any of the clause of the Bid Rejection Criteria / Bid Evaluation Criteria (BEC / BRC) contradicts the clauses in the General Terms & Conditions of the tender and/or elsewhere, those mentioned in the BEC/BRC shall prevail.
- 15.0 To ascertain the substantial responsiveness of the bid OIL reserves the right to ask the bidder for clarification in respect of clauses covered under BRC also and such clarifications fulfilling the BRC clauses in toto must be received on or before the deadline given by the company, failing which the offer may be summarily rejected.
- 16.0 **No press advertisement will be published regarding amendment to Bidding Document or extension of Bid Closing Date. The same will be uploaded in OIL's website and informed to all prospective bidders who have received the bidding documents. Bidders to keep themselves updated.**

Sd-
(M.B. SINGHA)
SR. MANAGER MATERIALS (PL)
FOR GENERAL MANAGER - MATERIALS (PL)
FOR: CHIEF GENERAL MANAGER (PLS)

TECHNICAL SPECIFICATION**A. Technical Features of POLYCARBONATE Panel**

1. Materials: Thermoplastic Polycarbonate (PC)
2. Gasket: Internally embedded made of Polyurethane
3. Degree of Protection: IP55
4. Fire Protection in the event of internal faults Minimum requirements:
 - Glow wire test in accordance with IEC 60 695-2-11- UL Subject 94
 - 650 Degree C for boxes & cable glands
 - 850 Degree C for conducting components
5. Burning behaviour:
 - Glow wire test in accordance with IEC 60 695-2-11-960 Degree C
 - UL Subject 94- V2
 - flame retardant & self-extinguishing.
6. Degree of protection against mechanical load: IK 08 (5 Joule)
7. Toxic behavior: Halogen, Silicon free, conform to RoHS directive 2002/95/EC
8. Temperature resistant: -40 Deg. C to +120 Deg. C
9. Chemical resistant: Acid, Lye, Petrol, Mineral Oil & partially resistant from Benzene
10. Rated Insulated Voltage: AC/DC 690V
11. Cable entries: Through cable plate
12. Protection Class: Class II, totally insulated
13. Type test certificate: Should hold type test certificate with switchgear assemblies (TTA), according to IEC 60 439-1 (IS 8623), AND CPRI

B. Technical Specification of feeder Pillar Enclosure

1. Enclosure Material: Polycarbonate
2. Degree of Protection: IP55
3. Bus bar rating: 400A (RYB: 20X10MM, N: 12X10 & PE:12X05MM CU)
4. Bus bar short time current capacity: 30kA Peak
5. Dimension: 2900 [L] x 2150 [H] x 920 [D] mm(maximum)
6. Finish: RAL 7035
7. Accessories: RAL 7035 / 7032
8. Mounting structure: RAL 7016
9. Weight: 750 kgs or less(Appx.)
10. Mounting Type: Outdoor / Floor mounting
11. Cable entry: Bottom
12. System voltage: 433V,50HZ,4Wire

C. Equipment details of the Feeder Pillar Panel

1. MCCB 400A FP 36kA: 3 Nos. (two incomers one bus-coupler)
2. Rotary Handle: For all MCCBs
3. Spreader Link (Set of 4): For all cable termination.
4. Earth Leakage device for both Incomer: 2 Nos
5. Outgoing:
 - i. MCCB 160A FP 36kA: 2 Nos
 - ii. MCCB 100A FP 25kA: 2 Nos
 - iii. MCCB 63A FP 25kA: 6 Nos
 - iv. MCCB 32A FP 25kA: 8 Nos
6. Miniature Circuit Breaker 16A SP 10kA: 1 Nos (for local supply)
7. Danger Plate: On both Front & back side of the Panel (In English, Assamese & Hindi)
8. Terminal Block: As Required (Sizes as per current rating & size of cables)
9. Marking Label: For all incomer, outgoing & bus coupler panel.

10. 3 Lock & 2Key mechanical interlock
11. Wiring Accessories, Earth strip, Sleeves, Ferrules, Dinrail, & other accessories as per requirement
12. Copper Earth bus should be provided inside the Panel.
13. "415V Feeder Pillar Panel" should be written on top of the Panel.
14. Busbar & Accessories: 400A Copper Busbar for main Bus (50mmX10mm Cu)
Minimum size: for earthing Bus (30mmX10mm Cu) minimum size

D. Recommended/Given cable size:

1. Incoming: 1 & 2 1RX4CX240Sq. mm AL Cable
2. Outgoing 1RX4CX120Sq.mm AL Cable(160A): 2 Nos.
3. Outgoing 1RX4CX95Sq.mm AL Cable(100A): 2 Nos.
4. Outgoing 1RX4CX50Sq.mm AL Cable(63A): 6 Nos.
5. Outgoing 1RX4CX16Sq.mm AL Cable(32A): 8 Nos.
6. Outgoing 1RX2CX2.5Sq.mm CU Cable(16A): 1 No.

E. DOCUMENTS/ SUBMITTALS:

- a) Bidder should provide detail dimensional drawing & SLD for technical evaluation without which the offer will be considered non responsive and rejected.
- b) The supplier shall obtain approval for the following drawings, documents. All electrical details shall be submitted within 45 days of placement of order. OIL shall require minimum 30 days' time for approval of drawings. The approval time may increase depending upon clarifications required from the supplier.
 - GA drawing showing all details, including constructional detail and component layout of the Panel
 - Busbar detailed sizing calculation. The design shall be such that the temperature rise will be within limits as per IS/IEC.
- c) Four sets of the following documents shall be submitted with the supply
 - Approved GA drawing showing all details, including constructional detail and component layout for panels
 - Approved Single line Power and Control Circuit diagrams
 - Technical specification of all equipment
 - Bill of materials with catalogues of various components.
 - Type test certificate from reputed test house accredited by National Accreditation Board for testing and calibration Laboratories (NABL), India for Short time current withstand test (50 kA for 1 sec) and temperature rise test of the panel.
 - Guarantee/Warranty Certificate
 - List of recommended spare parts with part no. for two year

F. TEST AND INSPECTION:

- a) All routine tests shall be carried out as per relevant IS and IEC.
- b) The equipment shall be inspected by engineer(s) of OIL prior to dispatch. Prior intimation at least 15 days in advance to be given to OIL for inspection before dispatch. Routine tests in accordance with relevant IS shall be carried out at manufacture's works which shall be witnessed by OIL's engineer(s). The inspection shall include accuracy of dimensions & circuitry as per approved drawings, insulation tests, mechanical & electrical operation tests, primary current injection tests and any other test of the relays as recommended by the manufacturer. All necessary arrangements for the tests shall be made by the supplier at their works during the inspection. All to & fro charges, boarding /lodging of OIL Engineers shall be borne by OIL. Bidder not to include the same in their quote.
- c) Any alteration requirements pointed during the inspection shall be carried out by the manufacturer and confirmed before dispatch, without which dispatch clearance shall not be given.
- d) Copies of the test certificates along with bound copies of complete test results shall be submitted for approval of OIL prior to dispatch of the PCC. This shall include complete reports and results of the routine tests as also certified copies of the type tests.

G. WARRANTY:

The equipment shall be of best quality and workmanship. The Panel along with all electrical equipment shall be guaranteed for 12 (Twelve) months from the date of commissioning against defects arising due to material, workmanship or design.

H. INSTALLATION AND COMMISSIONING OF PANEL

1. Installation, Testing & Commissioning of PANEL -

- (i) Shall be carried out under direct supervision of Specialist engineer from PANEL manufacturer.
- (ii) Tools and tackle shall be provided by bidder for erection, testing and commissioning.
- (iii) IR value of the panel shall be checked before energizing. Earth resistance value shall also be checked before energizing of Panel.
- (iv) Earthing: Earthing of the LT Panel including installation of 2(two) numbers of chemical earth electrodes and interconnection with 50mm × 6mm GI Strip shall be in the scope of bidder. All the materials required for earthing shall be brought by the bidder. The individual electrode resistance to earth should be less than 5 ohm and grid resistance less than 1 ohm.

2. **Bidder shall arrange for to & fro travel to the installation site, local conveyance and boarding & lodging during the installation. All charges shall be borne by the bidder and should be quoted accordingly separately which shall be inclusive of GST and all other taxes including Income Tax/Corporate Tax/ Personal Tax to be deducted at source.**

BID REJECTION CRITERIA/ BID EVALUATION CRITERIA**I. BID REJECTION CRITERIA (BRC):**

The bids must conform to the specifications, terms and conditions given in the tender document. Bids shall be rejected in case the items offered do not conform to the required minimum/ maximum parameters stipulated in the technical specifications and to the respective international /national standards wherever stipulated.

Notwithstanding the general conformity of the bids to the stipulated specifications and terms and conditions, the offer/ offers will be considered as non-responsive and is/are liable to be rejected, if the following conditions are not fulfilled:

(A) TECHNICAL

- 1.0 The bidder must quote for both (a) supply and (b) installation and commissioning of Panel.
- 2.0 The Bidder shall be the manufacturer of LT Panel or their authorised dealer. In case the bidder is an authorized dealer, they must submit Dealership/Authorization Certificate from the Original Manufacturer which shall be valid till completion of order as per the bid document.
- 3.0 In case the Bidder is an OEM - The Bidder shall have experience of design, manufacture and supply of at least 1 sets of LT Panel to any Central Govt. / State Govt. / PSUs /Public Limited Companies in the last 5(five) years prior to the original bid closing date of the tender.
- 4.0 In case the Bidder is an Authorised Dealer - The Bidder shall have experience of supply, installation & commissioning of at least 1 sets of 415V PCC Panel/ PMCC Panel/MCC Panel, of the same Manufacturer whose item has been quoted in the tender, to any Central Govt./ State Govt. / PSUs /Public Limited Companies in the last 5(five) years prior to the original bid closing date of the tender
- 5.0 Bidder shall submit documentary evidences such as purchase order and completion certificate of relevant previous supplies or Tax Invoice or Payment Certificate or Consignee receipted delivery challan or Performance Certificate and other necessary details & documents along with offer for meeting clause no. 2.0, 3.0 and 4.0 above.
- 6.0 One manufacturer can quote only through one supplier.
- 7.0 One supplier can quote based on an authority letter from one manufacturer only.
- 8.0 The bid shall be rejected, in case of any change of the manufacturer after submission of bid.
- 9.0 A job/supply executed by a bidder for its own organization/subsidiary cannot be considered as experience for the purpose of meeting Bid Rejection Criteria/ Bid Evaluation Criteria.
- 10.0 Size Conformity: Bidder should confirm that Panels supplied by them must be of size 2900mm [L] x 2150mm [H] x 920mm [D] or less.
- 11.0 In absence of requisite documents in support of the above clauses, OIL reserves the right to reject the bid without making any reference to bidders.
- 12.0 **Delivery Period**: **Delivery and Installation & Commissioning of the LT Polycarbonate Feeder Pillar Panel shall be completed within 6(Six) months from the date of issue of Purchase Order. Bidder shall categorically confirm acceptance of the delivery period in the bid.**

(B) FINANCIAL:

- 1.0 Annual Financial Turnover of the bidder during any of preceding three financial/accounting years from the original bid closing date should be at least INR 8,41,000.00.
- 1.1 **Net worth** of bidder must be positive for preceding financial/ accounting year.
- 2.0 Considering the time required for preparation of Financial Statements, if the last date of preceding financial/accounting year falls within the preceding six months reckoned from the original bid closing date and the Financial Statements of the preceding financial/accounting year are not available with the bidder, then the financial turnover of the previous three financial/accounting years excluding the preceding financial/accounting year will be considered. In such cases, the Net worth of the previous financial/accounting year excluding the preceding financial/accounting year will be considered. However, the bidder has to submit an affidavit/undertaking certifying that the balance sheet/Financial Statements for the financial year
(as the case may be) has actually not been audited so far.

Notes:

- a) For proof of Annual Turnover & Net worth any one of the following document must be submitted along with the bid: -
 - i) A certificate issued by a practicing Chartered/Cost Accountant (with Membership Number and Firm Registration Number), certifying the Annual turnover & Net worth as per format prescribed in **ANNEXURE EE**.
- OR
- ii) Audited Balance Sheet along with Profit & Loss account.
 - b) In case the bidder is a Central Govt. Organization/PSU/State Govt. Organization/Semi-State Govt. Organization or any other Central/State Govt. Undertaking, where the auditor is appointed only after the approval of Comptroller and Auditor General of India and the Central Government, their certificates may be accepted even though FRN is not available. However, bidder to provide documentary evidence for the same.

(C) COMMERCIAL

- 1.0 Bids are invited under **SINGLE STAGE COMPOSITE BID SYSTEM**. Bidders shall quote accordingly.
- 2.0 **Bid security of INR 33,640.00 shall be furnished as a part of the bid.** Any bid not accompanied by a proper bid security in ORIGINAL will be rejected without any further consideration. For exemption for submission of Bid Security, please refer Clause No. 8.8 of General Terms & Conditions for National Tenders (National Competitive Bidding), Booklet No. MM/LOCAL/E-01/2005 (For E-tenders). **The Bid Security shall be valid till 16.02.2018**
- 3.0 The prices offered will have to be firm through delivery and not subject to variation on any account. A bid submitted with an adjustable price will be treated as non-responsive and rejected.
- 4.0 **Validity of the bid shall be minimum 90 days from the Original Bid Closing date. Bids with lesser validity will be rejected.**
- 5.0 All the Bids must be Digitally Signed using Class III digital certificate (e-commerce application) with '**Certificate Type: Organisation Certificate**' as per Indian IT Act obtained from the licensed Certifying Authorities operating under the Root Certifying Authority of India (RCAI), Controller of Certifying Authorities (CCA) of India. **The bid signed using other than "Class 3" digital certificate, will be rejected.**
- 6.0 Successful bidder will be required to furnish a Performance Bank Guarantee @10% of the order value. The Performance Security specified above must be valid for 3(three) months beyond the Warranty period indicated in Clause no. (G) of Annexure – AA.

- 7.0 Bids received after the bid closing date and time will be rejected. Similarly, modifications to bids received after the bid closing date & time will not be considered.
- 8.0 Bids containing incorrect statement will be rejected.
- 9.0 No offers should be sent by Telex, Cable, E-mail or Fax. Such offers will not be accepted.
- 10.0 The following points are deemed as “non-negotiable” and offer shall be rejected straightaway without seeking clarification:
- i. Validity of bid shorter than validity indicated in the tender.
 - ii. Original Bid Security not received within the stipulated date and time mentioned in the tender.
 - iii. Bid security with (a) Validity shorter than the validity indicated in tender and/or (b) Bid security amount lesser than the amount indicated in the tender.
- 11.0 Bidder must accept and comply with the following clauses as given in the Bid Document, failing which bid shall be liable for rejection:
- i. Liquidated Damages
 - ii. Guarantee of material
 - iii. Arbitration / Resolution of Dispute
 - iv. Force Majeure
 - v. Applicable Laws
- 12.0 **DELIVERY LOCATION:** The LT Polycarbonate Feeder Pillar Panel is to be delivered, installed and commissioned at the following address -
- Oil India Limited
Pipeline Headquarters, Narangi,
P.O. Udayan Vihar, Guwahati
PIN -781171, Assam**
- 13.0 **PRICE SCHEDULE:**
- Bidder shall submit the Price Break up as per Annexure DD. Bidders should fill up the annexures, sign and upload under “Notes & Attachments” > “Attachments” only. Evaluation of offers shall be done on F.O.R. Destination, Guwahati basis.**
- 13.1 The bids conforming to the specifications, terms and conditions stipulated in the enquiry and considered to be responsive after subjecting to the Bid Rejection Criteria will be considered for further evaluation as per the Bid Evaluation Criteria given below:
1. Basic Material Value
 2. Packing & Forwarding Charges, if any
 3. **Total Ex-works Value (1+2)**
 4. GST on Total Ex-Works Value
 5. Compensatory Cess, if any
 6. **Total FOR Despatching Station Value (3+4+5)**
 7. Freight Charges upto destination
 8. GST on Freight Charges
 9. Insurance Charges @0.5% of (6) inclusive of GST
 10. Installation & Commissioning Charges
 11. GST on Installation & Commissioning Charges
 12. **Total FOR Destination, Site Value (6+7+8+9+10+11)**
- 13.2 **Comparison of offers shall be done on Total Value vide Srl. No. 12 (Total FOR Destination Value).**

- 13.3 Domestic bidders must quote inland freight charges upto Destination. In case bidder fails to quote inland freight charges, highest freight quoted by domestic bidder (considering pro-rata distance) against this tender or OIL's estimated freight, whichever is higher, shall be loaded to their offer for comparison purpose.
- 13.4 If there is any discrepancy between the unit price and the total price, the unit price will prevail and the total price shall be corrected. Similarly, if there is any discrepancy between words and figure, the amounts in words shall prevail and will be adopted for evaluation.
- 13.5 Other terms and conditions of the enquiry shall be as per General Terms and Conditions for LCB Tender. However, if any of the Clauses of the Bid Rejection Criteria / Bid Evaluation Criteria (BEC/BRC) mentioned here contradict the Clauses in the General Terms & Conditions of LCB Tender of the tender and/or elsewhere, those mentioned in this BEC/BRC shall prevail.
