

Corrigendum No.1

This **Corrigendum No. 1** dated **16.02.2026** to EXPRESSION OF INTEREST (EOI)NO.: **EOI/PSS/STF-EOI/2025-26/002** dated **06.02.2026** for “**Setting up a modular Desalination Plant (Zero Liquid Discharge) for treating Effluent Treatment Plant treated water of 3000 KLPD processing capacity at STF-Madhuban, Duliajan, Assam to generate permeate water suitable for industrial re-use /surface drainage on Engineering, Procurement & Construction (EPC) and Operation & Maintenance (O&M) for 05 years execution mode**” is issued to amend the following:

1.0 Additional parameters have been incorporated into the **Clause No. 6 of Annexure-I** (Notes to the Respondent) of **EOI NO.: EOI/PSS/STF-EOI/2025-26/002**

<u>Desalination Plant Feed Water (Clarified Water) Parameters (Additional)</u>				
Sl No.	Parameters	Min. Value	Max. Value	Unit
1	Total Hardness (as CaCO ₃)	120	160	mg/L
2	Alkalinity (as CaCO ₃)	1750	2100	mg/L
3	Calcium as Ca ²⁺	16	24	mg/L
4	Magnesium as Mg ²⁺	19	24	mg/L
5	Silica (as SiO ₂)	55	70	mg/L