



ऑयल इंडिया लिमिटेड
(भारत सरकार का उद्यम)

(A GOVT. OF INDIA ENTERPRISE)
CONTRACTS DEPARTMENT
PIPELINE HEADQUARTERS
GUWAHATI – 781171, ASSAM
E-mail: contracts_phq@oilindia.in

CONTRACT SECTION, PHQ NOONMATI

Date: 09.10.2025

CORRIGENDUM – 1 FOR OIL TENDER NO. GEM/2025/B/6672037

1. THIS CORRIGENDUM IS BEING ISSUED AS PER THE FOLLOWING:

a) EXTENSION OF SUBMISSION DEADLINE: **17.10.2025 (11:00 HRS.)**

b) **Technical specification:**

(i) **As per OISD-129 guidelines**, - External inspection Only and all Execution arrangements under the scope of the vendor.

(ii) **Total number of thickness measurement spots per tank:** - There is only one tank for the inspection concerned, and the calculation is for the no. of measurement spots.

(iii) **Thickness Measurement of Overground Process Piping & Fire Water Network**

Pump Station 10, Barauni : All the piping's are inside the station premises.

Diameter of station piping's: - 16"(Only inlet section - around 50 meters and overall- 10"

Diameter of Fire water Line- 12"/8".

Diameter RS-17- 14".

The number of thickness spots of the job are well within the specified quantities mentioned in the tender. Exact nos. cannot be specified.

(iv) **Thickness Measurement** – Repeater Station 17, Khagaria and number of thickness measurement spots to be covered at this station.

Clarification- Diameter- 14"

Length- 50 meters.

Address- Khagaria Town, Khagaria District, Bihar.

The number of thickness spots of the job are well within the specified quantities mentioned in the tender. Exact nos. cannot be specified.

(v)**Execution plan:** The job needs to be completed within the stipulated time mentioned in the tender. The sequence of operation is not mandatory.

(vi)**Project Duration:** The completion time schedule/duration is mentioned in the tender

(c) EXTENSION OF TECHNICAL RESPONSE OPENING DATE:**17.10.2025 (14:00 HRS.)**

ALL OTHER TERMS AND CONDITIONS SHALL REMAIN UNCHANGED IN THE ABOVE TENDER

