

OIL INDIA LIMITED
(A Government of India Enterprise)
CONTRACTS DEPARTMENT
P.O.: Duliajan- 786602, Assam

CORRIGENDUM-2 DATED: 04.04.2024 TO TENDER NO. : CDI5748P24

This Corrigendum is issued to all concerned bidders of the aforesaid tenders to notify the following:

- i) Detailed specification mentioned under **Annexure-II to SCC** for **Item No. 110** (Casement Windows Panels) under CIVIL WORK, Page No.126 of the Tender Document has been amended. The Revised specification for **Item No. 110** (Casement Windows Panels) has been attached herewith.
- ii) Bid Closing Date & Time : Extended up to 23.04.2024 [11:00 Hrs. (IST)]
- iii) Bid Opening Date & Time : Extended up to 23.04.2024 [14:00 Hrs. (IST)]

All others terms and conditions of the Bid Document remain unchanged. Details can be viewed at www.oil-india.com.


OFFICER-CONTRACTS (C)

Item No.	Item Name	Description
110	Casement Windows Panels	<p>Providing and fixing factory made uPVC glazed/wire mesh windows/doors comprising of lead free uPVC multi-chambered frame, sash and mullion/coupler (where ever required) extruded profiles having minimum wall thickness of 1.70 mm for Series R1 and R2 profiles and 2.10mm for Series R3 and R4 profiles conforming to EN: 12608 in any shape, colour and design duly reinforced with galvanized mild steel section made of required shape & size as per CPWD Specification, uPVC extruded glazing beads, interlocks and Inline sash adaptor (where ever required) of appropriate dimension, EPDM gasket, hardware, SS 304 grade fasteners of minimum 8 mm dia. with countersunk head, comprising of matching polyamide PA6 grade sleeve for fixing frame to finished wall as per IS 1367 : Part 1 to 14, plastic packers, plastic caps and necessary stainless steel screws etc. Profile of frame, sash & mullion (if required) shall be mitred cut and fusion welded/mechanically jointed duly sealed at all corners, including drilling of holes for fixing hardware and drainage of water etc. After fixing frame the gap between frame and adjacent finished wall shall be filled with weather proof silicon sealant over backer rod of approved size and quality, all complete as per approved drawing conforming to CPWD specification & direction of Engineer-in-Charge. Section of steel reinforcement and cross sections of uPVC profiles to be as per design approved by Engineer-in-Charge. Wire mesh / Glazing of plain/ toughened/ laminated/ double glass unit with / without high performance coatings as per design requirements and conforming to IS: 3548 & IS: 16231 shall be paid separately. Note:- Structural design proof checked from a Government Engineering Institute, to be provided by the manufacturer for : (i) Sites with basic wind speed > 45 m/sec as per IS 875 – Part 3 (ii) Sites with structure height more than 20m for all wind speeds: : Casement window double panels with fixed mullion with S.S. 304 friction hinges as per size and weight of sash, multi-point locking system, zinc alloy (zamak) powder coated handles. Using R3 series with frame (55mm & above) x (45mm & above) & sash (55mm & above) x (65mm & above) & mullion (55mm & above) x (65mm & above). (Height upto 1.8 metre).</p> <p>(Refer CPWD DSR 2023 9.147.E2.2)</p>