

OIL INDIA LIMITED
RAJASTHAN FIELD
JODHPUR

Amendment No. 06 dated 07.04.2025

to

OIL's Tender No.: CJI8540P25 Dated 07-02-2025

This Corrigendum is issued to notify the following clauses of the tender instead of existing:

Sl. No.	Cluse No.	Existing SECTION – IV SPECIAL CONDITIONS OF CONTRACT (SCC)	Amended SECTION – IV SPECIAL CONDITIONS OF CONTRACT (SCC)
1	BROAD SCOPE OF WORK - E	Bidder to consider the power requirements for Gas Sweetening Unit as well as CO2 compressor and other auxiliaries which will be utilised for carbon sequestration project. Necessary data for the CO2 compressor and other auxiliaries will be shared to bidder by OIL.	Bidder to consider the power requirements for Gas Sweetening Unit as well as CO2 compressor and other auxiliaries which will be utilised for carbon sequestration project. Please consider Normal Power Demand is 1.9 MW and Peak Power Demand is 2.3 MW for CCS facility (i.e. apart from the scope of this tender). The CCS facility Emergency Power Demand is approx. 100 kW (i.e. to operate instrument air compressor, and some other critical vent and drain system equipment). CCS facility: (Medium Voltage (6.6kV)): Major equipment such as: CCS LP / MP / HP compressors (1400kW) GSU compressor (1500kW, TBC). Any other data will be shared during design phase.