OIL INDIA LIMITED (A Govt. of India Enterprise)
Contacts & Purchase Department
02-A, District Shopping Centre
Saraswati Nagar
Basni
Jodhpur – 342 005
Rajasthan
E-mail: amar_singh@oilindia.in

BID CORRIGENDUM

AMENDMENT NO. 02 DATED 21.09.2026
TO
TENDER NO.: CJI2628P27

1. This addendum/corrigendum is issued to amend the following clause of NIT as under in lieu of existing:

S. No.	Tender Clause	Existing Tender Clause & Description	Amended Tender Clause & Description
1	VOLUME-II DOCUMENT TITLE: SCOPE OF WORK & SPECIAL CONDITIONS OF CONTRACT (SCC)	Clause 2.2 – Design Approval: Design Criteria: 1. Ambient (Outdoor) Design Temperature: 55°C	Under Clause 2.2 – Design Approval: Design Criteria: 1. Ambient (Outdoor) Design Temperature: The outdoor design condition for heat-load calculation and equipment selection shall be considered as per the applicable climatic design condition for Jodhpur. Maximum Operating Ambient Temperature: The selected HVAC/VRF outdoor units shall be suitable for safe and reliable operation at an outdoor ambient temperature up to 55°C

2. This addendum is issued to extend the Bid Closing/Opening dates as under:

Description	Existing Date & Time	**Extended upto**
Bid Closing Date & Time	22.09.2026 (at 15:00 Hrs. IST)	**29.09.2026** **(at 15:00 Hrs. IST)**
Technical Bid Opening Date & Time	22.09.2026 (at 15:30 Hrs. IST)	**29.09.2026** **(at 15:30 Hrs. IST)**

3. All other Terms & Conditions of the bid document shall remain unaltered.

sd/-
A. D. SINGH
Sr. Manager (C&P)